

WASTEWATER CHARACTERIZATION STUDY

CITY OF MEXICALI BAJA CALIFORNIA, MEXICO

(January - July, 2003)



**Prepared by THE CITY OF SAN DIEGO
Metropolitan Wastewater Department**

**Under subcontract with San Diego State University Foundation
SDSU Foundation Fund No. 52822A 7802 (E0001704)**

**Prepared for the State Water Resources Control Board and the California
Environmental Protection Agency**

TABLE OF CONTENTS

Titles below contain internal links to referenced Tabs.

DISCLAIMER-----	<u>TAB 1</u>
ACKNOWLEDGMENTS-----	<u>TAB 1</u>
ABSTRACT-----	<u>TAB 1</u>
INTRODUCTION-----	<u>TAB 1</u>
METHODS-----	<u>TAB 1</u>
SAMPLING LOCATIONS -----	<u>TAB 2</u>
MAPS-----	<u>TAB 2</u>
FIELD TEST RESULTS -----	<u>TAB 3</u>
LABORATORY TEST RESULTS -----	<u>TAB 4</u>
OBSERVATIONS -----	<u>TAB 5</u>
ACTIONS (DGE AND CESPM)-----	<u>TAB 5</u>
CONCLUSIONS AND RECOMMENDATIONS -----	<u>TAB 5</u>

DISCLAIMER

The statements and conclusions in this report are those of the contractor and not necessarily those of the California Environmental Protection Agency or the State Water Resources Control Board. The mention of commercial products, their source, or their use in connection with material reported herein is not to be construed as actual or implied endorsement of such products.

ACKNOWLEDGMENTS

The following agencies were the main participants in this project.

From Mexico:

Comisión Estatal de Servicios Públicos de Mexicali
Dirección General de Ecología del Estado de Baja California
Comisión Internacional de Límites y Aguas

From the United States:

California Environmental Protection Agency
State Water Resources Control Board
Regional Water Quality Control Board, Colorado River Basin-Region 7
San Diego State University Foundation
International Boundary and Water Commission
City of San Diego

ABSTRACT

The main purpose of this project was to develop and implement a wastewater sampling and laboratory analysis program to obtain baseline information regarding the quality of the wastewater in the collection system of the City of Mexicali, Baja California, Mexico. In addition, the project involved the training of personnel from the Comisión Estatal de Servicios Públicos de Mexicali (CESPM) in wastewater sampling techniques and the transfer of wastewater sampling equipment. CESPM analyzed some of the samples for the parameters they have laboratory capabilities, to obtain data for laboratory comparison studies. A total of twenty-two sampling events were conducted, at six sites per event, representing a total of twenty different sampling locations. The results of the analyses are consistent with an overall low-medium strength wastewater. pH and conductivity measurements showed a high degree of variability and extreme values at two of the sites sampled.



INTRODUCTION

The purpose of the project was to sample and analyze wastewater throughout the collection system in Mexicali to obtain baseline data to be used in support of wastewater operations and the industrial wastewater discharge control program. Training in wastewater sampling was provided to CESPM personnel and wastewater sampling equipment was issued in order to provide CESPM with the capability to continue sampling after the end of this project.

CESPM conducts routine monitoring only at the wastewater treatment plants and their laboratory analytical capabilities are limited. This project expanded the sampling into different parts of the City and the laboratory analyses included additional pollutants of concern such as cyanide, metals, pesticides, volatile and semivolatile organic compounds.

METHODS

The general sampling plan, including the initial sampling sites and schedule, was developed by a Technical Committee with representatives from CESPM, Baja California's Department of Ecology, California's Environmental Protection Agency, State Water Resources Control Board, California Regional Water Quality Control Board (Colorado River Basin-Region 7,) San Diego State University Foundation and the City of San Diego. CESPM selected additional sampling sites as the program progressed and laboratory data became available.



The sampling activities involved setting-up and programming automatic samplers one day, and collecting the samples the next day. The schedule was set to start a sampling event every eight days, so that all days of the week would be represented after seven sampling events. A total of twenty-two sampling events were conducted, collecting six samples per event at a total of twenty different sites. City of San Diego personnel performed all of the sampling activities at first, while training personnel from CESPM. Gradually CESPM took over the sampling and delivered the samples to City of San Diego personnel at the wastewater treatment plant in Tecate, Baja California.

The laboratory analyses were performed by the City of San Diego's Industrial Waste Laboratory. The laboratory is certified for the specific tests performed in this project by the Environmental Laboratory Accreditation Program of the State of California's Department of Health Services, Certificate No. 1985. The laboratory followed its standard quality assurance and quality control procedures established to comply with the requirements of the accreditation program.

Samples were collected as grabs or as 24-hr composites. Grab samples only represent the moment of sample collection, but are required to preserve some parameters for laboratory analysis. 24-hr composites are prepared by programming the automatic sampler to collect a sample every fifteen minutes and to switch to the next bottle after every hour. Conductivity and pH are determined for each of the twenty-four bottles and a composite is made for laboratory analyses.



The laboratory analytical methods employed are summarized in the following table:

Parameter	Analytical Method	Sample Type	Ref.
Total Suspended Solids	EPA 160.2	24-hr composite	1
Ammonia-Nitrogen	EPA 350.3	24-hr composite	1
Cyanide: amenable total	EPA 335.1 EPA 335.2	Grab Grab	1 1
Biochemical Oxygen Demand	EPA 405.1	24-hr composite	1
Chemical Oxygen Demand	EPA 410.4	24-hr composite	1
Hexane Extractable Material (HEM)	EPA 1664	Grab	2
HEM-Silica Gel Treated	EPA 1664	Grab	2
Methylene Blue Active Substances	EPA 425.1	24-hr composite	1
Organophosphorous Pesticides	EPA 614	Grab	3
Organochlorine Pesticides & PCB	EPA 608	Grab	3
Volatile Organic Compounds	EPA 624	Grab	3
Semivolatile Organic Compounds	EPA 625	Grab	3
Metals	EPA 200.8	24-hr composite	4

1. Methods for Chemical Analysis of Water and Wastewater, EPA-600/4-79-020, revised March 1983 and EPA-600/4-84-017, March 1984.
2. Environmental Protection Agency, EPA-821-R-98-002, February 1999.
3. Methods for Organic Analysis of Municipal and Industrial Wastewater, EPA-600/4-82-057, July 1982.
4. Methods for the Determination of Metals in Environmental Samples-Supplement I, EPA/600/R-94/111, May 1994.



SAMPLING LOCATIONS

The names and descriptions of the sampling sites are given in the following table (see maps on the following pages):

SITE #	NAME	DESCRIPTION
100	Planta de bombeo #2	327 liters per sec; mainly commercial (restaurants, etc.)
200	Planta de bombeo #1	830 liters per sec; site 100 plus mainly domestic
300	Planta de bombeo #3	319 liters per sec; mainly domestic (some industrial)
400	Planta de bombeo #4	Mainly industrial with some domestic
500	Colector principal dentro de los campos de Kenmex	Mainly industrial with some domestic
600	Cárcamo Palaco	43.5 liters per sec: 50% industrial, 50% domestic
700	Colector Robledo	Mainly industrial
800	Calle Séptima	Industrial
900	Calle Novena frente a Nutrimex	Industrial
1000	Frente a parque Industrial Nelson	No samples collected at this site
1100	Parque Industrial Nelson	Industrial park
1200	Calle Primera	Industrial
1300	Cárcamo Cetys	Mainly industrial
1400	Colector periférico a 200 metros de Siglo XXI	Industrial park
1500	Magaplast, S.A.	Industrial discharge (organic solvents)
1600	Efluente Melco Display Devices	Industrial discharge (metals)
1700	Parque Industrial Progreso I	Industrial park (oils and paints)
1800	Efluente Jumex	Industrial discharge (BOD, solids)
1900	Efluente Nestlé	Industrial discharge
2000	Efluente Sky Works	Industrial discharge (metals)
2100	Efluente Chromaloy	Industrial discharge (metals)



MAPS



bat Docu

~~ITS
11th included~~



SITE 1

City of Mexicali
Site 1

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
13-JAN-03	MONDAY	1_Hr_COMP	1000	Specific Conductance	2300	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1000	pH	7.8	pH
13-JAN-03	MONDAY	1_Hr_COMP	1100	Specific Conductance	2300	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1100	pH	7.8	pH
13-JAN-03	MONDAY	1_Hr_COMP	1200	Specific Conductance	2300	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1200	pH	7.7	pH
13-JAN-03	MONDAY	1_Hr_COMP	1300	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1300	pH	7.7	pH
13-JAN-03	MONDAY	1_Hr_COMP	1400	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1400	pH	7.7	pH
13-JAN-03	MONDAY	1_Hr_COMP	1500	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1500	pH	7.7	pH
13-JAN-03	MONDAY	1_Hr_COMP	1600	Specific Conductance	2300	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1600	pH	7.7	pH
13-JAN-03	MONDAY	1_Hr_COMP	1700	Specific Conductance	2300	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1700	pH	7.7	pH
13-JAN-03	MONDAY	1_Hr_COMP	1800	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1800	pH	7.7	pH
13-JAN-03	MONDAY	1_Hr_COMP	1900	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1900	pH	7.7	pH
13-JAN-03	MONDAY	1_Hr_COMP	2000	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	2000	pH	7.7	pH
13-JAN-03	MONDAY	1_Hr_COMP	2100	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	2100	pH	7.8	pH
13-JAN-03	MONDAY	1_Hr_COMP	2200	Specific Conductance	2100	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	2200	pH	7.8	pH
13-JAN-03	MONDAY	1_Hr_COMP	2300	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	2300	pH	7.8	pH
13-JAN-03	MONDAY	1_Hr_COMP	2400	Specific Conductance	2100	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	2400	pH	7.9	pH
14-JAN-03	TUESDAY	1_Hr_COMP	100	Specific Conductance	2100	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	100	pH	7.9	pH
14-JAN-03	TUESDAY	1_Hr_COMP	200	Specific Conductance	2100	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	200	pH	8.1	pH
14-JAN-03	TUESDAY	1_Hr_COMP	300	Specific Conductance	2100	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	300	pH	8.1	pH
14-JAN-03	TUESDAY	1_Hr_COMP	400	Specific Conductance	2200	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	400	pH	8.2	pH
14-JAN-03	TUESDAY	1_Hr_COMP	500	Specific Conductance	2200	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	500	pH	8.2	pH
14-JAN-03	TUESDAY	1_Hr_COMP	600	Specific Conductance	2200	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	600	pH	8.3	pH
14-JAN-03	TUESDAY	1_Hr_COMP	700	Specific Conductance	2400	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	700	pH	8.2	pH
14-JAN-03	TUESDAY	1_Hr_COMP	800	Specific Conductance	2300	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	800	pH	8.1	pH
14-JAN-03	TUESDAY	1_Hr_COMP	900	Specific Conductance	2300	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	900	pH	8.1	pH
14-JAN-03	TUESDAY	COMP_CONDUCT	950	Specific Conductance	2300	umhos/cm
14-JAN-03	TUESDAY	COMP_PH	950	pH	8.0	pH
14-JAN-03	TUESDAY	GRAB	1000	Specific Conductance	3600	umhos/cm
14-JAN-03	TUESDAY	GRAB	1000	pH	7.6	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1015	Specific Conductance	2700	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1015	pH	7.2	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1115	Specific Conductance	2400	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1115	pH	7.3	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1215	Specific Conductance	2200	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1215	pH	7.3	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1315	Specific Conductance	2500	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1315	pH	7.2	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1415	Specific Conductance	2300	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1415	pH	7.1	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1515	Specific Conductance	2300	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1515	pH	7.1	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1615	Specific Conductance	2200	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1615	pH	7.1	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1715	Specific Conductance	2800	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1715	pH	7.1	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1815	Specific Conductance	2200	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1815	pH	7.2	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1915	Specific Conductance	2100	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1915	pH	7.2	pH
21-JAN-03	TUESDAY	1_Hr_COMP	2015	Specific Conductance	2200	umhos/cm

City of Mexicali
Site 1

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
21-JAN-03	TUESDAY	1_Hr_COMP	2015	pH	7.2	pH
21-JAN-03	TUESDAY	1_Hr_COMP	2115	Specific Conductance	2100	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	2115	pH	7.3	pH
21-JAN-03	TUESDAY	1_Hr_COMP	2215	Specific Conductance	2100	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	2215	pH	7.4	pH
21-JAN-03	TUESDAY	1_Hr_COMP	2315	Specific Conductance	2100	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	2315	pH	7.4	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	15	Specific Conductance	2200	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	15	pH	7.5	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	115	Specific Conductance	2100	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	115	pH	7.6	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	215	Specific Conductance	2100	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	215	pH	7.6	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	315	Specific Conductance	2500	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	315	pH	7.6	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	415	Specific Conductance	2400	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	415	pH	7.7	pH
22-JAN-03	WEDNESDAY	COMP_CONDUCT	915	Specific Conductance	2200	umhos/cm
22-JAN-03	WEDNESDAY	COMP_PH	915	pH	7.1	pH
22-JAN-03	WEDNESDAY	GRAB	925	Specific Conductance	2200	umhos/cm
22-JAN-03	WEDNESDAY	GRAB	925	pH	7.3	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	950	Specific Conductance	2600	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	950	pH	7.7	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1050	Specific Conductance	2600	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1050	pH	7.5	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1150	Specific Conductance	2200	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1150	pH	7.3	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1250	Specific Conductance	2300	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1250	pH	7.3	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1350	Specific Conductance	2200	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1350	pH	7.3	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1450	Specific Conductance	2700	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1450	pH	7.3	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1550	Specific Conductance	2300	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1550	pH	7.2	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1650	Specific Conductance	2400	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1650	pH	7.2	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1750	Specific Conductance	2300	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1750	pH	7.4	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1850	Specific Conductance	2600	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1850	pH	7.4	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1950	Specific Conductance	2300	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1950	pH	7.5	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2050	Specific Conductance	2200	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2050	pH	7.5	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2150	Specific Conductance	2200	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2150	pH	7.5	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2250	Specific Conductance	2200	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2250	pH	7.5	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2350	Specific Conductance	2200	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2350	pH	7.4	pH
30-JAN-03	THURSDAY	1_Hr_COMP	50	Specific Conductance	2200	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	50	pH	7.4	pH
30-JAN-03	THURSDAY	1_Hr_COMP	150	Specific Conductance	2200	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	150	pH	7.5	pH
30-JAN-03	THURSDAY	1_Hr_COMP	250	Specific Conductance	2400	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	250	pH	7.5	pH
30-JAN-03	THURSDAY	1_Hr_COMP	350	Specific Conductance	2600	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	350	pH	7.5	pH
30-JAN-03	THURSDAY	1_Hr_COMP	450	Specific Conductance	2200	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	450	pH	7.6	pH
30-JAN-03	THURSDAY	1_Hr_COMP	550	Specific Conductance	2100	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	550	pH	7.7	pH
30-JAN-03	THURSDAY	1_Hr_COMP	650	Specific Conductance	1900	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	650	pH	7.6	pH
30-JAN-03	THURSDAY	1_Hr_COMP	750	Specific Conductance	2200	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	750	pH	7.6	pH
30-JAN-03	THURSDAY	1_Hr_COMP	850	Specific Conductance	2200	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	850	pH	7.6	pH
30-JAN-03	THURSDAY	COMP_CONDUCT	910	Specific Conductance	2200	umhos/cm
30-JAN-03	THURSDAY	COMP_PH	910	pH	7.3	pH
30-JAN-03	THURSDAY	GRAB	920	Specific Conductance	2200	umhos/cm
30-JAN-03	THURSDAY	GRAB	920	pH	7.4	pH

City of Mexicali
Site 1

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
06-FEB-03	THURSDAY	1_Hr_COMP	910	Specific Conductance	1900	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	910	pH	7.4	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1010	Specific Conductance	1900	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1010	pH	7.4	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1110	Specific Conductance	2100	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1110	pH	7.4	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1210	Specific Conductance	1900	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1210	pH	7.3	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1310	Specific Conductance	1900	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1310	pH	7.2	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1410	Specific Conductance	1900	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1410	pH	7.2	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1510	Specific Conductance	2400	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1510	pH	7	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1610	Specific Conductance	1900	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1610	pH	7.1	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1710	Specific Conductance	1900	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1710	pH	7.1	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1810	Specific Conductance	1800	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1810	pH	7.2	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1910	Specific Conductance	1900	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1910	pH	7.1	pH
06-FEB-03	THURSDAY	1_Hr_COMP	2010	Specific Conductance	1900	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	2010	pH	7.2	pH
06-FEB-03	THURSDAY	1_Hr_COMP	2110	Specific Conductance	2000	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	2110	pH	7.2	pH
06-FEB-03	THURSDAY	1_Hr_COMP	2210	Specific Conductance	1900	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	2210	pH	7.3	pH
06-FEB-03	THURSDAY	1_Hr_COMP	2310	Specific Conductance	1800	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	2310	pH	7.2	pH
07-FEB-03	FRIDAY	1_Hr_COMP	10	Specific Conductance	1800	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	10	pH	7.3	pH
07-FEB-03	FRIDAY	1_Hr_COMP	110	Specific Conductance	1900	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	110	pH	7.4	pH
07-FEB-03	FRIDAY	1_Hr_COMP	210	Specific Conductance	1800	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	210	pH	7.3	pH
07-FEB-03	FRIDAY	1_Hr_COMP	310	Specific Conductance	1800	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	310	pH	7.4	pH
07-FEB-03	FRIDAY	1_Hr_COMP	410	Specific Conductance	1800	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	410	pH	7.4	pH
07-FEB-03	FRIDAY	1_Hr_COMP	510	Specific Conductance	1800	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	510	pH	7.4	pH
07-FEB-03	FRIDAY	1_Hr_COMP	610	Specific Conductance	1800	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	610	pH	7.5	pH
07-FEB-03	FRIDAY	1_Hr_COMP	710	Specific Conductance	1900	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	710	pH	7.5	pH
07-FEB-03	FRIDAY	1_Hr_COMP	810	Specific Conductance	1800	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	810	pH	7.6	pH
07-FEB-03	FRIDAY	COMP_CONDUCT	1040	Specific Conductance	1900	umhos/cm
07-FEB-03	FRIDAY	COMP_PH	1040	pH	7.3	pH
07-FEB-03	FRIDAY	GRAB	1050	Specific Conductance	2300	umhos/cm
07-FEB-03	FRIDAY	GRAB	1050	pH	7.3	pH
22-FEB-03	SATURDAY	1_Hr_COMP	810	Specific Conductance	1500	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	810	pH	7.5	pH
22-FEB-03	SATURDAY	1_Hr_COMP	910	Specific Conductance	1400	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	910	pH	7.5	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1010	Specific Conductance	1400	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1010	pH	7.7	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1110	Specific Conductance	1400	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1110	pH	7.7	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1210	Specific Conductance	1400	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1210	pH	7.7	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1310	Specific Conductance	1400	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1310	pH	7.5	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1410	Specific Conductance	1400	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1410	pH	7.5	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1510	Specific Conductance	1300	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1510	pH	7.6	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1610	Specific Conductance	1300	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1610	pH	7.6	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1710	Specific Conductance	1300	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1710	pH	7.5	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1810	Specific Conductance	1400	umhos/cm

City of Mexicali
Site 1

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
22-FEB-03	SATURDAY	1_Hr_COMP	1810	pH	7.5	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1910	Specific Conductance	1300	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1910	pH	7.7	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2010	Specific Conductance	1300	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2010	pH	7.7	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2110	Specific Conductance	1300	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2110	pH	7.7	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2210	Specific Conductance	1600	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2210	pH	7.7	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2310	Specific Conductance	1400	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2310	pH	7.7	pH
23-FEB-03	SUNDAY	1_Hr_COMP	10	Specific Conductance	1300	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	10	pH	7.8	pH
23-FEB-03	SUNDAY	1_Hr_COMP	110	Specific Conductance	1300	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	110	pH	7.8	pH
23-FEB-03	SUNDAY	1_Hr_COMP	210	Specific Conductance	1400	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	210	pH	7.7	pH
23-FEB-03	SUNDAY	1_Hr_COMP	310	Specific Conductance	1400	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	310	pH	7.7	pH
23-FEB-03	SUNDAY	1_Hr_COMP	410	Specific Conductance	1400	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	410	pH	7.7	pH
23-FEB-03	SUNDAY	1_Hr_COMP	510	Specific Conductance	1400	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	510	pH	7.6	pH
23-FEB-03	SUNDAY	1_Hr_COMP	610	Specific Conductance	1500	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	610	pH	7.6	pH
23-FEB-03	SUNDAY	1_Hr_COMP	710	Specific Conductance	1500	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	710	pH	7.6	pH
23-FEB-03	SUNDAY	COMP_CONDUCT	1013	Specific Conductance	1500	umhos/cm
23-FEB-03	SUNDAY	COMP_PH	1013	pH	7.6	pH
23-FEB-03	SUNDAY	GRAB	1023	Specific Conductance	2300	umhos/cm
23-FEB-03	SUNDAY	GRAB	1023	pH	7.4	pH
02-MAR-03	SUNDAY	1_Hr_COMP	733	Specific Conductance	1700	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	733	pH	7.2	pH
02-MAR-03	SUNDAY	1_Hr_COMP	833	Specific Conductance	1700	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	833	pH	7.4	pH
02-MAR-03	SUNDAY	1_Hr_COMP	933	Specific Conductance	1900	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	933	pH	7.6	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1033	Specific Conductance	1800	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1033	pH	7.7	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1133	Specific Conductance	1800	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1133	pH	7.8	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1233	Specific Conductance	1800	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1233	pH	7.7	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1333	Specific Conductance	1700	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1333	pH	7.7	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1433	Specific Conductance	1700	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1433	pH	7.6	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1533	Specific Conductance	1700	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1533	pH	7.6	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1633	Specific Conductance	2500	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1633	pH	7.5	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1733	Specific Conductance	2000	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1733	pH	7.5	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1833	Specific Conductance	1900	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1833	pH	7.5	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1933	Specific Conductance	1900	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1933	pH	7.5	pH
02-MAR-03	SUNDAY	1_Hr_COMP	2033	Specific Conductance	1900	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2033	pH	7.5	pH
02-MAR-03	SUNDAY	1_Hr_COMP	2133	Specific Conductance	2300	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2133	pH	7.5	pH
02-MAR-03	SUNDAY	1_Hr_COMP	2233	Specific Conductance	1900	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2233	pH	7.5	pH
02-MAR-03	SUNDAY	1_Hr_COMP	2333	Specific Conductance	1900	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2333	pH	7.6	pH
03-MAR-03	MONDAY	1_Hr_COMP	33	Specific Conductance	1800	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	33	pH	7.6	pH
03-MAR-03	MONDAY	1_Hr_COMP	133	Specific Conductance	1900	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	133	pH	7.6	pH
03-MAR-03	MONDAY	1_Hr_COMP	233	Specific Conductance	2200	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	233	pH	7.6	pH
03-MAR-03	MONDAY	1_Hr_COMP	333	Specific Conductance	1900	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	333	pH	7.6	pH

City of Mexicali
Site 1

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE UNITS
03-MAR-03	MONDAY	1_Hr_COMP	433	Specific Conductance	1800 umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	433	pH	7.7 pH
03-MAR-03	MONDAY	1_Hr_COMP	533	Specific Conductance	1800 umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	533	pH	7.6 pH
03-MAR-03	MONDAY	1_Hr_COMP	633	Specific Conductance	1800 umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	633	pH	7.6 pH
03-MAR-03	MONDAY	COMP_CONDUCT	735	Specific Conductance	2200 umhos/cm
03-MAR-03	MONDAY	COMP_PH	735	pH	7.5 pH
03-MAR-03	MONDAY	GRAB	745	Specific Conductance	1700 umhos/cm
03-MAR-03	MONDAY	GRAB	745	pH	7.3 pH

SITE 2

City of Mexicali
Site 2

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
13-JAN-03	MONDAY	1_Hr_COMP	1110	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1110	pH	7.7	pH
13-JAN-03	MONDAY	1_Hr_COMP	1210	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1210	pH	7.7	pH
13-JAN-03	MONDAY	1_Hr_COMP	1310	Specific Conductance	2300	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1310	pH	7.6	pH
13-JAN-03	MONDAY	1_Hr_COMP	1410	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1410	pH	7.5	pH
13-JAN-03	MONDAY	1_Hr_COMP	1510	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1510	pH	7.5	pH
13-JAN-03	MONDAY	1_Hr_COMP	1610	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1610	pH	7.5	pH
13-JAN-03	MONDAY	1_Hr_COMP	1710	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1710	pH	7.5	pH
13-JAN-03	MONDAY	1_Hr_COMP	1810	Specific Conductance	2300	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1810	pH	7.6	pH
13-JAN-03	MONDAY	1_Hr_COMP	1910	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1910	pH	7.6	pH
13-JAN-03	MONDAY	1_Hr_COMP	2010	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	2010	pH	7.6	pH
13-JAN-03	MONDAY	1_Hr_COMP	2110	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	2110	pH	7.7	pH
13-JAN-03	MONDAY	1_Hr_COMP	2210	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	2210	pH	7.7	pH
13-JAN-03	MONDAY	1_Hr_COMP	2310	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	2310	pH	7.7	pH
14-JAN-03	TUESDAY	1_Hr_COMP	10	Specific Conductance	2200	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	10	pH	7.7	pH
14-JAN-03	TUESDAY	1_Hr_COMP	110	Specific Conductance	2200	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	110	pH	7.8	pH
14-JAN-03	TUESDAY	1_Hr_COMP	210	Specific Conductance	2200	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	210	pH	7.8	pH
14-JAN-03	TUESDAY	1_Hr_COMP	310	Specific Conductance	2200	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	310	pH	7.8	pH
14-JAN-03	TUESDAY	1_Hr_COMP	410	Specific Conductance	2100	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	410	pH	7.8	pH
14-JAN-03	TUESDAY	1_Hr_COMP	510	Specific Conductance	2200	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	510	pH	7.8	pH
14-JAN-03	TUESDAY	1_Hr_COMP	610	Specific Conductance	2200	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	610	pH	7.8	pH
14-JAN-03	TUESDAY	1_Hr_COMP	710	Specific Conductance	2200	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	710	pH	7.9	pH
14-JAN-03	TUESDAY	1_Hr_COMP	810	Specific Conductance	2200	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	810	pH	8	pH
14-JAN-03	TUESDAY	1_Hr_COMP	910	Specific Conductance	2200	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	910	pH	7.8	pH
14-JAN-03	TUESDAY	1_Hr_COMP	1010	Specific Conductance	2200	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	1010	pH	7.8	pH
14-JAN-03	TUESDAY	COMP_CONDUCT	1040	Specific Conductance	2100	umhos/cm
14-JAN-03	TUESDAY	COMP_PH	1040	pH	7.8	pH
14-JAN-03	TUESDAY	GRAB	1050	Specific Conductance	2200	umhos/cm
14-JAN-03	TUESDAY	GRAB	1050	pH	7.6	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1050	Specific Conductance	2100	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1050	pH	7.8	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1150	Specific Conductance	2300	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1150	pH	7.7	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1250	Specific Conductance	2200	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1250	pH	7.7	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1350	Specific Conductance	2200	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1350	pH	7.7	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1450	Specific Conductance	2300	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1450	pH	7.7	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1550	Specific Conductance	2200	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1550	pH	7.5	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1650	Specific Conductance	2200	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1650	pH	7.3	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1750	Specific Conductance	2200	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1750	pH	7.4	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1850	Specific Conductance	2200	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1850	pH	7.4	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1950	Specific Conductance	2100	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1950	pH	7.5	pH
21-JAN-03	TUESDAY	1_Hr_COMP	2050	Specific Conductance	2100	umhos/cm

City of Mexicali
Site 2

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
21-JAN-03	TUESDAY	1_Hr_COMP	2050	pH	7.6	pH
21-JAN-03	TUESDAY	1_Hr_COMP	2150	Specific Conductance	2100	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	2150	pH	7.6	pH
21-JAN-03	TUESDAY	1_Hr_COMP	2250	Specific Conductance	2200	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	2250	pH	7.7	pH
21-JAN-03	TUESDAY	1_Hr_COMP	2350	Specific Conductance	2200	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	2350	pH	7.7	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	50	Specific Conductance	2100	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	50	pH	7.7	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	150	Specific Conductance	2100	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	150	pH	7.8	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	250	Specific Conductance	2100	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	250	pH	7.8	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	350	Specific Conductance	2100	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	350	pH	7.9	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	450	Specific Conductance	2100	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	450	pH	7.9	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	550	Specific Conductance	2100	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	550	pH	7.9	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	650	Specific Conductance	2100	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	650	pH	7.9	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	750	Specific Conductance	2100	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	750	pH	7.9	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	850	Specific Conductance	2100	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	850	pH	7.8	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	950	Specific Conductance	2100	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	950	pH	7.7	pH
22-JAN-03	WEDNESDAY	COMP_CONDUCT	1035	Specific Conductance	2200	umhos/cm
22-JAN-03	WEDNESDAY	COMP_PH	1035	pH	7.5	pH
22-JAN-03	WEDNESDAY	GRAB	1045	Specific Conductance	2200	umhos/cm
22-JAN-03	WEDNESDAY	GRAB	1045	pH	7.2	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1010	Specific Conductance	2100	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1010	pH	7.7	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1110	Specific Conductance	2200	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1110	pH	7.7	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1210	Specific Conductance	2300	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1210	pH	7.8	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1310	Specific Conductance	2200	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1310	pH	7.6	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1410	Specific Conductance	2200	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1410	pH	7.6	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1510	Specific Conductance	2200	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1510	pH	7.6	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1610	Specific Conductance	2300	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1610	pH	7.6	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1710	Specific Conductance	2200	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1710	pH	7.5	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1810	Specific Conductance	2200	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1810	pH	7.5	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1910	Specific Conductance	2200	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1910	pH	7.5	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2010	Specific Conductance	2200	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2010	pH	7.6	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2110	Specific Conductance	2300	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2110	pH	7.7	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2210	Specific Conductance	2100	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2210	pH	7.7	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2310	Specific Conductance	2100	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2310	pH	7.8	pH
30-JAN-03	THURSDAY	1_Hr_COMP	10	Specific Conductance	2100	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	10	pH	7.8	pH
30-JAN-03	THURSDAY	1_Hr_COMP	110	Specific Conductance	2100	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	110	pH	7.8	pH
30-JAN-03	THURSDAY	1_Hr_COMP	210	Specific Conductance	2100	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	210	pH	7.7	pH
30-JAN-03	THURSDAY	1_Hr_COMP	310	Specific Conductance	2100	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	310	pH	7.8	pH
30-JAN-03	THURSDAY	1_Hr_COMP	410	Specific Conductance	2100	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	410	pH	7.8	pH
30-JAN-03	THURSDAY	1_Hr_COMP	510	Specific Conductance	2100	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	510	pH	7.8	pH
30-JAN-03	THURSDAY	1_Hr_COMP	610	Specific Conductance	2200	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	610	pH	7.9	pH

City of Mexicali
Site 2

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
30-JAN-03	THURSDAY	1_Hr_COMP	710 Specific Conductance	2300 umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	710 pH	7.9 pH
30-JAN-03	THURSDAY	1_Hr_COMP	810 Specific Conductance	2200 umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	810 pH	7.9 pH
30-JAN-03	THURSDAY	1_Hr_COMP	910 Specific Conductance	2300 umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	910 pH	7.8 pH
30-JAN-03	THURSDAY	COMP_CONDUCT	950 Specific Conductance	2200 umhos/cm
30-JAN-03	THURSDAY	COMP_PH	950 pH	7.5 pH
30-JAN-03	THURSDAY	GRAB	1000 Specific Conductance	2200 umhos/cm
30-JAN-03	THURSDAY	GRAB	1000 pH	7.3 pH
06-FEB-03	THURSDAY	1_Hr_COMP	930 Specific Conductance	2100 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	930 pH	7.7 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1030 Specific Conductance	2100 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1030 pH	7.8 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1130 Specific Conductance	3100 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1130 pH	7.8 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1230 Specific Conductance	2600 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1230 pH	7.7 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1330 Specific Conductance	3000 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1330 pH	7.8 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1430 Specific Conductance	3100 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1430 pH	7.7 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1530 Specific Conductance	2900 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1530 pH	7.5 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1630 Specific Conductance	2800 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1630 pH	7.4 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1730 Specific Conductance	2600 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1730 pH	7.4 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1830 Specific Conductance	2200 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1830 pH	7.4 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1930 Specific Conductance	2000 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1930 pH	7.6 pH
06-FEB-03	THURSDAY	1_Hr_COMP	2030 Specific Conductance	2400 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	2030 pH	7.7 pH
06-FEB-03	THURSDAY	1_Hr_COMP	2130 Specific Conductance	2300 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	2130 pH	7.7 pH
06-FEB-03	THURSDAY	1_Hr_COMP	2230 Specific Conductance	2200 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	2230 pH	7.8 pH
06-FEB-03	THURSDAY	1_Hr_COMP	2330 Specific Conductance	2500 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	2330 pH	7.9 pH
07-FEB-03	FRIDAY	1_Hr_COMP	30 Specific Conductance	2500 umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	30 pH	8 pH
07-FEB-03	FRIDAY	1_Hr_COMP	130 Specific Conductance	3500 umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	130 pH	7.8 pH
07-FEB-03	FRIDAY	1_Hr_COMP	230 Specific Conductance	2100 umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	230 pH	7.8 pH
07-FEB-03	FRIDAY	1_Hr_COMP	330 Specific Conductance	2100 umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	330 pH	7.8 pH
07-FEB-03	FRIDAY	1_Hr_COMP	430 Specific Conductance	2100 umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	430 pH	7.9 pH
07-FEB-03	FRIDAY	1_Hr_COMP	530 Specific Conductance	2100 umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	530 pH	7.8 pH
07-FEB-03	FRIDAY	1_Hr_COMP	630 Specific Conductance	2100 umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	630 pH	7.8 pH
07-FEB-03	FRIDAY	1_Hr_COMP	730 Specific Conductance	2100 umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	730 pH	7.8 pH
07-FEB-03	FRIDAY	1_Hr_COMP	830 Specific Conductance	2100 umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	830 pH	7.8 pH
07-FEB-03	FRIDAY	COMP_CONDUCT	1243 Specific Conductance	2100 umhos/cm
07-FEB-03	FRIDAY	COMP_PH	1243 pH	7.5 pH
07-FEB-03	FRIDAY	GRAB	1253 Specific Conductance	2400 umhos/cm
07-FEB-03	FRIDAY	GRAB	1253 pH	7.3 pH
22-FEB-03	SATURDAY	1_Hr_COMP	835 Specific Conductance	2000 umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	835 pH	7.6 pH
22-FEB-03	SATURDAY	1_Hr_COMP	935 Specific Conductance	2100 umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	935 pH	7.6 pH
22-FEB-03	SATURDAY	1_Hr_COMP	1035 Specific Conductance	2100 umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1035 pH	7.6 pH
22-FEB-03	SATURDAY	1_Hr_COMP	1135 Specific Conductance	2200 umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1135 pH	7.6 pH
22-FEB-03	SATURDAY	1_Hr_COMP	1235 Specific Conductance	2200 umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1235 pH	7.6 pH
22-FEB-03	SATURDAY	1_Hr_COMP	1335 Specific Conductance	2100 umhos/cm

City of Mexicali
Site 2

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
22-FEB-03	SATURDAY	1_Hr_COMP	1335	pH	7.6	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1435	Specific Conductance	2100	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1435	pH	7.5	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1535	Specific Conductance	2300	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1535	pH	7.4	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1635	Specific Conductance	2100	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1635	pH	7.5	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1735	Specific Conductance	2100	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1735	pH	7.6	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1835	Specific Conductance	2200	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1835	pH	7.5	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1935	Specific Conductance	2100	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1935	pH	7.5	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2035	Specific Conductance	2100	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2035	pH	7.5	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2135	Specific Conductance	2100	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2135	pH	7.6	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2235	Specific Conductance	2100	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2235	pH	7.7	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2335	Specific Conductance	2100	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2335	pH	7.7	pH
23-FEB-03	SUNDAY	1_Hr_COMP	35	Specific Conductance	2200	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	35	pH	7.7	pH
23-FEB-03	SUNDAY	1_Hr_COMP	135	Specific Conductance	2200	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	135	pH	7.6	pH
23-FEB-03	SUNDAY	1_Hr_COMP	235	Specific Conductance	2000	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	235	pH	7.7	pH
23-FEB-03	SUNDAY	1_Hr_COMP	335	Specific Conductance	2100	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	335	pH	7.7	pH
23-FEB-03	SUNDAY	1_Hr_COMP	435	Specific Conductance	2100	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	435	pH	7.7	pH
23-FEB-03	SUNDAY	1_Hr_COMP	535	Specific Conductance	2100	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	535	pH	7.7	pH
23-FEB-03	SUNDAY	1_Hr_COMP	635	Specific Conductance	2100	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	635	pH	7.7	pH
23-FEB-03	SUNDAY	1_Hr_COMP	735	Specific Conductance	2000	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	735	pH	7.7	pH
23-FEB-03	SUNDAY	COMP_CONDUCT	1110	Specific Conductance	2100	umhos/cm
23-FEB-03	SUNDAY	COMP_PH	1110	pH	7.4	pH
23-FEB-03	SUNDAY	GRAB	1120	Specific Conductance	2200	umhos/cm
23-FEB-03	SUNDAY	GRAB	1120	pH	7.4	pH
02-MAR-03	SUNDAY	1_Hr_COMP	755	Specific Conductance	2200	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	755	pH	7.7	pH
02-MAR-03	SUNDAY	1_Hr_COMP	855	Specific Conductance	2200	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	855	pH	7.7	pH
02-MAR-03	SUNDAY	1_Hr_COMP	955	Specific Conductance	2200	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	955	pH	7.7	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1055	Specific Conductance	2200	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1055	pH	7.7	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1155	Specific Conductance	2200	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1155	pH	7.7	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1255	Specific Conductance	2200	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1255	pH	7.7	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1355	Specific Conductance	2000	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1355	pH	7.7	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1455	Specific Conductance	2000	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1455	pH	7.7	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1555	Specific Conductance	2000	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1555	pH	7.7	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1655	Specific Conductance	2000	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1655	pH	7.7	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1755	Specific Conductance	1500	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1755	pH	7.7	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1855	Specific Conductance	2800	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1855	pH	7.8	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1955	Specific Conductance	2600	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1955	pH	8	pH
02-MAR-03	SUNDAY	1_Hr_COMP	2055	Specific Conductance	2400	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2055	pH	8	pH
02-MAR-03	SUNDAY	1_Hr_COMP	2155	Specific Conductance	2300	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2155	pH	8	pH
02-MAR-03	SUNDAY	1_Hr_COMP	2255	Specific Conductance	2300	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2255	pH	8	pH

City of Mexicali
Site 2

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
02-MAR-03	SUNDAY	1_Hr_COMP	2355	Specific Conductance	1100	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2355	pH	8	pH
03-MAR-03	MONDAY	1_Hr_COMP	55	Specific Conductance	2000	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	55	pH	8	pH
03-MAR-03	MONDAY	1_Hr_COMP	155	Specific Conductance	2000	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	155	pH	8.1	pH
03-MAR-03	MONDAY	1_Hr_COMP	255	Specific Conductance	2000	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	255	pH	8.1	pH
03-MAR-03	MONDAY	1_Hr_COMP	355	Specific Conductance	2000	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	355	pH	8.1	pH
03-MAR-03	MONDAY	1_Hr_COMP	455	Specific Conductance	2000	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	455	pH	8.1	pH
03-MAR-03	MONDAY	1_Hr_COMP	555	Specific Conductance	2100	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	555	pH	8.1	pH
03-MAR-03	MONDAY	1_Hr_COMP	655	Specific Conductance	2200	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	655	pH	8.1	pH
03-MAR-03	MONDAY	GRAB	825	Specific Conductance	3000	umhos/cm
03-MAR-03	MONDAY	GRAB	825	pH	7.4	pH
28-MAR-03	FRIDAY	1_Hr_COMP	840	Specific Conductance	2000	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	840	pH	7.8	pH
28-MAR-03	FRIDAY	1_Hr_COMP	940	Specific Conductance	2100	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	940	pH	7.7	pH
28-MAR-03	FRIDAY	1_Hr_COMP	1040	Specific Conductance	2000	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1040	pH	7.8	pH
28-MAR-03	FRIDAY	1_Hr_COMP	1140	Specific Conductance	2000	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1140	pH	7.7	pH
28-MAR-03	FRIDAY	1_Hr_COMP	1240	Specific Conductance	2100	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1240	pH	7	pH
28-MAR-03	FRIDAY	1_Hr_COMP	1340	Specific Conductance	2100	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1340	pH	7.1	pH
28-MAR-03	FRIDAY	1_Hr_COMP	1440	Specific Conductance	2000	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1440	pH	7.1	pH
28-MAR-03	FRIDAY	1_Hr_COMP	1540	Specific Conductance	2000	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1540	pH	7.2	pH
28-MAR-03	FRIDAY	1_Hr_COMP	1640	Specific Conductance	2100	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1640	pH	7.2	pH
28-MAR-03	FRIDAY	1_Hr_COMP	1740	Specific Conductance	2100	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1740	pH	7.2	pH
28-MAR-03	FRIDAY	1_Hr_COMP	1840	Specific Conductance	2200	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1840	pH	7.3	pH
28-MAR-03	FRIDAY	1_Hr_COMP	1940	Specific Conductance	2200	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1940	pH	7.4	pH
28-MAR-03	FRIDAY	1_Hr_COMP	2040	Specific Conductance	2000	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2040	pH	7.4	pH
28-MAR-03	FRIDAY	1_Hr_COMP	2140	Specific Conductance	2000	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2140	pH	7.4	pH
28-MAR-03	FRIDAY	1_Hr_COMP	2240	Specific Conductance	2000	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2240	pH	6.8	pH
28-MAR-03	FRIDAY	1_Hr_COMP	2340	Specific Conductance	2000	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2340	pH	6.7	pH
29-MAR-03	SATURDAY	1_Hr_COMP	40	Specific Conductance	2000	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	40	pH	6.9	pH
29-MAR-03	SATURDAY	1_Hr_COMP	140	Specific Conductance	2000	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	140	pH	7.14	pH
29-MAR-03	SATURDAY	1_Hr_COMP	240	Specific Conductance	2000	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	240	pH	7	pH
29-MAR-03	SATURDAY	1_Hr_COMP	340	Specific Conductance	2000	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	340	pH	7.2	pH
29-MAR-03	SATURDAY	1_Hr_COMP	440	Specific Conductance	2100	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	440	pH	7.3	pH
29-MAR-03	SATURDAY	1_Hr_COMP	540	Specific Conductance	2000	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	540	pH	7.3	pH
29-MAR-03	SATURDAY	1_Hr_COMP	640	Specific Conductance	2000	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	640	pH	7.3	pH
29-MAR-03	SATURDAY	1_Hr_COMP	740	Specific Conductance	2000	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	740	pH	7.5	pH
29-MAR-03	SATURDAY	COMP_CONDUCT	810	Specific Conductance	2000	umhos/cm
29-MAR-03	SATURDAY	COMP_PH	810	pH	7.3	pH
29-MAR-03	SATURDAY	GRAB	820	Specific Conductance	2000	umhos/cm
29-MAR-03	SATURDAY	GRAB	820	pH	7	pH
05-APR-03	SATURDAY	1_Hr_COMP	750	Specific Conductance	2200	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	750	pH	7.7	pH
05-APR-03	SATURDAY	1_Hr_COMP	850	Specific Conductance	2200	umhos/cm

City of Mexicali
Site 2

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
05-APR-03	SATURDAY	1_Hr_COMP		850 pH	7.7	pH
05-APR-03	SATURDAY	1_Hr_COMP		950 Specific Conductance	2100	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP		950 pH	7.6	pH
05-APR-03	SATURDAY	1_Hr_COMP		1050 Specific Conductance	2100	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP		1050 pH	7.5	pH
05-APR-03	SATURDAY	1_Hr_COMP		1150 Specific Conductance	2200	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP		1150 pH	7.5	pH
05-APR-03	SATURDAY	1_Hr_COMP		1250 Specific Conductance	2200	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP		1250 pH	7.4	pH
05-APR-03	SATURDAY	1_Hr_COMP		1350 Specific Conductance	2100	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP		1350 pH	7.2	pH
05-APR-03	SATURDAY	1_Hr_COMP		1450 Specific Conductance	2100	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP		1450 pH	7.1	pH
05-APR-03	SATURDAY	1_Hr_COMP		1550 Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP		1550 pH	7.2	pH
05-APR-03	SATURDAY	1_Hr_COMP		1650 Specific Conductance	2100	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP		1650 pH	7.3	pH
05-APR-03	SATURDAY	1_Hr_COMP		1750 Specific Conductance	2100	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP		1750 pH	7.3	pH
05-APR-03	SATURDAY	1_Hr_COMP		1850 Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP		1850 pH	7.2	pH
05-APR-03	SATURDAY	1_Hr_COMP		1950 Specific Conductance	2400	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP		1950 pH	7.2	pH
05-APR-03	SATURDAY	1_Hr_COMP		2050 Specific Conductance	2300	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP		2050 pH	7.3	pH
05-APR-03	SATURDAY	1_Hr_COMP		2150 Specific Conductance	2100	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP		2150 pH	7.5	pH
05-APR-03	SATURDAY	1_Hr_COMP		2250 Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP		2250 pH	7.5	pH
05-APR-03	SATURDAY	1_Hr_COMP		2350 Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP		2350 pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP		50 Specific Conductance	2000	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP		50 pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP		150 Specific Conductance	2000	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP		150 pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP		250 Specific Conductance	2000	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP		250 pH	7.3	pH
06-APR-03	SUNDAY	1_Hr_COMP		350 Specific Conductance	2100	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP		350 pH	7.3	pH
06-APR-03	SUNDAY	1_Hr_COMP		450 Specific Conductance	2000	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP		450 pH	7.5	pH
06-APR-03	SUNDAY	1_Hr_COMP		550 Specific Conductance	2000	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP		550 pH	7.5	pH
06-APR-03	SUNDAY	1_Hr_COMP		650 Specific Conductance	2000	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP		650 pH	7.6	pH
06-APR-03	SUNDAY	COMP_CONDUCT		845 Specific Conductance	2100	umhos/cm
06-APR-03	SUNDAY	COMP_PH		845 pH	7.5	pH
06-APR-03	SUNDAY	GRAB		850 Specific Conductance	2100	umhos/cm
06-APR-03	SUNDAY	GRAB		850 pH	7.5	pH
14-APR-03	MONDAY	1_Hr_COMP		800 Specific Conductance	2000	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP		800 pH	7.5	pH
14-APR-03	MONDAY	1_Hr_COMP		900 Specific Conductance	2000	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP		900 pH	7.5	pH
14-APR-03	MONDAY	1_Hr_COMP		1000 Specific Conductance	2100	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP		1000 pH	7.5	pH
14-APR-03	MONDAY	1_Hr_COMP		1100 Specific Conductance	2100	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP		1100 pH	7.5	pH
14-APR-03	MONDAY	1_Hr_COMP		1200 Specific Conductance	2200	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP		1200 pH	7.3	pH
14-APR-03	MONDAY	1_Hr_COMP		1300 Specific Conductance	2300	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP		1300 pH	7	pH
14-APR-03	MONDAY	1_Hr_COMP		1400 Specific Conductance	2100	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP		1400 pH	7.1	pH
14-APR-03	MONDAY	1_Hr_COMP		1500 Specific Conductance	2100	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP		1500 pH	7.1	pH
14-APR-03	MONDAY	1_Hr_COMP		1600 Specific Conductance	2000	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP		1600 pH	8	pH
14-APR-03	MONDAY	1_Hr_COMP		1700 Specific Conductance	2100	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP		1700 pH	7.2	pH
14-APR-03	MONDAY	1_Hr_COMP		1800 Specific Conductance	2000	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP		1800 pH	7.2	pH
14-APR-03	MONDAY	1_Hr_COMP		1900 Specific Conductance	2000	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP		1900 pH	7.2	pH

City of Mexicali
Site 2

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
14-APR-03	MONDAY	1_Hr_COMP	2000	Specific Conductance	2200	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2000	pH	7.2	pH
14-APR-03	MONDAY	1_Hr_COMP	2100	Specific Conductance	2100	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2100	pH	7.2	pH
14-APR-03	MONDAY	1_Hr_COMP	2200	Specific Conductance	2100	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2200	pH	7.3	pH
14-APR-03	MONDAY	1_Hr_COMP	2300	Specific Conductance	2100	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2300	pH	7.5	pH
14-APR-03	MONDAY	1_Hr_COMP	2400	Specific Conductance	2100	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2400	pH	7.5	pH
15-APR-03	TUESDAY	1_Hr_COMP	100	Specific Conductance	2100	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	100	pH	7.4	pH
15-APR-03	TUESDAY	1_Hr_COMP	200	Specific Conductance	2200	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	200	pH	7.4	pH
15-APR-03	TUESDAY	1_Hr_COMP	300	Specific Conductance	2000	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	300	pH	7.7	pH
15-APR-03	TUESDAY	1_Hr_COMP	400	Specific Conductance	2100	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	400	pH	7.5	pH
15-APR-03	TUESDAY	1_Hr_COMP	500	Specific Conductance	2500	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	500	pH	7.4	pH
15-APR-03	TUESDAY	1_Hr_COMP	600	Specific Conductance	2000	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	600	pH	7.4	pH
15-APR-03	TUESDAY	1_Hr_COMP	700	Specific Conductance	2100	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	700	pH	7.3	pH
15-APR-03	TUESDAY	COMP_CONDUCT	800	Specific Conductance	2100	umhos/cm
15-APR-03	TUESDAY	COMP_PH	800	pH	7.3	pH
15-APR-03	TUESDAY	GRAB	805	Specific Conductance	2000	umhos/cm
15-APR-03	TUESDAY	GRAB	805	pH	7.1	pH
22-APR-03	TUESDAY	1_Hr_COMP	838	Specific Conductance	2100	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	838	pH	7.4	pH
22-APR-03	TUESDAY	1_Hr_COMP	938	Specific Conductance	2200	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	938	pH	7.4	pH
22-APR-03	TUESDAY	1_Hr_COMP	1038	Specific Conductance	2100	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1038	pH	7.4	pH
22-APR-03	TUESDAY	1_Hr_COMP	1138	Specific Conductance	2000	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1138	pH	7.3	pH
22-APR-03	TUESDAY	1_Hr_COMP	1238	Specific Conductance	2100	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1238	pH	7.2	pH
22-APR-03	TUESDAY	1_Hr_COMP	1338	Specific Conductance	2100	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1338	pH	7.2	pH
22-APR-03	TUESDAY	1_Hr_COMP	1438	Specific Conductance	2100	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1438	pH	7.2	pH
22-APR-03	TUESDAY	1_Hr_COMP	1538	Specific Conductance	2000	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1538	pH	7.1	pH
22-APR-03	TUESDAY	1_Hr_COMP	1638	Specific Conductance	2000	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1638	pH	7.1	pH
22-APR-03	TUESDAY	1_Hr_COMP	1738	Specific Conductance	2200	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1738	pH	7.2	pH
22-APR-03	TUESDAY	1_Hr_COMP	1838	Specific Conductance	2100	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1838	pH	7.3	pH
22-APR-03	TUESDAY	1_Hr_COMP	1938	Specific Conductance	2100	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1938	pH	7.2	pH
22-APR-03	TUESDAY	1_Hr_COMP	2038	Specific Conductance	2100	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2038	pH	7.2	pH
22-APR-03	TUESDAY	1_Hr_COMP	2138	Specific Conductance	2100	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2138	pH	7.2	pH
22-APR-03	TUESDAY	1_Hr_COMP	2238	Specific Conductance	2100	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2238	pH	7.2	pH
22-APR-03	TUESDAY	1_Hr_COMP	2338	Specific Conductance	2100	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2338	pH	7.2	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	38	Specific Conductance	2300	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	38	pH	7.4	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	138	Specific Conductance	2300	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	138	pH	7.4	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	238	Specific Conductance	2200	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	238	pH	7.3	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	338	Specific Conductance	2200	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	338	pH	7.2	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	438	Specific Conductance	2100	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	438	pH	7.1	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	538	Specific Conductance	2100	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	538	pH	7.1	pH
23-APR-03	WEDNESDAY	COMP_CONDUCT	845	Specific Conductance	2100	umhos/cm

City of Mexicali
Site 2

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
23-APR-03	WEDNESDAY	COMP_PH	845	pH	7.3	pH
23-APR-03	WEDNESDAY	GRAB	855	Specific Conductance	2000	umhos/cm
23-APR-03	WEDNESDAY	GRAB	855	pH	7.2	pH

SITE 3

City of Mexicali
Site 3

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
13-JAN-03	MONDAY	1_Hr_COMP	1135	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1135	pH	7.3	pH
13-JAN-03	MONDAY	1_Hr_COMP	1235	Specific Conductance	2300	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1235	pH	7.4	pH
13-JAN-03	MONDAY	1_Hr_COMP	1335	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1335	pH	7.3	pH
13-JAN-03	MONDAY	1_Hr_COMP	1435	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1435	pH	7.4	pH
13-JAN-03	MONDAY	1_Hr_COMP	1535	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1535	pH	7.4	pH
13-JAN-03	MONDAY	1_Hr_COMP	1635	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1635	pH	7.4	pH
13-JAN-03	MONDAY	1_Hr_COMP	1735	Specific Conductance	2100	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1735	pH	7.3	pH
13-JAN-03	MONDAY	1_Hr_COMP	1835	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1835	pH	7.4	pH
13-JAN-03	MONDAY	1_Hr_COMP	1935	Specific Conductance	2100	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1935	pH	7.4	pH
13-JAN-03	MONDAY	1_Hr_COMP	2035	Specific Conductance	2300	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	2035	pH	7.5	pH
13-JAN-03	MONDAY	1_Hr_COMP	2135	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	2135	pH	7.5	pH
13-JAN-03	MONDAY	1_Hr_COMP	2235	Specific Conductance	2100	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	2235	pH	7.5	pH
13-JAN-03	MONDAY	1_Hr_COMP	2335	Specific Conductance	2200	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	2335	pH	7.6	pH
14-JAN-03	TUESDAY	1_Hr_COMP	35	Specific Conductance	2100	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	35	pH	7.6	pH
14-JAN-03	TUESDAY	1_Hr_COMP	135	Specific Conductance	2100	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	135	pH	7.5	pH
14-JAN-03	TUESDAY	1_Hr_COMP	235	Specific Conductance	2100	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	235	pH	7.5	pH
14-JAN-03	TUESDAY	1_Hr_COMP	335	Specific Conductance	2100	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	335	pH	7.6	pH
14-JAN-03	TUESDAY	1_Hr_COMP	435	Specific Conductance	2100	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	435	pH	7.6	pH
14-JAN-03	TUESDAY	1_Hr_COMP	535	Specific Conductance	2100	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	535	pH	7.7	pH
14-JAN-03	TUESDAY	1_Hr_COMP	635	Specific Conductance	2100	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	635	pH	7.8	pH
14-JAN-03	TUESDAY	1_Hr_COMP	735	Specific Conductance	2100	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	735	pH	7.9	pH
14-JAN-03	TUESDAY	1_Hr_COMP	835	Specific Conductance	2200	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	835	pH	7.8	pH
14-JAN-03	TUESDAY	1_Hr_COMP	935	Specific Conductance	2100	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	935	pH	7.8	pH
14-JAN-03	TUESDAY	1_Hr_COMP	1035	Specific Conductance	2200	umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	1035	pH	7.9	pH
14-JAN-03	TUESDAY	COMP_CONDUCT	1230	Specific Conductance	2100	umhos/cm
14-JAN-03	TUESDAY	COMP_PH	1230	pH	7.4	pH
14-JAN-03	TUESDAY	GRAB	1240	Specific Conductance	2300	umhos/cm
14-JAN-03	TUESDAY	GRAB	1240	pH	7.6	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1120	Specific Conductance	2100	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1120	pH	7.4	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1220	Specific Conductance	2200	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1220	pH	7.4	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1320	Specific Conductance	2200	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1320	pH	7.4	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1420	Specific Conductance	2200	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1420	pH	7.4	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1520	Specific Conductance	2100	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1520	pH	7.4	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1620	Specific Conductance	2100	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1620	pH	7.4	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1720	Specific Conductance	2100	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1720	pH	7.4	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1820	Specific Conductance	2100	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1820	pH	7.3	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1920	Specific Conductance	2100	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1920	pH	7.4	pH
21-JAN-03	TUESDAY	1_Hr_COMP	2020	Specific Conductance	2100	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	2020	pH	7.4	pH
21-JAN-03	TUESDAY	1_Hr_COMP	2120	Specific Conductance	2100	umhos/cm

City of Mexicali
Site 3

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
21-JAN-03	TUESDAY	1_Hr_COMP	2120	pH	7.5	pH
21-JAN-03	TUESDAY	1_Hr_COMP	2220	Specific Conductance	2100	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	2220	pH	7.5	pH
21-JAN-03	TUESDAY	1_Hr_COMP	2320	Specific Conductance	2000	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	2320	pH	7.5	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	20	Specific Conductance	2000	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	20	pH	7.5	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	120	Specific Conductance	2000	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	120	pH	7.5	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	220	Specific Conductance	2000	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	220	pH	7.5	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	320	Specific Conductance	1900	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	320	pH	7.5	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	420	Specific Conductance	1900	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	420	pH	7.6	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	520	Specific Conductance	1900	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	520	pH	7.7	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	620	Specific Conductance	1900	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	620	pH	7.7	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	720	Specific Conductance	2000	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	720	pH	7.7	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	820	Specific Conductance	2000	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	820	pH	7.8	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	920	Specific Conductance	2100	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	920	pH	7.8	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	1020	Specific Conductance	2300	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	1020	pH	7.8	pH
22-JAN-03	WEDNESDAY	COMP_CONDUCT	1110	Specific Conductance	2000	umhos/cm
22-JAN-03	WEDNESDAY	COMP_PH	1110	pH	7.6	pH
22-JAN-03	WEDNESDAY	GRAB	1120	Specific Conductance	2200	umhos/cm
22-JAN-03	WEDNESDAY	GRAB	1120	pH	7.5	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1040	Specific Conductance	2120	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1040	pH	7	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1140	Specific Conductance	2100	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1140	pH	7.4	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1240	Specific Conductance	2100	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1240	pH	7.3	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1340	Specific Conductance	2200	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1340	pH	7.3	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1440	Specific Conductance	2100	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1440	pH	7.3	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1540	Specific Conductance	2100	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1540	pH	7.3	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1640	Specific Conductance	2100	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1640	pH	7.3	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1740	Specific Conductance	2100	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1740	pH	7.2	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1840	Specific Conductance	2100	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1840	pH	7.2	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1940	Specific Conductance	2000	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1940	pH	7.3	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2040	Specific Conductance	2000	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2040	pH	7.4	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2140	Specific Conductance	2000	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2140	pH	7.4	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2240	Specific Conductance	2000	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2240	pH	7.4	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2340	Specific Conductance	2000	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2340	pH	7.3	pH
30-JAN-03	THURSDAY	1_Hr_COMP	40	Specific Conductance	2000	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	40	pH	7.4	pH
30-JAN-03	THURSDAY	1_Hr_COMP	140	Specific Conductance	2000	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	140	pH	7.4	pH
30-JAN-03	THURSDAY	COMP_CONDUCT	1020	Specific Conductance	2000	umhos/cm
30-JAN-03	THURSDAY	COMP_PH	1020	pH	7.4	pH
30-JAN-03	THURSDAY	GRAB	1030	Specific Conductance	2200	umhos/cm
30-JAN-03	THURSDAY	GRAB	1030	pH	7.7	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1005	Specific Conductance	1900	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1005	pH	7.7	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1105	Specific Conductance	1900	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1105	pH	7.9	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1205	Specific Conductance	1900	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1205	pH	7.9	pH

City of Mexicali
Site 3

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
06-FEB-03	THURSDAY	1_Hr_COMP	1305 Specific Conductance	2200 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1305 pH	7.9 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1405 Specific Conductance	2300 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1405 pH	8 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1505 Specific Conductance	2300 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1505 pH	7.8 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1605 Specific Conductance	2300 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1605 pH	7.9 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1705 Specific Conductance	2400 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1705 pH	7.9 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1805 Specific Conductance	2300 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1805 pH	7.8 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1905 Specific Conductance	1900 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1905 pH	7.8 pH
06-FEB-03	THURSDAY	1_Hr_COMP	2005 Specific Conductance	1900 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	2005 pH	7.8 pH
06-FEB-03	THURSDAY	1_Hr_COMP	2105 Specific Conductance	1900 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	2105 pH	7.8 pH
06-FEB-03	THURSDAY	1_Hr_COMP	2205 Specific Conductance	1900 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	2205 pH	7.9 pH
06-FEB-03	THURSDAY	1_Hr_COMP	2305 Specific Conductance	1900 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	2305 pH	7.8 pH
07-FEB-03	FRIDAY	1_Hr_COMP	5 Specific Conductance	1900 umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	5 pH	7.8 pH
07-FEB-03	FRIDAY	1_Hr_COMP	105 Specific Conductance	1900 umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	105 pH	7.8 pH
07-FEB-03	FRIDAY	1_Hr_COMP	205 Specific Conductance	1900 umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	205 pH	7.8 pH
07-FEB-03	FRIDAY	1_Hr_COMP	305 Specific Conductance	1800 umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	305 pH	7.8 pH
07-FEB-03	FRIDAY	1_Hr_COMP	405 Specific Conductance	1900 umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	405 pH	7.8 pH
07-FEB-03	FRIDAY	1_Hr_COMP	505 Specific Conductance	1900 umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	505 pH	7.8 pH
07-FEB-03	FRIDAY	1_Hr_COMP	605 Specific Conductance	1700 umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	605 pH	7.9 pH
07-FEB-03	FRIDAY	1_Hr_COMP	705 Specific Conductance	1800 umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	705 pH	7.9 pH
07-FEB-03	FRIDAY	1_Hr_COMP	805 Specific Conductance	1700 umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	805 pH	8 pH
07-FEB-03	FRIDAY	1_Hr_COMP	905 Specific Conductance	1800 umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	905 pH	8.1 pH
07-FEB-03	FRIDAY	COMP_CONDUCT	1200 Specific Conductance	1800 umhos/cm
07-FEB-03	FRIDAY	COMP_PH	1200 pH	7.8 pH
07-FEB-03	FRIDAY	GRAB	1210 Specific Conductance	2000 umhos/cm
07-FEB-03	FRIDAY	GRAB	1210 pH	7.3 pH
22-FEB-03	SATURDAY	1_Hr_COMP	850 Specific Conductance	1900 umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	850 pH	6.9 pH
22-FEB-03	SATURDAY	1_Hr_COMP	950 Specific Conductance	1900 umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	950 pH	7.2 pH
22-FEB-03	SATURDAY	1_Hr_COMP	1050 Specific Conductance	1900 umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1050 pH	7.2 pH
22-FEB-03	SATURDAY	1_Hr_COMP	1150 Specific Conductance	1900 umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1150 pH	7.3 pH
22-FEB-03	SATURDAY	1_Hr_COMP	1250 Specific Conductance	2100 umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1250 pH	7.2 pH
22-FEB-03	SATURDAY	1_Hr_COMP	1350 Specific Conductance	2000 umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1350 pH	7.2 pH
22-FEB-03	SATURDAY	1_Hr_COMP	1450 Specific Conductance	1800 umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1450 pH	7.2 pH
22-FEB-03	SATURDAY	1_Hr_COMP	1550 Specific Conductance	2000 umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1550 pH	7.2 pH
22-FEB-03	SATURDAY	1_Hr_COMP	1650 Specific Conductance	2000 umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1650 pH	7 pH
22-FEB-03	SATURDAY	1_Hr_COMP	1750 Specific Conductance	1900 umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1750 pH	7 pH
22-FEB-03	SATURDAY	1_Hr_COMP	1850 Specific Conductance	1900 umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1850 pH	7.2 pH
22-FEB-03	SATURDAY	1_Hr_COMP	1950 Specific Conductance	1700 umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1950 pH	7.2 pH
22-FEB-03	SATURDAY	1_Hr_COMP	2050 Specific Conductance	1900 umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2050 pH	7.4 pH
22-FEB-03	SATURDAY	1_Hr_COMP	2150 Specific Conductance	1900 umhos/cm

City of Mexicali
Site 3

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
22-FEB-03	SATURDAY	1_Hr_COMP	2150	pH	7.4	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2250	Specific Conductance	1900	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2250	pH	7.3	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2350	Specific Conductance	1900	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2350	pH	7.2	pH
23-FEB-03	SUNDAY	1_Hr_COMP	50	Specific Conductance	1900	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	50	pH	7.2	pH
23-FEB-03	SUNDAY	1_Hr_COMP	150	Specific Conductance	1900	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	150	pH	7.3	pH
23-FEB-03	SUNDAY	1_Hr_COMP	250	Specific Conductance	2000	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	250	pH	7.3	pH
23-FEB-03	SUNDAY	1_Hr_COMP	350	Specific Conductance	1800	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	350	pH	7.3	pH
23-FEB-03	SUNDAY	1_Hr_COMP	450	Specific Conductance	1900	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	450	pH	7.3	pH
23-FEB-03	SUNDAY	1_Hr_COMP	550	Specific Conductance	1800	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	550	pH	7.3	pH
23-FEB-03	SUNDAY	1_Hr_COMP	650	Specific Conductance	1800	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	650	pH	7.3	pH
23-FEB-03	SUNDAY	1_Hr_COMP	750	Specific Conductance	1800	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	750	pH	7.4	pH
23-FEB-03	SUNDAY	COMP_CONDUCT	1150	Specific Conductance	2100	umhos/cm
23-FEB-03	SUNDAY	COMP_PH	1150	pH	7.3	pH
23-FEB-03	SUNDAY	GRAB	1200	Specific Conductance	2000	umhos/cm
23-FEB-03	SUNDAY	GRAB	1200	pH	7.5	pH
02-MAR-03	SUNDAY	1_Hr_COMP	815	Specific Conductance	1900	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	815	pH	7.7	pH
02-MAR-03	SUNDAY	1_Hr_COMP	915	Specific Conductance	1900	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	915	pH	7.1	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1015	Specific Conductance	2400	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1015	pH	7.7	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1115	Specific Conductance	2400	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1115	pH	7.7	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1215	Specific Conductance	2400	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1215	pH	7.7	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1315	Specific Conductance	2600	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1315	pH	7.5	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1415	Specific Conductance	2400	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1415	pH	7.5	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1515	Specific Conductance	2300	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1515	pH	7.5	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1615	Specific Conductance	2300	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1615	pH	7.4	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1715	Specific Conductance	2300	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1715	pH	7.7	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1815	Specific Conductance	2000	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1815	pH	7	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1915	Specific Conductance	2000	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1915	pH	7.2	pH
02-MAR-03	SUNDAY	1_Hr_COMP	2015	Specific Conductance	2300	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2015	pH	7.4	pH
02-MAR-03	SUNDAY	1_Hr_COMP	2115	Specific Conductance	2300	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2115	pH	7.4	pH
02-MAR-03	SUNDAY	1_Hr_COMP	2215	Specific Conductance	2400	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2215	pH	7.4	pH
02-MAR-03	SUNDAY	1_Hr_COMP	2315	Specific Conductance	2300	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2315	pH	7.4	pH
03-MAR-03	MONDAY	1_Hr_COMP	15	Specific Conductance	2400	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	15	pH	7.5	pH
03-MAR-03	MONDAY	1_Hr_COMP	115	Specific Conductance	2400	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	115	pH	7.5	pH
03-MAR-03	MONDAY	1_Hr_COMP	215	Specific Conductance	2400	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	215	pH	7.3	pH
03-MAR-03	MONDAY	1_Hr_COMP	315	Specific Conductance	2400	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	315	pH	7.4	pH
03-MAR-03	MONDAY	1_Hr_COMP	415	Specific Conductance	2200	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	415	pH	7.4	pH
03-MAR-03	MONDAY	1_Hr_COMP	515	Specific Conductance	2100	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	515	pH	7.6	pH
03-MAR-03	MONDAY	1_Hr_COMP	615	Specific Conductance	2300	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	615	pH	7.5	pH
03-MAR-03	MONDAY	1_Hr_COMP	715	Specific Conductance	2200	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	715	pH	7.6	pH

City of Mexicali
Site 3

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
03-MAR-03	MONDAY	COMP_CONDUCT	850	Specific Conductance	2400	umhos/cm
03-MAR-03	MONDAY	COMP_PH	850	pH	7.6	pH
03-MAR-03	MONDAY	GRAB	900	Specific Conductance	2100	umhos/cm
03-MAR-03	MONDAY	GRAB	900	pH	7.6	pH
28-MAR-03	FRIDAY	1_Hr_COMP	920	Specific Conductance	1900	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	920	pH	7.6	pH
28-MAR-03	FRIDAY	1_Hr_COMP	1120	Specific Conductance	3200	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1120	pH	7.6	pH
28-MAR-03	FRIDAY	1_Hr_COMP	1220	Specific Conductance	2000	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1220	pH	7.5	pH
28-MAR-03	FRIDAY	1_Hr_COMP	1320	Specific Conductance	2000	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1320	pH	7.5	pH
28-MAR-03	FRIDAY	1_Hr_COMP	1420	Specific Conductance	1900	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1420	pH	7.2	pH
28-MAR-03	FRIDAY	1_Hr_COMP	1520	Specific Conductance	1900	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1520	pH	7.2	pH
28-MAR-03	FRIDAY	1_Hr_COMP	1620	Specific Conductance	1900	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1620	pH	7.2	pH
28-MAR-03	FRIDAY	1_Hr_COMP	1720	Specific Conductance	2000	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1720	pH	7.1	pH
28-MAR-03	FRIDAY	1_Hr_COMP	1820	Specific Conductance	2000	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1820	pH	7	pH
28-MAR-03	FRIDAY	1_Hr_COMP	1920	Specific Conductance	2000	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1920	pH	7	pH
28-MAR-03	FRIDAY	1_Hr_COMP	2020	Specific Conductance	1900	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2020	pH	7.1	pH
28-MAR-03	FRIDAY	1_Hr_COMP	2120	Specific Conductance	2000	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2120	pH	6.9	pH
28-MAR-03	FRIDAY	1_Hr_COMP	2220	Specific Conductance	1900	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2220	pH	7.5	pH
28-MAR-03	FRIDAY	1_Hr_COMP	2320	Specific Conductance	1900	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2320	pH	7.2	pH
29-MAR-03	SATURDAY	1_Hr_COMP	20	Specific Conductance	1900	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	20	pH	7.2	pH
29-MAR-03	SATURDAY	1_Hr_COMP	120	Specific Conductance	1900	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	120	pH	7.2	pH
29-MAR-03	SATURDAY	1_Hr_COMP	220	Specific Conductance	1900	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	220	pH	7.3	pH
29-MAR-03	SATURDAY	1_Hr_COMP	320	Specific Conductance	2000	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	320	pH	7	pH
29-MAR-03	SATURDAY	1_Hr_COMP	420	Specific Conductance	2000	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	420	pH	7.3	pH
29-MAR-03	SATURDAY	1_Hr_COMP	520	Specific Conductance	1900	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	520	pH	7.4	pH
29-MAR-03	SATURDAY	1_Hr_COMP	620	Specific Conductance	1900	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	620	pH	7.4	pH
29-MAR-03	SATURDAY	1_Hr_COMP	720	Specific Conductance	1900	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	720	pH	7.4	pH
29-MAR-03	SATURDAY	1_Hr_COMP	820	Specific Conductance	1800	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	820	pH	7.5	pH
29-MAR-03	SATURDAY	COMP_CONDUCT	850	Specific Conductance	2000	umhos/cm
29-MAR-03	SATURDAY	COMP_PH	850	pH	7	pH
29-MAR-03	SATURDAY	GRAB	900	Specific Conductance	2100	umhos/cm
29-MAR-03	SATURDAY	GRAB	900	pH	7.1	pH
05-APR-03	SATURDAY	1_Hr_COMP	815	Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	815	pH	7.6	pH
05-APR-03	SATURDAY	1_Hr_COMP	915	Specific Conductance	2100	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	915	pH	7.8	pH
05-APR-03	SATURDAY	1_Hr_COMP	1015	Specific Conductance	2100	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1015	pH	7.5	pH
05-APR-03	SATURDAY	1_Hr_COMP	1115	Specific Conductance	2200	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1115	pH	7.5	pH
05-APR-03	SATURDAY	1_Hr_COMP	1215	Specific Conductance	2200	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1215	pH	7.3	pH
05-APR-03	SATURDAY	1_Hr_COMP	1315	Specific Conductance	2200	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1315	pH	7.2	pH
05-APR-03	SATURDAY	1_Hr_COMP	1415	Specific Conductance	2200	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1415	pH	7.3	pH
05-APR-03	SATURDAY	1_Hr_COMP	1515	Specific Conductance	2100	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1515	pH	7.3	pH
05-APR-03	SATURDAY	1_Hr_COMP	1615	Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1615	pH	7.3	pH
05-APR-03	SATURDAY	1_Hr_COMP	1715	Specific Conductance	2000	umhos/cm

City of Mexicali
Site 3

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
05-APR-03	SATURDAY	1_Hr_COMP	1715	pH	7.1	pH
05-APR-03	SATURDAY	1_Hr_COMP	1815	Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1815	pH	7	pH
05-APR-03	SATURDAY	1_Hr_COMP	1915	Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1915	pH	7	pH
05-APR-03	SATURDAY	1_Hr_COMP	2015	Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	2015	pH	7	pH
05-APR-03	SATURDAY	1_Hr_COMP	2115	Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	2115	pH	7.4	pH
05-APR-03	SATURDAY	1_Hr_COMP	2215	Specific Conductance	2100	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	2215	pH	7.4	pH
05-APR-03	SATURDAY	1_Hr_COMP	2315	Specific Conductance	2100	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	2315	pH	7.1	pH
06-APR-03	SUNDAY	1_Hr_COMP	15	Specific Conductance	2000	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	15	pH	7.1	pH
06-APR-03	SUNDAY	1_Hr_COMP	115	Specific Conductance	2000	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	115	pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP	215	Specific Conductance	2000	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	215	pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP	315	Specific Conductance	2000	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	315	pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP	415	Specific Conductance	1900	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	415	pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP	515	Specific Conductance	1900	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	515	pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP	615	Specific Conductance	1900	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	615	pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP	715	Specific Conductance	1900	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	715	pH	7.4	pH
06-APR-03	SUNDAY	COMP_CONDUCT	930	Specific Conductance	1900	umhos/cm
06-APR-03	SUNDAY	COMP_PH	930	pH	7.4	pH
06-APR-03	SUNDAY	GRAB	940	Specific Conductance	1900	umhos/cm
06-APR-03	SUNDAY	GRAB	940	pH	7.4	pH
14-APR-03	MONDAY	1_Hr_COMP	820	Specific Conductance	1900	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	820	pH	6.9	pH
14-APR-03	MONDAY	1_Hr_COMP	920	Specific Conductance	1900	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	920	pH	7.5	pH
14-APR-03	MONDAY	1_Hr_COMP	1020	Specific Conductance	2000	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1020	pH	7.5	pH
14-APR-03	MONDAY	1_Hr_COMP	1120	Specific Conductance	2000	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1120	pH	7.5	pH
14-APR-03	MONDAY	1_Hr_COMP	1220	Specific Conductance	2100	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1220	pH	7.2	pH
14-APR-03	MONDAY	1_Hr_COMP	1320	Specific Conductance	2100	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1320	pH	7.3	pH
14-APR-03	MONDAY	1_Hr_COMP	1420	Specific Conductance	2000	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1420	pH	7.3	pH
14-APR-03	MONDAY	1_Hr_COMP	1520	Specific Conductance	2000	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1520	pH	7.2	pH
14-APR-03	MONDAY	1_Hr_COMP	1620	Specific Conductance	2000	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1620	pH	7.1	pH
14-APR-03	MONDAY	1_Hr_COMP	1720	Specific Conductance	1900	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1720	pH	7.3	pH
14-APR-03	MONDAY	1_Hr_COMP	1820	Specific Conductance	2000	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1820	pH	7.3	pH
14-APR-03	MONDAY	1_Hr_COMP	1920	Specific Conductance	1900	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1920	pH	7.3	pH
14-APR-03	MONDAY	1_Hr_COMP	2020	Specific Conductance	1900	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2020	pH	7.2	pH
14-APR-03	MONDAY	1_Hr_COMP	2120	Specific Conductance	1900	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2120	pH	7.4	pH
14-APR-03	MONDAY	1_Hr_COMP	2220	Specific Conductance	1900	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2220	pH	7.3	pH
14-APR-03	MONDAY	1_Hr_COMP	2320	Specific Conductance	2000	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2320	pH	7.1	pH
15-APR-03	TUESDAY	1_Hr_COMP	20	Specific Conductance	1900	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	20	pH	7.3	pH
15-APR-03	TUESDAY	1_Hr_COMP	120	Specific Conductance	1900	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	120	pH	7.4	pH
15-APR-03	TUESDAY	1_Hr_COMP	220	Specific Conductance	1900	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	220	pH	7.4	pH
15-APR-03	TUESDAY	1_Hr_COMP	320	Specific Conductance	1900	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	320	pH	7.3	pH

City of Mexicali
Site 3

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
15-APR-03	TUESDAY	1_Hr_COMP	420	Specific Conductance	1900	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	420	pH	7.3	pH
15-APR-03	TUESDAY	1_Hr_COMP	520	Specific Conductance	1800	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	520	pH	7.8	pH
15-APR-03	TUESDAY	1_Hr_COMP	620	Specific Conductance	1800	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	620	pH	7.4	pH
15-APR-03	TUESDAY	1_Hr_COMP	720	Specific Conductance	1900	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	720	pH	7.7	pH
15-APR-03	TUESDAY	COMP_CONDUCT	840	Specific Conductance	1900	umhos/cm
15-APR-03	TUESDAY	COMP_PH	840	pH	7.4	pH
15-APR-03	TUESDAY	GRAB	845	Specific Conductance	1800	umhos/cm
15-APR-03	TUESDAY	GRAB	845	pH	7.5	pH
22-APR-03	TUESDAY	1_Hr_COMP	905	Specific Conductance	1900	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	905	pH	7.3	pH
22-APR-03	TUESDAY	1_Hr_COMP	1005	Specific Conductance	2000	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1005	pH	7.4	pH
22-APR-03	TUESDAY	1_Hr_COMP	1105	Specific Conductance	2300	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1105	pH	7.5	pH
22-APR-03	TUESDAY	1_Hr_COMP	1205	Specific Conductance	2300	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1205	pH	7.4	pH
22-APR-03	TUESDAY	1_Hr_COMP	1305	Specific Conductance	2300	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1305	pH	7.2	pH
22-APR-03	TUESDAY	1_Hr_COMP	1405	Specific Conductance	2200	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1405	pH	7.3	pH
22-APR-03	TUESDAY	1_Hr_COMP	1505	Specific Conductance	2300	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1505	pH	7.2	pH
22-APR-03	TUESDAY	1_Hr_COMP	1605	Specific Conductance	2000	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1605	pH	7.3	pH
22-APR-03	TUESDAY	1_Hr_COMP	1705	Specific Conductance	2000	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1705	pH	7.3	pH
22-APR-03	TUESDAY	1_Hr_COMP	1805	Specific Conductance	2000	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1805	pH	7.2	pH
22-APR-03	TUESDAY	1_Hr_COMP	1905	Specific Conductance	2000	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1905	pH	7.3	pH
22-APR-03	TUESDAY	1_Hr_COMP	2005	Specific Conductance	2000	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2005	pH	7.5	pH
22-APR-03	TUESDAY	1_Hr_COMP	2105	Specific Conductance	2200	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2105	pH	7.5	pH
22-APR-03	TUESDAY	1_Hr_COMP	2205	Specific Conductance	2000	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2205	pH	7.6	pH
22-APR-03	TUESDAY	1_Hr_COMP	2305	Specific Conductance	2200	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2305	pH	7.7	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	5	Specific Conductance	2000	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	5	pH	7.2	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	105	Specific Conductance	2000	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	105	pH	7.4	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	205	Specific Conductance	2000	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	205	pH	7.4	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	305	Specific Conductance	2000	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	305	pH	7.5	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	405	Specific Conductance	2000	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	405	pH	7.4	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	505	Specific Conductance	2000	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	505	pH	7.4	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	605	Specific Conductance	2000	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	605	pH	7.4	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	705	Specific Conductance	2000	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	705	pH	7.4	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	805	Specific Conductance	2000	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	805	pH	7.5	pH
23-APR-03	WEDNESDAY	COMP_CONDUCT	925	Specific Conductance	2000	umhos/cm
23-APR-03	WEDNESDAY	COMP_PH	925	pH	7.5	pH
23-APR-03	WEDNESDAY	GRAB	935	Specific Conductance	1900	umhos/cm
23-APR-03	WEDNESDAY	GRAB	935	pH	7.3	pH
30-APR-03	WEDNESDAY	1_Hr_COMP	850	Specific Conductance	1900	umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	850	pH	7.1	pH
30-APR-03	WEDNESDAY	1_Hr_COMP	950	Specific Conductance	2000	umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	950	pH	7.3	pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1050	Specific Conductance	2000	umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1050	pH	7.3	pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1150	Specific Conductance	2000	umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1150	pH	7.2	pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1250	Specific Conductance	2100	umhos/cm

City of Mexicali
Site 3

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
30-APR-03	WEDNESDAY	1_Hr_COMP	1250	pH	7.1	pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1350	Specific Conductance	2100	umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1350	pH	7.1	pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1450	Specific Conductance	2000	umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1450	pH	7.2	pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1550	Specific Conductance	2000	umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1550	pH	7.2	pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1650	Specific Conductance	2000	umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1650	pH	7	pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1750	Specific Conductance	2000	umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1750	pH	7	pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1850	Specific Conductance	1900	umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1850	pH	7.1	pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1950	Specific Conductance	2000	umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1950	pH	7.1	pH
30-APR-03	WEDNESDAY	1_Hr_COMP	2050	Specific Conductance	1900	umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	2050	pH	7.1	pH
30-APR-03	WEDNESDAY	1_Hr_COMP	2150	Specific Conductance	1900	umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	2150	pH	7	pH
30-APR-03	WEDNESDAY	1_Hr_COMP	2250	Specific Conductance	1900	umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	2250	pH	7	pH
30-APR-03	WEDNESDAY	1_Hr_COMP	2350	Specific Conductance	1900	umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	2350	pH	7	pH
01-MAY-03	THURSDAY	1_Hr_COMP	50	Specific Conductance	2100	umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	50	pH	7.2	pH
01-MAY-03	THURSDAY	1_Hr_COMP	150	Specific Conductance	1900	umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	150	pH	7.2	pH
01-MAY-03	THURSDAY	1_Hr_COMP	250	Specific Conductance	1900	umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	250	pH	7.2	pH
01-MAY-03	THURSDAY	1_Hr_COMP	350	Specific Conductance	1900	umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	350	pH	7.2	pH
01-MAY-03	THURSDAY	1_Hr_COMP	450	Specific Conductance	1900	umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	450	pH	7.3	pH
01-MAY-03	THURSDAY	1_Hr_COMP	550	Specific Conductance	1900	umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	550	pH	7.3	pH
01-MAY-03	THURSDAY	1_Hr_COMP	650	Specific Conductance	1800	umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	650	pH	7.4	pH
01-MAY-03	THURSDAY	1_Hr_COMP	750	Specific Conductance	1800	umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	750	pH	7.4	pH
01-MAY-03	THURSDAY	COMP_CONDUCT	815	Specific Conductance	1900	umhos/cm
01-MAY-03	THURSDAY	COMP_PH	815	pH	7.4	pH
01-MAY-03	THURSDAY	GRAB	825	Specific Conductance	1900	umhos/cm
01-MAY-03	THURSDAY	GRAB	825	pH	7.4	pH
08-MAY-03	THURSDAY	1_Hr_COMP	810	Specific Conductance	1900	umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	810	pH	6.8	pH
08-MAY-03	THURSDAY	1_Hr_COMP	910	Specific Conductance	2000	umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	910	pH	6.7	pH
08-MAY-03	THURSDAY	1_Hr_COMP	1010	Specific Conductance	2000	umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1010	pH	6.9	pH
08-MAY-03	THURSDAY	1_Hr_COMP	1110	Specific Conductance	2000	umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1110	pH	7.1	pH
08-MAY-03	THURSDAY	1_Hr_COMP	1210	Specific Conductance	2200	umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1210	pH	7.2	pH
08-MAY-03	THURSDAY	1_Hr_COMP	1310	Specific Conductance	2000	umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1310	pH	7.1	pH
08-MAY-03	THURSDAY	1_Hr_COMP	1410	Specific Conductance	2000	umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1410	pH	7.2	pH
08-MAY-03	THURSDAY	1_Hr_COMP	1510	Specific Conductance	2000	umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1510	pH	7.2	pH
08-MAY-03	THURSDAY	1_Hr_COMP	1610	Specific Conductance	1900	umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1610	pH	7.3	pH
08-MAY-03	THURSDAY	1_Hr_COMP	1710	Specific Conductance	1900	umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1710	pH	7.1	pH
08-MAY-03	THURSDAY	1_Hr_COMP	1810	Specific Conductance	2000	umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1810	pH	7.1	pH
08-MAY-03	THURSDAY	1_Hr_COMP	1910	Specific Conductance	2000	umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1910	pH	7.2	pH
08-MAY-03	THURSDAY	1_Hr_COMP	2010	Specific Conductance	1900	umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	2010	pH	7.2	pH
08-MAY-03	THURSDAY	1_Hr_COMP	2110	Specific Conductance	1900	umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	2110	pH	7.2	pH
08-MAY-03	THURSDAY	1_Hr_COMP	2210	Specific Conductance	1900	umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	2210	pH	7.2	pH

City of Mexicali
Site 3

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
08-MAY-03	THURSDAY	1_Hr_COMP	2310 Specific Conductance	1900 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	2310 pH	7.2 pH
09-MAY-03	FRIDAY	1_Hr_COMP	10 Specific Conductance	1900 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	10 pH	7.1 pH
09-MAY-03	FRIDAY	1_Hr_COMP	110 Specific Conductance	1900 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	110 pH	7.1 pH
09-MAY-03	FRIDAY	1_Hr_COMP	210 Specific Conductance	1900 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	210 pH	7.2 pH
09-MAY-03	FRIDAY	1_Hr_COMP	310 Specific Conductance	1900 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	310 pH	7.2 pH
09-MAY-03	FRIDAY	1_Hr_COMP	410 Specific Conductance	1900 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	410 pH	7.3 pH
09-MAY-03	FRIDAY	1_Hr_COMP	510 Specific Conductance	1900 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	510 pH	7.3 pH
09-MAY-03	FRIDAY	1_Hr_COMP	610 Specific Conductance	1800 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	610 pH	7.3 pH
09-MAY-03	FRIDAY	1_Hr_COMP	710 Specific Conductance	1800 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	710 pH	7.4 pH
09-MAY-03	FRIDAY	COMP_CONDUCT	810 Specific Conductance	2000 umhos/cm
09-MAY-03	FRIDAY	COMP_PH	810 pH	7 pH
09-MAY-03	FRIDAY	GRAB	820 Specific Conductance	1800 umhos/cm
09-MAY-03	FRIDAY	GRAB	820 pH	7.1 pH
16-MAY-03	FRIDAY	1_Hr_COMP	825 Specific Conductance	2100 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	825 pH	7.2 pH
16-MAY-03	FRIDAY	1_Hr_COMP	925 Specific Conductance	2100 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	925 pH	7.4 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1025 Specific Conductance	2200 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1025 pH	7.1 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1125 Specific Conductance	2200 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1125 pH	7.4 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1225 Specific Conductance	2200 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1225 pH	7.4 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1325 Specific Conductance	2200 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1325 pH	7.2 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1425 Specific Conductance	2200 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1425 pH	7.3 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1525 Specific Conductance	2200 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1525 pH	7.3 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1625 Specific Conductance	2200 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1625 pH	7.3 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1725 Specific Conductance	2100 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1725 pH	7.3 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1825 Specific Conductance	2200 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1825 pH	7.3 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1925 Specific Conductance	2100 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1925 pH	7.2 pH
16-MAY-03	FRIDAY	1_Hr_COMP	2025 Specific Conductance	2100 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2025 pH	7.3 pH
16-MAY-03	FRIDAY	1_Hr_COMP	2125 Specific Conductance	2100 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2125 pH	7.3 pH
16-MAY-03	FRIDAY	1_Hr_COMP	2225 Specific Conductance	2100 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2225 pH	7.3 pH
16-MAY-03	FRIDAY	1_Hr_COMP	2325 Specific Conductance	2100 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2325 pH	7.3 pH
17-MAY-03	SATURDAY	1_Hr_COMP	25 Specific Conductance	2100 umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	25 pH	7.3 pH
17-MAY-03	SATURDAY	1_Hr_COMP	125 Specific Conductance	2200 umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	125 pH	7.2 pH
17-MAY-03	SATURDAY	1_Hr_COMP	225 Specific Conductance	2000 umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	225 pH	7.3 pH
17-MAY-03	SATURDAY	1_Hr_COMP	325 Specific Conductance	2000 umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	325 pH	7.3 pH
17-MAY-03	SATURDAY	1_Hr_COMP	425 Specific Conductance	2000 umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	425 pH	7.3 pH
17-MAY-03	SATURDAY	1_Hr_COMP	525 Specific Conductance	2000 umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	525 pH	7.3 pH
17-MAY-03	SATURDAY	1_Hr_COMP	625 Specific Conductance	2000 umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	625 pH	7.4 pH
17-MAY-03	SATURDAY	1_Hr_COMP	725 Specific Conductance	2200 umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	725 pH	7.5 pH
17-MAY-03	SATURDAY	COMP_CONDUCT	805 Specific Conductance	2100 umhos/cm
17-MAY-03	SATURDAY	COMP_PH	805 pH	7.1 pH
17-MAY-03	SATURDAY	GRAB	810 Specific Conductance	2000 umhos/cm

City of Mexicali
Site 3

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
17-MAY-03	SATURDAY	GRAB	810 pH	7.2 pH
24-MAY-03	SATURDAY	1_Hr_COMP	800 Specific Conductance	2000 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	800 pH	7.3 pH
24-MAY-03	SATURDAY	1_Hr_COMP	900 Specific Conductance	2000 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	900 pH	7.3 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1000 Specific Conductance	2100 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1000 pH	7.2 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1100 Specific Conductance	2200 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1100 pH	7.3 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1200 Specific Conductance	2200 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1200 pH	7.3 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1300 Specific Conductance	2200 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1300 pH	7.3 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1400 Specific Conductance	2200 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1400 pH	7.1 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1500 Specific Conductance	2200 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1500 pH	7.1 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1600 Specific Conductance	2200 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1600 pH	7.2 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1700 Specific Conductance	2100 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1700 pH	7.2 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1800 Specific Conductance	2100 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1800 pH	7.3 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1900 Specific Conductance	2100 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1900 pH	7.2 pH
24-MAY-03	SATURDAY	1_Hr_COMP	2000 Specific Conductance	2100 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2000 pH	7.4 pH
24-MAY-03	SATURDAY	1_Hr_COMP	2100 Specific Conductance	2000 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2100 pH	7.2 pH
24-MAY-03	SATURDAY	1_Hr_COMP	2200 Specific Conductance	2000 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2200 pH	7.3 pH
24-MAY-03	SATURDAY	1_Hr_COMP	2300 Specific Conductance	2100 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2300 pH	7.3 pH
24-MAY-03	SATURDAY	1_Hr_COMP	2400 Specific Conductance	2000 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2400 pH	7.3 pH
25-MAY-03	SUNDAY	1_Hr_COMP	100 Specific Conductance	2100 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	100 pH	7.3 pH
25-MAY-03	SUNDAY	1_Hr_COMP	200 Specific Conductance	2000 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	200 pH	7.2 pH
25-MAY-03	SUNDAY	1_Hr_COMP	300 Specific Conductance	2100 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	300 pH	7.3 pH
25-MAY-03	SUNDAY	1_Hr_COMP	400 Specific Conductance	2000 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	400 pH	7.3 pH
25-MAY-03	SUNDAY	1_Hr_COMP	500 Specific Conductance	2000 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	500 pH	7.4 pH
25-MAY-03	SUNDAY	1_Hr_COMP	600 Specific Conductance	2000 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	600 pH	7.5 pH
25-MAY-03	SUNDAY	1_Hr_COMP	700 Specific Conductance	2000 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	700 pH	7.5 pH
25-MAY-03	SUNDAY	COMP_CONDUCT	750 Specific Conductance	2100 umhos/cm
25-MAY-03	SUNDAY	COMP_PH	750 pH	7.5 pH
25-MAY-03	SUNDAY	GRAB	800 Specific Conductance	1900 umhos/cm
25-MAY-03	SUNDAY	GRAB	800 pH	7.3 pH
01-JUN-03	SUNDAY	1_Hr_COMP	806 Specific Conductance	1900 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	806 pH	7.6 pH
01-JUN-03	SUNDAY	1_Hr_COMP	906 Specific Conductance	2100 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	906 pH	7.6 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1006 Specific Conductance	2000 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1006 pH	7.4 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1106 Specific Conductance	2000 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1106 pH	7.5 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1206 Specific Conductance	2200 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1206 pH	8.6 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1306 Specific Conductance	2100 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1306 pH	7.4 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1406 Specific Conductance	2100 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1406 pH	7.3 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1506 Specific Conductance	2100 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1506 pH	7.3 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1606 Specific Conductance	2100 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1606 pH	7.3 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1706 Specific Conductance	2100 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1706 pH	7.2 pH

City of Mexicali
Site 3

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
01-JUN-03	SUNDAY	1_Hr_COMP	1806 Specific Conductance	8000 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1806 pH	7.2 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1906 Specific Conductance	8000 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1906 pH	7.2 pH
01-JUN-03	SUNDAY	1_Hr_COMP	2006 Specific Conductance	8000 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2006 pH	7.3 pH
01-JUN-03	SUNDAY	1_Hr_COMP	2106 Specific Conductance	8000 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2106 pH	7.2 pH
01-JUN-03	SUNDAY	1_Hr_COMP	2206 Specific Conductance	2100 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2206 pH	7.2 pH
01-JUN-03	SUNDAY	1_Hr_COMP	2306 Specific Conductance	2000 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2306 pH	7.3 pH
02-JUN-03	MONDAY	1_Hr_COMP	6 Specific Conductance	2000 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	6 pH	7.3 pH
02-JUN-03	MONDAY	1_Hr_COMP	106 Specific Conductance	2000 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	106 pH	7.3 pH
02-JUN-03	MONDAY	1_Hr_COMP	206 Specific Conductance	2000 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	206 pH	7.2 pH
02-JUN-03	MONDAY	1_Hr_COMP	306 Specific Conductance	2000 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	306 pH	7.2 pH
02-JUN-03	MONDAY	1_Hr_COMP	406 Specific Conductance	1900 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	406 pH	7.3 pH
02-JUN-03	MONDAY	1_Hr_COMP	506 Specific Conductance	1900 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	506 pH	7.3 pH
02-JUN-03	MONDAY	1_Hr_COMP	606 Specific Conductance	1900 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	606 pH	7.3 pH
02-JUN-03	MONDAY	1_Hr_COMP	706 Specific Conductance	1900 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	706 pH	7.4 pH
02-JUN-03	MONDAY	COMP_CONDUCT	815 Specific Conductance	2000 umhos/cm
02-JUN-03	MONDAY	COMP_PH	815 pH	7.4 pH
02-JUN-03	MONDAY	GRAB	825 Specific Conductance	1900 umhos/cm
02-JUN-03	MONDAY	GRAB	825 pH	7.5 pH
09-JUN-03	MONDAY	1_Hr_COMP	830 Specific Conductance	1900 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	830 pH	7.5 pH
09-JUN-03	MONDAY	1_Hr_COMP	930 Specific Conductance	1900 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	930 pH	7.5 pH
09-JUN-03	MONDAY	1_Hr_COMP	1030 Specific Conductance	1900 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1030 pH	7.5 pH
09-JUN-03	MONDAY	1_Hr_COMP	1130 Specific Conductance	2000 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1130 pH	7.7 pH
09-JUN-03	MONDAY	1_Hr_COMP	1230 Specific Conductance	1600 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1230 pH	7.8 pH
09-JUN-03	MONDAY	1_Hr_COMP	1330 Specific Conductance	1500 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1330 pH	7.8 pH
09-JUN-03	MONDAY	1_Hr_COMP	1430 Specific Conductance	1500 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1430 pH	7.8 pH
09-JUN-03	MONDAY	1_Hr_COMP	1530 Specific Conductance	1900 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1530 pH	7.8 pH
09-JUN-03	MONDAY	1_Hr_COMP	1630 Specific Conductance	1900 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1630 pH	7.8 pH
09-JUN-03	MONDAY	1_Hr_COMP	1730 Specific Conductance	1900 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1730 pH	7.2 pH
09-JUN-03	MONDAY	1_Hr_COMP	1830 Specific Conductance	2000 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1830 pH	7.1 pH
09-JUN-03	MONDAY	1_Hr_COMP	1930 Specific Conductance	1800 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1930 pH	7.1 pH
09-JUN-03	MONDAY	1_Hr_COMP	2030 Specific Conductance	1900 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	2030 pH	7.8 pH
09-JUN-03	MONDAY	1_Hr_COMP	2130 Specific Conductance	2000 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	2130 pH	7.8 pH
09-JUN-03	MONDAY	1_Hr_COMP	2230 Specific Conductance	2000 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	2230 pH	7.8 pH
09-JUN-03	MONDAY	1_Hr_COMP	2330 Specific Conductance	2000 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	2330 pH	7.7 pH
10-JUN-03	TUESDAY	1_Hr_COMP	30 Specific Conductance	1900 umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	30 pH	7.8 pH
10-JUN-03	TUESDAY	1_Hr_COMP	130 Specific Conductance	1900 umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	130 pH	7.9 pH
10-JUN-03	TUESDAY	1_Hr_COMP	230 Specific Conductance	1700 umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	230 pH	7.9 pH
10-JUN-03	TUESDAY	1_Hr_COMP	330 Specific Conductance	1900 umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	330 pH	7.1 pH
10-JUN-03	TUESDAY	1_Hr_COMP	430 Specific Conductance	1700 umhos/cm

City of Mexicali
Site 3

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
10-JUN-03	TUESDAY	1_Hr_COMP	430 pH	7.8 pH
10-JUN-03	TUESDAY	1_Hr_COMP	530 Specific Conductance	1800 umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	530 pH	7.9 pH
10-JUN-03	TUESDAY	1_Hr_COMP	630 Specific Conductance	1800 umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	630 pH	8 pH
10-JUN-03	TUESDAY	1_Hr_COMP	730 Specific Conductance	1800 umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	730 pH	8 pH
10-JUN-03	TUESDAY	COMP_CONDUCT	840 Specific Conductance	2000 umhos/cm
10-JUN-03	TUESDAY	COMP_PH	840 pH	7.2 pH
10-JUN-03	TUESDAY	GRAB	850 Specific Conductance	1900 umhos/cm
10-JUN-03	TUESDAY	GRAB	850 pH	7.2 pH
18-JUN-03	WEDNESDAY	GRAB	810 Specific Conductance	1800 umhos/cm
18-JUN-03	WEDNESDAY	GRAB	810 pH	7.4 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	830 Specific Conductance	2100 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	830 pH	7.1 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	930 Specific Conductance	1900 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	930 pH	7.7 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1030 Specific Conductance	1900 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1030 pH	7.4 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1130 Specific Conductance	1600 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1130 pH	7.7 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1230 Specific Conductance	1900 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1230 pH	7.6 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1330 Specific Conductance	2000 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1330 pH	7.8 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1430 Specific Conductance	2000 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1430 pH	7.9 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1530 Specific Conductance	2000 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1530 pH	8 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1630 Specific Conductance	2000 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1630 pH	8 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1730 Specific Conductance	2000 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1730 pH	8.1 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1830 Specific Conductance	1900 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1830 pH	8 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1930 Specific Conductance	1900 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1930 pH	8.1 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	2030 Specific Conductance	2000 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	2030 pH	8 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	2130 Specific Conductance	1900 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	2130 pH	8 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	2230 Specific Conductance	1900 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	2230 pH	7.8 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	2330 Specific Conductance	1900 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	2330 pH	7.7 pH
26-JUN-03	THURSDAY	1_Hr_COMP	330 Specific Conductance	2000 umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	330 pH	7.8 pH
26-JUN-03	THURSDAY	1_Hr_COMP	430 Specific Conductance	1900 umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	430 pH	7.9 pH
26-JUN-03	THURSDAY	1_Hr_COMP	530 Specific Conductance	1900 umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	530 pH	7.9 pH
26-JUN-03	THURSDAY	1_Hr_COMP	630 Specific Conductance	2000 umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	630 pH	8 pH
26-JUN-03	THURSDAY	1_Hr_COMP	730 Specific Conductance	2100 umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	730 pH	7.9 pH
26-JUN-03	THURSDAY	COMP_CONDUCT	810 Specific Conductance	2000 umhos/cm
26-JUN-03	THURSDAY	COMP_PH	810 pH	7.9 pH
26-JUN-03	THURSDAY	GRAB	820 Specific Conductance	2000 umhos/cm
26-JUN-03	THURSDAY	GRAB	820 pH	7.1 pH
03-JUL-03	THURSDAY	1_Hr_COMP	810 Specific Conductance	1800 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	810 pH	7.4 pH
03-JUL-03	THURSDAY	1_Hr_COMP	910 Specific Conductance	1800 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	910 pH	7.7 pH
03-JUL-03	THURSDAY	1_Hr_COMP	1010 Specific Conductance	1800 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1010 pH	7.8 pH
03-JUL-03	THURSDAY	1_Hr_COMP	1110 Specific Conductance	1800 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1110 pH	7.9 pH
03-JUL-03	THURSDAY	1_Hr_COMP	1210 Specific Conductance	1900 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1210 pH	7.9 pH
03-JUL-03	THURSDAY	1_Hr_COMP	1310 Specific Conductance	1900 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1310 pH	7.9 pH
03-JUL-03	THURSDAY	1_Hr_COMP	1410 Specific Conductance	1900 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1410 pH	7.8 pH

City of Mexicali
Site 3

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
03-JUL-03	THURSDAY	1_Hr_COMP	1510 Specific Conductance	1900 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1510 pH	7.7 pH
03-JUL-03	THURSDAY	1_Hr_COMP	1610 Specific Conductance	1900 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1610 pH	7.8 pH
03-JUL-03	THURSDAY	1_Hr_COMP	1710 Specific Conductance	1900 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1710 pH	7.5 pH
03-JUL-03	THURSDAY	1_Hr_COMP	1810 Specific Conductance	1900 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1810 pH	7.5 pH
03-JUL-03	THURSDAY	1_Hr_COMP	1910 Specific Conductance	1900 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1910 pH	7.8 pH
03-JUL-03	THURSDAY	1_Hr_COMP	2010 Specific Conductance	2000 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	2010 pH	7.9 pH
03-JUL-03	THURSDAY	1_Hr_COMP	2110 Specific Conductance	2000 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	2110 pH	7.9 pH
03-JUL-03	THURSDAY	1_Hr_COMP	2210 Specific Conductance	2000 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	2210 pH	7.9 pH
03-JUL-03	THURSDAY	1_Hr_COMP	2310 Specific Conductance	2000 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	2310 pH	7.9 pH
04-JUL-03	FRIDAY	1_Hr_COMP	10 Specific Conductance	2000 umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	10 pH	7.9 pH
04-JUL-03	FRIDAY	1_Hr_COMP	110 Specific Conductance	1900 umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	110 pH	7.1 pH
04-JUL-03	FRIDAY	1_Hr_COMP	210 Specific Conductance	1900 umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	210 pH	7.1 pH
04-JUL-03	FRIDAY	1_Hr_COMP	310 Specific Conductance	2000 umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	310 pH	7.8 pH
04-JUL-03	FRIDAY	1_Hr_COMP	410 Specific Conductance	2000 umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	410 pH	7.7 pH
04-JUL-03	FRIDAY	1_Hr_COMP	510 Specific Conductance	1900 umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	510 pH	7.9 pH
04-JUL-03	FRIDAY	1_Hr_COMP	610 Specific Conductance	1800 umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	610 pH	7.9 pH
04-JUL-03	FRIDAY	1_Hr_COMP	710 Specific Conductance	1800 umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	710 pH	7.9 pH
04-JUL-03	FRIDAY	COMP_CONDUCT	825 Specific Conductance	1800 umhos/cm
04-JUL-03	FRIDAY	COMP_PH	825 pH	7.6 pH
04-JUL-03	FRIDAY	GRAB	830 Specific Conductance	2000 umhos/cm
04-JUL-03	FRIDAY	GRAB	830 pH	7.2 pH
11-JUL-03	FRIDAY	1_Hr_COMP	840 Specific Conductance	2400 umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	840 pH	7.3 pH
11-JUL-03	FRIDAY	1_Hr_COMP	940 Specific Conductance	2500 umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	940 pH	7.2 pH
11-JUL-03	FRIDAY	1_Hr_COMP	1040 Specific Conductance	2000 umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1040 pH	7.3 pH
11-JUL-03	FRIDAY	1_Hr_COMP	1140 Specific Conductance	2100 umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1140 pH	7.2 pH
11-JUL-03	FRIDAY	1_Hr_COMP	1240 Specific Conductance	2000 umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1240 pH	6.8 pH
11-JUL-03	FRIDAY	1_Hr_COMP	1340 Specific Conductance	2100 umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1340 pH	7.2 pH
11-JUL-03	FRIDAY	1_Hr_COMP	1440 Specific Conductance	2200 umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1440 pH	7.2 pH
11-JUL-03	FRIDAY	1_Hr_COMP	1540 Specific Conductance	2200 umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1540 pH	7.2 pH
11-JUL-03	FRIDAY	1_Hr_COMP	1640 Specific Conductance	1900 umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1640 pH	7.2 pH
11-JUL-03	FRIDAY	1_Hr_COMP	1740 Specific Conductance	1900 umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1740 pH	7.1 pH
11-JUL-03	FRIDAY	1_Hr_COMP	1840 Specific Conductance	1900 umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1840 pH	7.2 pH
11-JUL-03	FRIDAY	1_Hr_COMP	1940 Specific Conductance	1900 umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1940 pH	7.2 pH
11-JUL-03	FRIDAY	1_Hr_COMP	2040 Specific Conductance	1900 umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	2040 pH	7.2 pH
11-JUL-03	FRIDAY	1_Hr_COMP	2140 Specific Conductance	1900 umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	2140 pH	7.2 pH
11-JUL-03	FRIDAY	1_Hr_COMP	2240 Specific Conductance	2000 umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	2240 pH	7.3 pH
11-JUL-03	FRIDAY	1_Hr_COMP	2340 Specific Conductance	1900 umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	2340 pH	7.3 pH
12-JUL-03	SATURDAY	COMP_CONDUCT	810 Specific Conductance	2000 umhos/cm
12-JUL-03	SATURDAY	COMP_PH	810 pH	7.2 pH
12-JUL-03	SATURDAY	GRAB	815 Specific Conductance	1900 umhos/cm

City of Mexicali
Site 3

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
12-JUL-03	SATURDAY	GRAB	815 pH	7.6 pH
19-JUL-03	SATURDAY	1_Hr_COMP	800 Specific Conductance	1800 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	800 pH	7.6 pH
19-JUL-03	SATURDAY	1_Hr_COMP	900 Specific Conductance	1900 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	900 pH	7.4 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1000 Specific Conductance	1800 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1000 pH	7.5 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1100 Specific Conductance	1900 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1100 pH	7.4 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1200 Specific Conductance	2000 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1200 pH	7.3 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1300 Specific Conductance	2000 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1300 pH	7.3 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1400 Specific Conductance	2000 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1400 pH	7.2 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1500 Specific Conductance	2100 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1500 pH	7.1 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1600 Specific Conductance	2000 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1600 pH	7.1 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1700 Specific Conductance	2000 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1700 pH	7.1 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1800 Specific Conductance	2000 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1800 pH	7.1 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1900 Specific Conductance	2000 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1900 pH	7.2 pH
19-JUL-03	SATURDAY	1_Hr_COMP	2000 Specific Conductance	1900 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	2000 pH	7.1 pH
19-JUL-03	SATURDAY	1_Hr_COMP	2100 Specific Conductance	1900 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	2100 pH	7.1 pH
19-JUL-03	SATURDAY	1_Hr_COMP	2200 Specific Conductance	2000 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	2200 pH	7.2 pH
19-JUL-03	SATURDAY	1_Hr_COMP	2300 Specific Conductance	2000 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	2300 pH	7.2 pH
19-JUL-03	SATURDAY	1_Hr_COMP	2400 Specific Conductance	2000 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	2400 pH	7.2 pH
20-JUL-03	SUNDAY	1_Hr_COMP	100 Specific Conductance	1900 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	100 pH	7.3 pH
20-JUL-03	SUNDAY	1_Hr_COMP	200 Specific Conductance	1900 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	200 pH	7.2 pH
20-JUL-03	SUNDAY	1_Hr_COMP	300 Specific Conductance	1900 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	300 pH	7.2 pH
20-JUL-03	SUNDAY	1_Hr_COMP	400 Specific Conductance	1900 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	400 pH	7.2 pH
20-JUL-03	SUNDAY	1_Hr_COMP	500 Specific Conductance	1900 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	500 pH	7.3 pH
20-JUL-03	SUNDAY	1_Hr_COMP	600 Specific Conductance	1900 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	600 pH	7.3 pH
20-JUL-03	SUNDAY	1_Hr_COMP	700 Specific Conductance	1900 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	700 pH	7.3 pH

SITE 4

City of Mexicali
Site 4

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
13-JAN-03	MONDAY	1_Hr_COMP	1240	Specific Conductance	2600	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1240	pH	7.3	pH
13-JAN-03	MONDAY	1_Hr_COMP	1340	Specific Conductance	2900	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1340	pH	7.3	pH
13-JAN-03	MONDAY	1_Hr_COMP	1440	Specific Conductance	2700	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1440	pH	7.3	pH
13-JAN-03	MONDAY	1_Hr_COMP	1540	Specific Conductance	2800	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1540	pH	7.1	pH
13-JAN-03	MONDAY	1_Hr_COMP	1640	Specific Conductance	2700	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1640	pH	7.2	pH
13-JAN-03	MONDAY	1_Hr_COMP	1740	Specific Conductance	2800	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1740	pH	7.2	pH
13-JAN-03	MONDAY	1_Hr_COMP	1840	Specific Conductance	2900	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1840	pH	7.2	pH
13-JAN-03	MONDAY	1_Hr_COMP	1940	Specific Conductance	3100	umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1940	pH	7.3	pH
14-JAN-03	TUESDAY	COMP_CONDUCT	1320	Specific Conductance	2900	umhos/cm
14-JAN-03	TUESDAY	COMP_PH	1320	pH	7.1	pH
14-JAN-03	TUESDAY	GRAB	1330	Specific Conductance	2800	umhos/cm
14-JAN-03	TUESDAY	GRAB	1330	pH	7.4	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1240	Specific Conductance	2700	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1240	pH	7.2	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1340	Specific Conductance	3200	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1340	pH	7.3	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1440	Specific Conductance	3500	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1440	pH	7.5	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1540	Specific Conductance	3000	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1540	pH	7.3	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1640	Specific Conductance	2700	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1640	pH	7.2	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1740	Specific Conductance	2800	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1740	pH	7	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1840	Specific Conductance	2800	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1840	pH	7.2	pH
21-JAN-03	TUESDAY	1_Hr_COMP	1940	Specific Conductance	2900	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1940	pH	7.3	pH
21-JAN-03	TUESDAY	1_Hr_COMP	2040	Specific Conductance	3400	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	2040	pH	7.4	pH
21-JAN-03	TUESDAY	1_Hr_COMP	2140	Specific Conductance	3200	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	2140	pH	7.4	pH
21-JAN-03	TUESDAY	1_Hr_COMP	2240	Specific Conductance	3000	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	2240	pH	7.4	pH
21-JAN-03	TUESDAY	1_Hr_COMP	2340	Specific Conductance	3600	umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	2340	pH	7.4	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	40	Specific Conductance	3100	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	40	pH	7.5	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	140	Specific Conductance	3400	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	140	pH	7.4	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	240	Specific Conductance	3100	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	240	pH	7.4	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	340	Specific Conductance	3300	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	340	pH	7.5	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	440	Specific Conductance	3200	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	440	pH	7.2	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	540	Specific Conductance	3200	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	540	pH	7.3	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	640	Specific Conductance	3200	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	640	pH	7.5	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	740	Specific Conductance	3200	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	740	pH	7.4	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	840	Specific Conductance	3000	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	840	pH	7.3	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	940	Specific Conductance	2900	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	940	pH	7.3	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	1040	Specific Conductance	2900	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	1040	pH	7.4	pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	1140	Specific Conductance	3200	umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	1140	pH	7.3	pH
22-JAN-03	WEDNESDAY	COMP_CONDUCT	1230	Specific Conductance	3100	umhos/cm
22-JAN-03	WEDNESDAY	COMP_PH	1230	pH	7.3	pH
22-JAN-03	WEDNESDAY	GRAB	1240	Specific Conductance	3000	umhos/cm
22-JAN-03	WEDNESDAY	GRAB	1240	pH	7.4	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1120	Specific Conductance	2600	umhos/cm

City of Mexicali
Site 4

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
29-JAN-03	WEDNESDAY	1_Hr_COMP	1120	pH	7.4	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1220	Specific Conductance	2600	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1220	pH	7.4	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1320	Specific Conductance	3100	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1320	pH	7.4	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1420	Specific Conductance	3600	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1420	pH	7.3	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1520	Specific Conductance	2800	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1520	pH	7.4	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1620	Specific Conductance	2800	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1620	pH	7.5	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1720	Specific Conductance	2900	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1720	pH	7.5	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1820	Specific Conductance	2800	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1820	pH	7	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1920	Specific Conductance	2800	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1920	pH	7.2	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2020	Specific Conductance	2800	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2020	pH	7.4	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2120	Specific Conductance	2800	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2120	pH	7.4	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2220	Specific Conductance	2900	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2220	pH	7.4	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2320	Specific Conductance	2800	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2320	pH	7.4	pH
30-JAN-03	THURSDAY	1_Hr_COMP	20	Specific Conductance	2800	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	20	pH	7.3	pH
30-JAN-03	THURSDAY	1_Hr_COMP	120	Specific Conductance	2700	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	120	pH	7.3	pH
30-JAN-03	THURSDAY	1_Hr_COMP	220	Specific Conductance	2700	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	220	pH	7.2	pH
30-JAN-03	THURSDAY	1_Hr_COMP	320	Specific Conductance	2800	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	320	pH	7.4	pH
30-JAN-03	THURSDAY	1_Hr_COMP	420	Specific Conductance	2800	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	420	pH	7.3	pH
30-JAN-03	THURSDAY	1_Hr_COMP	520	Specific Conductance	3000	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	520	pH	7.3	pH
30-JAN-03	THURSDAY	1_Hr_COMP	620	Specific Conductance	3100	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	620	pH	7.1	pH
30-JAN-03	THURSDAY	1_Hr_COMP	720	Specific Conductance	3300	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	720	pH	7.2	pH
30-JAN-03	THURSDAY	1_Hr_COMP	820	Specific Conductance	3500	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	820	pH	7.3	pH
30-JAN-03	THURSDAY	1_Hr_COMP	920	Specific Conductance	4800	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	920	pH	7.2	pH
30-JAN-03	THURSDAY	1_Hr_COMP	1020	Specific Conductance	2800	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	1020	pH	7.5	pH
30-JAN-03	THURSDAY	COMP_CONDUCT	1100	Specific Conductance	2900	umhos/cm
30-JAN-03	THURSDAY	COMP_PH	1100	pH	7.3	pH
30-JAN-03	THURSDAY	GRAB	1110	Specific Conductance	2700	umhos/cm
30-JAN-03	THURSDAY	GRAB	1110	pH	7.4	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1045	Specific Conductance	2700	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1045	pH	7.8	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1145	Specific Conductance	2600	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1145	pH	7.7	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1245	Specific Conductance	3400	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1245	pH	7.7	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1345	Specific Conductance	3300	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1345	pH	7.7	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1445	Specific Conductance	3000	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1445	pH	7.7	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1545	Specific Conductance	2800	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1545	pH	7.5	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1645	Specific Conductance	2700	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1645	pH	7.5	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1745	Specific Conductance	2700	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1745	pH	7.4	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1845	Specific Conductance	3000	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1845	pH	7.5	pH
06-FEB-03	THURSDAY	1_Hr_COMP	1945	Specific Conductance	2900	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1945	pH	7.5	pH
06-FEB-03	THURSDAY	1_Hr_COMP	2045	Specific Conductance	2900	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	2045	pH	7.5	pH

City of Mexicali
Site 4

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
06-FEB-03	THURSDAY	1_Hr_COMP	2145	Specific Conductance	2900	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	2145	pH	7.5	pH
06-FEB-03	THURSDAY	1_Hr_COMP	2245	Specific Conductance	2900	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	2245	pH	7.5	pH
06-FEB-03	THURSDAY	1_Hr_COMP	2345	Specific Conductance	2700	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	2345	pH	7.6	pH
07-FEB-03	FRIDAY	1_Hr_COMP	45	Specific Conductance	2700	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	45	pH	7.6	pH
07-FEB-03	FRIDAY	1_Hr_COMP	145	Specific Conductance	2800	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	145	pH	7.6	pH
07-FEB-03	FRIDAY	1_Hr_COMP	245	Specific Conductance	2700	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	245	pH	7.6	pH
07-FEB-03	FRIDAY	1_Hr_COMP	345	Specific Conductance	2800	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	345	pH	7.6	pH
07-FEB-03	FRIDAY	1_Hr_COMP	445	Specific Conductance	2900	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	445	pH	7.6	pH
07-FEB-03	FRIDAY	1_Hr_COMP	545	Specific Conductance	2700	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	545	pH	7.5	pH
07-FEB-03	FRIDAY	1_Hr_COMP	645	Specific Conductance	2800	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	645	pH	7.6	pH
07-FEB-03	FRIDAY	1_Hr_COMP	745	Specific Conductance	2900	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	745	pH	7.5	pH
07-FEB-03	FRIDAY	1_Hr_COMP	845	Specific Conductance	3100	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	845	pH	7.5	pH
07-FEB-03	FRIDAY	1_Hr_COMP	945	Specific Conductance	2900	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	945	pH	7.6	pH
07-FEB-03	FRIDAY	COMP_CONDUCT	1340	Specific Conductance	2700	umhos/cm
07-FEB-03	FRIDAY	COMP_PH	1340	pH	7.3	pH
07-FEB-03	FRIDAY	GRAB	1350	Specific Conductance	3300	umhos/cm
07-FEB-03	FRIDAY	GRAB	1350	pH	7.6	pH
22-FEB-03	SATURDAY	1_Hr_COMP	930	Specific Conductance	2500	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	930	pH	7.4	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1030	Specific Conductance	2300	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1030	pH	7.4	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1130	Specific Conductance	2100	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1130	pH	7.4	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1230	Specific Conductance	2000	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1230	pH	7.3	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1330	Specific Conductance	2100	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1330	pH	7.3	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1430	Specific Conductance	2200	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1430	pH	7.4	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1530	Specific Conductance	2400	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1530	pH	7.3	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1630	Specific Conductance	2300	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1630	pH	7.2	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1730	Specific Conductance	2400	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1730	pH	7.2	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1830	Specific Conductance	2600	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1830	pH	7.2	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1930	Specific Conductance	2400	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1930	pH	7.2	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2030	Specific Conductance	2600	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2030	pH	7.2	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2130	Specific Conductance	2400	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2130	pH	7.2	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2230	Specific Conductance	2400	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2230	pH	7.1	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2330	Specific Conductance	2200	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2330	pH	7.1	pH
23-FEB-03	SUNDAY	1_Hr_COMP	30	Specific Conductance	2200	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	30	pH	7.2	pH
23-FEB-03	SUNDAY	1_Hr_COMP	130	Specific Conductance	2300	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	130	pH	7.2	pH
23-FEB-03	SUNDAY	1_Hr_COMP	230	Specific Conductance	2200	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	230	pH	7.2	pH
23-FEB-03	SUNDAY	1_Hr_COMP	330	Specific Conductance	2100	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	330	pH	7.2	pH
23-FEB-03	SUNDAY	1_Hr_COMP	430	Specific Conductance	2400	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	430	pH	7.1	pH
23-FEB-03	SUNDAY	1_Hr_COMP	530	Specific Conductance	2400	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	530	pH	7.2	pH
23-FEB-03	SUNDAY	1_Hr_COMP	630	Specific Conductance	2400	umhos/cm

City of Mexicali
Site 4

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
23-FEB-03	SUNDAY	1_Hr_COMP	630 pH	7.3 pH
23-FEB-03	SUNDAY	1_Hr_COMP	730 Specific Conductance	2500 umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	730 pH	7.4 pH
23-FEB-03	SUNDAY	1_Hr_COMP	830 Specific Conductance	2300 umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	830 pH	7.4 pH
23-FEB-03	SUNDAY	COMP_CONDUCT	1230 Specific Conductance	2400 umhos/cm
23-FEB-03	SUNDAY	COMP_PH	1230 pH	7.3 pH
23-FEB-03	SUNDAY	GRAB	1240 Specific Conductance	2500 umhos/cm
23-FEB-03	SUNDAY	GRAB	1240 pH	7.1 pH
02-MAR-03	SUNDAY	1_Hr_COMP	845 Specific Conductance	2300 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	845 pH	6.8 pH
02-MAR-03	SUNDAY	1_Hr_COMP	945 Specific Conductance	2000 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	945 pH	6.9 pH
02-MAR-03	SUNDAY	1_Hr_COMP	1045 Specific Conductance	2100 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1045 pH	6.7 pH
02-MAR-03	SUNDAY	1_Hr_COMP	1145 Specific Conductance	1900 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1145 pH	6.9 pH
02-MAR-03	SUNDAY	1_Hr_COMP	1245 Specific Conductance	1900 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1245 pH	7 pH
02-MAR-03	SUNDAY	1_Hr_COMP	1345 Specific Conductance	1900 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1345 pH	7.1 pH
02-MAR-03	SUNDAY	1_Hr_COMP	1445 Specific Conductance	2000 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1445 pH	7.2 pH
02-MAR-03	SUNDAY	1_Hr_COMP	1545 Specific Conductance	2000 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1545 pH	7 pH
02-MAR-03	SUNDAY	1_Hr_COMP	1645 Specific Conductance	2000 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1645 pH	7 pH
02-MAR-03	SUNDAY	1_Hr_COMP	1745 Specific Conductance	1900 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1745 pH	7 pH
02-MAR-03	SUNDAY	1_Hr_COMP	1845 Specific Conductance	2300 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1845 pH	7.1 pH
02-MAR-03	SUNDAY	1_Hr_COMP	1945 Specific Conductance	1900 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1945 pH	7.1 pH
02-MAR-03	SUNDAY	1_Hr_COMP	2045 Specific Conductance	1900 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2045 pH	7.1 pH
02-MAR-03	SUNDAY	1_Hr_COMP	2145 Specific Conductance	1900 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2145 pH	7.1 pH
02-MAR-03	SUNDAY	1_Hr_COMP	2245 Specific Conductance	1900 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2245 pH	7.1 pH
02-MAR-03	SUNDAY	1_Hr_COMP	2345 Specific Conductance	1800 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2345 pH	7.1 pH
03-MAR-03	MONDAY	1_Hr_COMP	45 Specific Conductance	1800 umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	45 pH	7.1 pH
03-MAR-03	MONDAY	1_Hr_COMP	145 Specific Conductance	1800 umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	145 pH	7.2 pH
03-MAR-03	MONDAY	1_Hr_COMP	245 Specific Conductance	1900 umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	245 pH	7 pH
03-MAR-03	MONDAY	1_Hr_COMP	345 Specific Conductance	1900 umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	345 pH	7 pH
03-MAR-03	MONDAY	1_Hr_COMP	445 Specific Conductance	1900 umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	445 pH	7.2 pH
03-MAR-03	MONDAY	1_Hr_COMP	545 Specific Conductance	1900 umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	545 pH	7.2 pH
03-MAR-03	MONDAY	COMP_CONDUCT	934 Specific Conductance	2900 umhos/cm
03-MAR-03	MONDAY	COMP_PH	934 pH	7.3 pH
03-MAR-03	MONDAY	GRAB	940 Specific Conductance	2500 umhos/cm
03-MAR-03	MONDAY	GRAB	940 pH	7.3 pH
28-MAR-03	FRIDAY	1_Hr_COMP	946 Specific Conductance	2700 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1046 Specific Conductance	2400 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1146 Specific Conductance	2500 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1246 Specific Conductance	2700 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1346 Specific Conductance	3600 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1446 Specific Conductance	3900 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1546 Specific Conductance	3200 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1646 Specific Conductance	3100 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1746 Specific Conductance	3300 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1846 Specific Conductance	3000 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1946 Specific Conductance	2700 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2046 Specific Conductance	2900 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2146 Specific Conductance	3000 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2246 Specific Conductance	2700 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2346 Specific Conductance	2700 umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	46 Specific Conductance	2900 umhos/cm

City of Mexicali
Site 4

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
29-MAR-03	SATURDAY	1_Hr_COMP	146	Specific Conductance	3100	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	246	Specific Conductance	3500	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	346	Specific Conductance	3100	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	446	Specific Conductance	3400	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	546	Specific Conductance	3300	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	646	Specific Conductance	3400	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	746	Specific Conductance	3300	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	846	Specific Conductance	3100	umhos/cm
29-MAR-03	SATURDAY	COMP_CONDUCT	935	Specific Conductance	2900	umhos/cm
29-MAR-03	SATURDAY	GRAB	940	Specific Conductance	3700	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	833	Specific Conductance	3100	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	833	pH	7.6	pH
05-APR-03	SATURDAY	1_Hr_COMP	933	Specific Conductance	2800	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	933	pH	7.1	pH
05-APR-03	SATURDAY	1_Hr_COMP	1033	Specific Conductance	2800	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1033	pH	7.6	pH
05-APR-03	SATURDAY	1_Hr_COMP	1133	Specific Conductance	2400	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1133	pH	7.2	pH
05-APR-03	SATURDAY	1_Hr_COMP	1233	Specific Conductance	2500	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1233	pH	7.6	pH
05-APR-03	SATURDAY	1_Hr_COMP	1333	Specific Conductance	3200	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1333	pH	7.6	pH
05-APR-03	SATURDAY	1_Hr_COMP	1433	Specific Conductance	2600	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1433	pH	7.6	pH
05-APR-03	SATURDAY	1_Hr_COMP	1533	Specific Conductance	2500	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1533	pH	7.2	pH
05-APR-03	SATURDAY	1_Hr_COMP	1633	Specific Conductance	2490	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1633	pH	7.2	pH
05-APR-03	SATURDAY	1_Hr_COMP	1733	Specific Conductance	2600	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1733	pH	7.3	pH
05-APR-03	SATURDAY	1_Hr_COMP	1833	Specific Conductance	2400	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1833	pH	7.3	pH
05-APR-03	SATURDAY	1_Hr_COMP	1933	Specific Conductance	2500	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1933	pH	7.4	pH
05-APR-03	SATURDAY	1_Hr_COMP	2033	Specific Conductance	2500	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	2033	pH	7.5	pH
05-APR-03	SATURDAY	1_Hr_COMP	2133	Specific Conductance	2400	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	2133	pH	7.5	pH
05-APR-03	SATURDAY	1_Hr_COMP	2233	Specific Conductance	2600	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	2233	pH	7.5	pH
05-APR-03	SATURDAY	1_Hr_COMP	2333	Specific Conductance	3200	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	2333	pH	7.5	pH
06-APR-03	SUNDAY	1_Hr_COMP	33	Specific Conductance	2400	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	33	pH	7.5	pH
06-APR-03	SUNDAY	1_Hr_COMP	133	Specific Conductance	2300	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	133	pH	7.5	pH
06-APR-03	SUNDAY	1_Hr_COMP	233	Specific Conductance	2300	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	233	pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP	333	Specific Conductance	2300	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	333	pH	7.7	pH
06-APR-03	SUNDAY	1_Hr_COMP	433	Specific Conductance	2300	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	433	pH	7.6	pH
06-APR-03	SUNDAY	1_Hr_COMP	533	Specific Conductance	2500	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	533	pH	7.3	pH
06-APR-03	SUNDAY	1_Hr_COMP	633	Specific Conductance	2300	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	633	pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP	733	Specific Conductance	2300	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	733	pH	7.5	pH
06-APR-03	SUNDAY	COMP_CONDUCT	1008	Specific Conductance	2500	umhos/cm
06-APR-03	SUNDAY	COMP_PH	1008	pH	7.6	pH
06-APR-03	SUNDAY	GRAB	1018	Specific Conductance	2700	umhos/cm
06-APR-03	SUNDAY	GRAB	1018	pH	7	pH
14-APR-03	MONDAY	1_Hr_COMP	850	Specific Conductance	2400	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	850	pH	7.6	pH
14-APR-03	MONDAY	1_Hr_COMP	950	Specific Conductance	2200	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	950	pH	7.8	pH
14-APR-03	MONDAY	1_Hr_COMP	1050	Specific Conductance	2000	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1050	pH	7.7	pH
14-APR-03	MONDAY	1_Hr_COMP	1150	Specific Conductance	2100	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1150	pH	7.6	pH
14-APR-03	MONDAY	1_Hr_COMP	1250	Specific Conductance	2400	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1250	pH	7.5	pH
14-APR-03	MONDAY	1_Hr_COMP	1350	Specific Conductance	2600	umhos/cm

City of Mexicali
Site 4

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
14-APR-03	MONDAY	1_Hr_COMP	1350	pH	7.4	pH
14-APR-03	MONDAY	1_Hr_COMP	1450	Specific Conductance	2900	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1450	pH	7.4	pH
14-APR-03	MONDAY	1_Hr_COMP	1550	Specific Conductance	2800	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1550	pH	7.3	pH
14-APR-03	MONDAY	1_Hr_COMP	1650	Specific Conductance	2900	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1650	pH	7.1	pH
14-APR-03	MONDAY	1_Hr_COMP	1750	Specific Conductance	2900	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1750	pH	7.3	pH
14-APR-03	MONDAY	1_Hr_COMP	1850	Specific Conductance	2800	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1850	pH	7.2	pH
14-APR-03	MONDAY	1_Hr_COMP	1950	Specific Conductance	2600	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1950	pH	7.3	pH
14-APR-03	MONDAY	1_Hr_COMP	2050	Specific Conductance	2600	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2050	pH	7.5	pH
14-APR-03	MONDAY	1_Hr_COMP	2150	Specific Conductance	2700	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2150	pH	7.5	pH
14-APR-03	MONDAY	1_Hr_COMP	2250	Specific Conductance	2700	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2250	pH	7.5	pH
14-APR-03	MONDAY	1_Hr_COMP	2350	Specific Conductance	2500	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2350	pH	7.4	pH
15-APR-03	TUESDAY	1_Hr_COMP	50	Specific Conductance	2400	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	50	pH	7.4	pH
15-APR-03	TUESDAY	1_Hr_COMP	150	Specific Conductance	2400	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	150	pH	7.4	pH
15-APR-03	TUESDAY	1_Hr_COMP	250	Specific Conductance	2300	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	250	pH	7.5	pH
15-APR-03	TUESDAY	1_Hr_COMP	350	Specific Conductance	2400	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	350	pH	7.5	pH
15-APR-03	TUESDAY	1_Hr_COMP	450	Specific Conductance	2300	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	450	pH	7.4	pH
15-APR-03	TUESDAY	1_Hr_COMP	550	Specific Conductance	2500	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	550	pH	7.4	pH
15-APR-03	TUESDAY	1_Hr_COMP	650	Specific Conductance	2700	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	650	pH	7.5	pH
15-APR-03	TUESDAY	1_Hr_COMP	750	Specific Conductance	2700	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	750	pH	7.5	pH
15-APR-03	TUESDAY	COMP_CONDUCT	915	Specific Conductance	2600	umhos/cm
15-APR-03	TUESDAY	COMP_PH	915	pH	7.4	pH
15-APR-03	TUESDAY	GRAB	920	Specific Conductance	2500	umhos/cm
15-APR-03	TUESDAY	GRAB	920	pH	7.2	pH
22-APR-03	TUESDAY	1_Hr_COMP	928	Specific Conductance	2900	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	928	pH	7.8	pH
22-APR-03	TUESDAY	1_Hr_COMP	1028	Specific Conductance	2800	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1028	pH	7.8	pH
22-APR-03	TUESDAY	1_Hr_COMP	1128	Specific Conductance	2600	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1128	pH	7.8	pH
22-APR-03	TUESDAY	1_Hr_COMP	1228	Specific Conductance	2600	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1228	pH	7.9	pH
22-APR-03	TUESDAY	1_Hr_COMP	1328	Specific Conductance	2800	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1328	pH	7.8	pH
22-APR-03	TUESDAY	1_Hr_COMP	1428	Specific Conductance	3600	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1428	pH	7.7	pH
22-APR-03	TUESDAY	1_Hr_COMP	1528	Specific Conductance	3300	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1528	pH	9.5	pH
22-APR-03	TUESDAY	1_Hr_COMP	1628	Specific Conductance	3300	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1628	pH	9.7	pH
22-APR-03	TUESDAY	1_Hr_COMP	1728	Specific Conductance	3300	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1728	pH	9.3	pH
22-APR-03	TUESDAY	1_Hr_COMP	1828	Specific Conductance	3500	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1828	pH	8.6	pH
22-APR-03	TUESDAY	1_Hr_COMP	1928	Specific Conductance	3300	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1928	pH	8.1	pH
22-APR-03	TUESDAY	1_Hr_COMP	2028	Specific Conductance	3300	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2028	pH	8	pH
22-APR-03	TUESDAY	1_Hr_COMP	2128	Specific Conductance	2800	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2128	pH	8	pH
22-APR-03	TUESDAY	1_Hr_COMP	2228	Specific Conductance	2800	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2228	pH	8	pH
22-APR-03	TUESDAY	1_Hr_COMP	2328	Specific Conductance	2800	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2328	pH	7.9	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	28	Specific Conductance	3000	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	28	pH	7.9	pH

City of Mexicali
Site 4

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
23-APR-03	WEDNESDAY	1_Hr_COMP	128 Specific Conductance	3300 umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	128 pH	8.2 pH
23-APR-03	WEDNESDAY	1_Hr_COMP	228 Specific Conductance	2100 umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	228 pH	8 pH
23-APR-03	WEDNESDAY	1_Hr_COMP	328 Specific Conductance	3200 umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	328 pH	8 pH
23-APR-03	WEDNESDAY	1_Hr_COMP	428 Specific Conductance	2700 umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	428 pH	8 pH
23-APR-03	WEDNESDAY	1_Hr_COMP	528 Specific Conductance	2700 umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	528 pH	7.9 pH
23-APR-03	WEDNESDAY	1_Hr_COMP	628 Specific Conductance	3100 umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	628 pH	7.9 pH
23-APR-03	WEDNESDAY	1_Hr_COMP	728 Specific Conductance	3200 umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	728 pH	7.8 pH
23-APR-03	WEDNESDAY	1_Hr_COMP	828 Specific Conductance	3100 umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	828 pH	7.8 pH
23-APR-03	WEDNESDAY	COMP_CONDUCT	1016 Specific Conductance	2900 umhos/cm
23-APR-03	WEDNESDAY	COMP_PH	1016 pH	8.6 pH
23-APR-03	WEDNESDAY	GRAB	1022 Specific Conductance	2700 umhos/cm
23-APR-03	WEDNESDAY	GRAB	1022 pH	7.3 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	950 Specific Conductance	2600 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	950 pH	8.2 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1050 Specific Conductance	2300 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1050 pH	8.1 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1150 Specific Conductance	2300 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1150 pH	8.1 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1250 Specific Conductance	2500 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1250 pH	8.1 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1350 Specific Conductance	3600 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1350 pH	8 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1450 Specific Conductance	2900 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1450 pH	8 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1550 Specific Conductance	2700 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1550 pH	7.8 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1650 Specific Conductance	2700 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1650 pH	7.7 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1750 Specific Conductance	2700 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1750 pH	7.7 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1850 Specific Conductance	2700 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1850 pH	7.7 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1950 Specific Conductance	2400 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1950 pH	7.7 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	2050 Specific Conductance	2800 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	2050 pH	7.7 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	2150 Specific Conductance	3700 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	2150 pH	7.8 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	2250 Specific Conductance	2700 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	2250 pH	7.8 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	2350 Specific Conductance	2800 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	2350 pH	7.9 pH
01-MAY-03	THURSDAY	1_Hr_COMP	50 Specific Conductance	2600 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	50 pH	7.8 pH
01-MAY-03	THURSDAY	1_Hr_COMP	150 Specific Conductance	3000 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	150 pH	7.9 pH
01-MAY-03	THURSDAY	1_Hr_COMP	250 Specific Conductance	2900 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	250 pH	7.9 pH
01-MAY-03	THURSDAY	1_Hr_COMP	350 Specific Conductance	2700 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	350 pH	7.9 pH
01-MAY-03	THURSDAY	1_Hr_COMP	450 Specific Conductance	2700 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	450 pH	7.9 pH
01-MAY-03	THURSDAY	1_Hr_COMP	550 Specific Conductance	3100 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	550 pH	7.9 pH
01-MAY-03	THURSDAY	1_Hr_COMP	650 Specific Conductance	3100 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	650 pH	7.9 pH
01-MAY-03	THURSDAY	1_Hr_COMP	750 Specific Conductance	2800 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	750 pH	7.8 pH
01-MAY-03	THURSDAY	1_Hr_COMP	850 Specific Conductance	3100 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	850 pH	7.7 pH
01-MAY-03	THURSDAY	COMP_CONDUCT	920 Specific Conductance	2700 umhos/cm
01-MAY-03	THURSDAY	COMP_PH	920 pH	7.8 pH
01-MAY-03	THURSDAY	GRAB	930 Specific Conductance	3500 umhos/cm
01-MAY-03	THURSDAY	GRAB	930 pH	7.6 pH
08-MAY-03	THURSDAY	1_Hr_COMP	845 Specific Conductance	2300 umhos/cm

City of Mexicali
Site 4

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
08-MAY-03	THURSDAY	1_Hr_COMP	845 pH	6.9 pH
08-MAY-03	THURSDAY	1_Hr_COMP	945 Specific Conductance	2600 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	945 pH	7.4 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1045 Specific Conductance	3300 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1045 pH	7.3 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1145 Specific Conductance	3000 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1145 pH	7.3 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1245 Specific Conductance	2300 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1245 pH	7.4 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1345 Specific Conductance	2300 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1345 pH	7.4 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1445 Specific Conductance	2800 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1445 pH	7.4 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1545 Specific Conductance	2500 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1545 pH	7.4 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1645 Specific Conductance	2600 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1645 pH	7.4 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1745 Specific Conductance	2700 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1745 pH	7.4 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1845 Specific Conductance	2600 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1845 pH	7.5 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1945 Specific Conductance	2700 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1945 pH	7.5 pH
08-MAY-03	THURSDAY	1_Hr_COMP	2045 Specific Conductance	2900 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	2045 pH	7.5 pH
08-MAY-03	THURSDAY	1_Hr_COMP	2145 Specific Conductance	2700 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	2145 pH	7.5 pH
08-MAY-03	THURSDAY	1_Hr_COMP	2245 Specific Conductance	2500 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	2245 pH	7.5 pH
08-MAY-03	THURSDAY	1_Hr_COMP	2345 Specific Conductance	2600 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	2345 pH	7.4 pH
09-MAY-03	FRIDAY	1_Hr_COMP	145 Specific Conductance	2500 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	145 pH	7.4 pH
09-MAY-03	FRIDAY	1_Hr_COMP	245 Specific Conductance	2400 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	245 pH	7.4 pH
09-MAY-03	FRIDAY	1_Hr_COMP	345 Specific Conductance	2800 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	345 pH	7.5 pH
09-MAY-03	FRIDAY	1_Hr_COMP	445 Specific Conductance	2600 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	445 pH	7.5 pH
09-MAY-03	FRIDAY	1_Hr_COMP	545 Specific Conductance	2900 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	545 pH	7.4 pH
09-MAY-03	FRIDAY	1_Hr_COMP	645 Specific Conductance	2700 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	645 pH	7.3 pH
09-MAY-03	FRIDAY	COMP_CONDUCT	900 Specific Conductance	2700 umhos/cm
09-MAY-03	FRIDAY	COMP_PH	900 pH	7.5 pH
09-MAY-03	FRIDAY	GRAB	910 Specific Conductance	2700 umhos/cm
09-MAY-03	FRIDAY	GRAB	910 pH	7 pH
16-MAY-03	FRIDAY	1_Hr_COMP	845 Specific Conductance	3000 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	845 pH	7.1 pH
16-MAY-03	FRIDAY	1_Hr_COMP	945 Specific Conductance	2700 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	945 pH	7.3 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1045 Specific Conductance	2500 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1045 pH	7.3 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1145 Specific Conductance	2600 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1145 pH	7.6 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1245 Specific Conductance	3100 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1245 pH	7.6 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1345 Specific Conductance	3500 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1345 pH	7.7 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1445 Specific Conductance	2800 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1445 pH	7.7 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1545 Specific Conductance	2800 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1545 pH	7.7 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1645 Specific Conductance	3000 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1645 pH	7.7 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1745 Specific Conductance	2700 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1745 pH	7.7 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1845 Specific Conductance	2600 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1845 pH	7.8 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1945 Specific Conductance	2700 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1945 pH	7.8 pH
16-MAY-03	FRIDAY	1_Hr_COMP	2045 Specific Conductance	3100 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2045 pH	7.8 pH

City of Mexicali
Site 4

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
16-MAY-03	FRIDAY	1_Hr_COMP	2145 Specific Conductance	3500 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2145 pH	7.8 pH
16-MAY-03	FRIDAY	1_Hr_COMP	2245 Specific Conductance	3000 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2245 pH	7.8 pH
16-MAY-03	FRIDAY	1_Hr_COMP	2345 Specific Conductance	2700 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2345 pH	7.9 pH
17-MAY-03	SATURDAY	1_Hr_COMP	45 Specific Conductance	2900 umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	45 pH	7.8 pH
17-MAY-03	SATURDAY	1_Hr_COMP	145 Specific Conductance	3100 umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	145 pH	7.8 pH
17-MAY-03	SATURDAY	1_Hr_COMP	245 Specific Conductance	3100 umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	245 pH	7.9 pH
17-MAY-03	SATURDAY	1_Hr_COMP	345 Specific Conductance	2900 umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	345 pH	7.9 pH
17-MAY-03	SATURDAY	1_Hr_COMP	445 Specific Conductance	2600 umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	445 pH	7.9 pH
17-MAY-03	SATURDAY	1_Hr_COMP	545 Specific Conductance	2800 umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	545 pH	7.9 pH
17-MAY-03	SATURDAY	1_Hr_COMP	645 Specific Conductance	2700 umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	645 pH	7.8 pH
17-MAY-03	SATURDAY	1_Hr_COMP	745 Specific Conductance	2800 umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	745 pH	7.7 pH
17-MAY-03	SATURDAY	COMP_CONDUCT	840 Specific Conductance	2900 umhos/cm
17-MAY-03	SATURDAY	COMP_PH	840 pH	7.1 pH
17-MAY-03	SATURDAY	GRAB	845 Specific Conductance	2700 umhos/cm
17-MAY-03	SATURDAY	GRAB	845 pH	6.9 pH
24-MAY-03	SATURDAY	1_Hr_COMP	835 Specific Conductance	2800 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	835 pH	7.5 pH
24-MAY-03	SATURDAY	1_Hr_COMP	935 Specific Conductance	3700 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	935 pH	7.9 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1035 Specific Conductance	2700 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1035 pH	8 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1135 Specific Conductance	2500 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1135 pH	8 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1235 Specific Conductance	2500 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1235 pH	8 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1335 Specific Conductance	3200 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1335 pH	7.8 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1435 Specific Conductance	2800 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1435 pH	7.8 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1535 Specific Conductance	2800 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1535 pH	7.6 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1635 Specific Conductance	2500 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1635 pH	7.7 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1735 Specific Conductance	2600 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1735 pH	7.7 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1835 Specific Conductance	2900 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1835 pH	7.7 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1935 Specific Conductance	2800 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1935 pH	7.8 pH
24-MAY-03	SATURDAY	1_Hr_COMP	2035 Specific Conductance	2500 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2035 pH	7.8 pH
24-MAY-03	SATURDAY	1_Hr_COMP	2135 Specific Conductance	2400 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2135 pH	7.8 pH
24-MAY-03	SATURDAY	1_Hr_COMP	2235 Specific Conductance	2400 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2235 pH	7.8 pH
24-MAY-03	SATURDAY	1_Hr_COMP	2335 Specific Conductance	2700 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2335 pH	7.7 pH
25-MAY-03	SUNDAY	1_Hr_COMP	35 Specific Conductance	2600 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	35 pH	7.8 pH
25-MAY-03	SUNDAY	1_Hr_COMP	135 Specific Conductance	2500 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	135 pH	7.8 pH
25-MAY-03	SUNDAY	1_Hr_COMP	235 Specific Conductance	2800 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	235 pH	7.7 pH
25-MAY-03	SUNDAY	1_Hr_COMP	335 Specific Conductance	2800 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	335 pH	7.7 pH
25-MAY-03	SUNDAY	1_Hr_COMP	435 Specific Conductance	2300 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	435 pH	7.7 pH
25-MAY-03	SUNDAY	1_Hr_COMP	535 Specific Conductance	2500 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	535 pH	7.7 pH
25-MAY-03	SUNDAY	1_Hr_COMP	635 Specific Conductance	2200 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	635 pH	7.7 pH
25-MAY-03	SUNDAY	1_Hr_COMP	735 Specific Conductance	2300 umhos/cm

City of Mexicali
Site 4

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
25-MAY-03	SUNDAY	1_Hr_COMP	735	pH	7.7	pH
25-MAY-03	SUNDAY	COMP_CONDUCT	850	Specific Conductance	2700	umhos/cm
25-MAY-03	SUNDAY	COMP_PH	850	pH	7.7	pH
25-MAY-03	SUNDAY	GRAB	900	Specific Conductance	2400	umhos/cm
25-MAY-03	SUNDAY	GRAB	900	pH	7.4	pH
01-JUN-03	SUNDAY	1_Hr_COMP	917	Specific Conductance	2600	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	917	pH	7.5	pH
01-JUN-03	SUNDAY	1_Hr_COMP	1017	Specific Conductance	2100	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1017	pH	7.9	pH
01-JUN-03	SUNDAY	1_Hr_COMP	1117	Specific Conductance	3000	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1117	pH	7.9	pH
01-JUN-03	SUNDAY	1_Hr_COMP	1217	Specific Conductance	2700	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1217	pH	8	pH
01-JUN-03	SUNDAY	1_Hr_COMP	1317	Specific Conductance	3100	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1317	pH	7.8	pH
01-JUN-03	SUNDAY	1_Hr_COMP	1417	Specific Conductance	2600	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1417	pH	7.8	pH
01-JUN-03	SUNDAY	1_Hr_COMP	1517	Specific Conductance	2600	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1517	pH	7.7	pH
01-JUN-03	SUNDAY	1_Hr_COMP	1617	Specific Conductance	2600	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1617	pH	7.7	pH
01-JUN-03	SUNDAY	1_Hr_COMP	1717	Specific Conductance	2600	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1717	pH	7.7	pH
01-JUN-03	SUNDAY	1_Hr_COMP	1817	Specific Conductance	2200	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1817	pH	7.8	pH
01-JUN-03	SUNDAY	1_Hr_COMP	1917	Specific Conductance	2200	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1917	pH	7.7	pH
01-JUN-03	SUNDAY	1_Hr_COMP	2017	Specific Conductance	2100	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2017	pH	7.7	pH
01-JUN-03	SUNDAY	1_Hr_COMP	2117	Specific Conductance	2100	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2117	pH	7.7	pH
01-JUN-03	SUNDAY	1_Hr_COMP	2217	Specific Conductance	2100	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2217	pH	7.7	pH
01-JUN-03	SUNDAY	2317	Specific Conductance	2200	umhos/cm	
01-JUN-03	SUNDAY	2317	pH	7.7	pH	
02-JUN-03	MONDAY	1_Hr_COMP	17	Specific Conductance	2200	umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	17	pH	7.7	pH
02-JUN-03	MONDAY	1_Hr_COMP	117	Specific Conductance	2200	umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	117	pH	7.7	pH
02-JUN-03	MONDAY	217	Specific Conductance	2300	umhos/cm	
02-JUN-03	MONDAY	217	pH	7.7	pH	
02-JUN-03	MONDAY	317	Specific Conductance	2300	umhos/cm	
02-JUN-03	MONDAY	317	pH	7.8	pH	
02-JUN-03	MONDAY	417	Specific Conductance	2400	umhos/cm	
02-JUN-03	MONDAY	417	pH	7.7	pH	
02-JUN-03	MONDAY	517	Specific Conductance	2200	umhos/cm	
02-JUN-03	MONDAY	517	pH	7.7	pH	
02-JUN-03	MONDAY	617	Specific Conductance	2200	umhos/cm	
02-JUN-03	MONDAY	617	pH	7.6	pH	
02-JUN-03	MONDAY	717	Specific Conductance	2700	umhos/cm	
02-JUN-03	MONDAY	717	pH	7.6	pH	
02-JUN-03	MONDAY	817	Specific Conductance	2300	umhos/cm	
02-JUN-03	MONDAY	817	pH	7.6	pH	
02-JUN-03	MONDAY	1015	Specific Conductance	2400	umhos/cm	
02-JUN-03	MONDAY	1015	pH	7.8	pH	
02-JUN-03	MONDAY	GRAB	1020	Specific Conductance	2800	umhos/cm
02-JUN-03	MONDAY	GRAB	1020	pH	7.1	pH
09-JUN-03	MONDAY	1_Hr_COMP	950	Specific Conductance	2200	umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	950	pH	7.6	pH
09-JUN-03	MONDAY	1_Hr_COMP	1050	Specific Conductance	2100	umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1050	pH	8	pH
09-JUN-03	MONDAY	1150	Specific Conductance	2300	umhos/cm	
09-JUN-03	MONDAY	1150	pH	8	pH	
09-JUN-03	MONDAY	1250	Specific Conductance	2400	umhos/cm	
09-JUN-03	MONDAY	1250	pH	7.9	pH	
09-JUN-03	MONDAY	1350	Specific Conductance	2600	umhos/cm	
09-JUN-03	MONDAY	1350	pH	7.9	pH	
09-JUN-03	MONDAY	1450	Specific Conductance	3100	umhos/cm	
09-JUN-03	MONDAY	1450	pH	7.9	pH	
09-JUN-03	MONDAY	1550	Specific Conductance	2900	umhos/cm	
09-JUN-03	MONDAY	1550	pH	7.9	pH	
09-JUN-03	MONDAY	1650	Specific Conductance	2900	umhos/cm	
09-JUN-03	MONDAY	1650	pH	7.9	pH	

City of Mexicali
Site 4

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
09-JUN-03	MONDAY	1_Hr_COMP	1750	Specific Conductance	2900	umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1750	pH	7.9	pH
09-JUN-03	MONDAY	1_Hr_COMP	1850	Specific Conductance	2900	umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1850	pH	7.8	pH
09-JUN-03	MONDAY	1_Hr_COMP	1950	Specific Conductance	3400	umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1950	pH	7.8	pH
09-JUN-03	MONDAY	1_Hr_COMP	2050	Specific Conductance	2900	umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	2050	pH	8	pH
10-JUN-03	TUESDAY	COMP_CONDUCT	955	Specific Conductance	2800	umhos/cm
10-JUN-03	TUESDAY	COMP_PH	955	pH	7.7	pH
10-JUN-03	TUESDAY	GRAB	1000	Specific Conductance	2800	umhos/cm
10-JUN-03	TUESDAY	GRAB	1000	pH	7.8	pH
17-JUN-03	TUESDAY	1_Hr_COMP	945	Specific Conductance	1900	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	945	pH	7.8	pH
17-JUN-03	TUESDAY	1_Hr_COMP	1045	Specific Conductance	1900	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1045	pH	7.9	pH
17-JUN-03	TUESDAY	1_Hr_COMP	1145	Specific Conductance	1900	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1145	pH	7.9	pH
17-JUN-03	TUESDAY	1_Hr_COMP	1245	Specific Conductance	2300	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1245	pH	7.9	pH
17-JUN-03	TUESDAY	1_Hr_COMP	1345	Specific Conductance	2600	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1345	pH	7.9	pH
17-JUN-03	TUESDAY	1_Hr_COMP	1445	Specific Conductance	2900	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1445	pH	7.8	pH
17-JUN-03	TUESDAY	1_Hr_COMP	1545	Specific Conductance	3000	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1545	pH	7.7	pH
17-JUN-03	TUESDAY	1_Hr_COMP	1645	Specific Conductance	2200	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1645	pH	7.8	pH
17-JUN-03	TUESDAY	1_Hr_COMP	1745	Specific Conductance	2400	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1745	pH	7.7	pH
17-JUN-03	TUESDAY	1_Hr_COMP	1845	Specific Conductance	2600	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1845	pH	7.8	pH
17-JUN-03	TUESDAY	1_Hr_COMP	1945	Specific Conductance	3700	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1945	pH	7.8	pH
17-JUN-03	TUESDAY	1_Hr_COMP	2045	Specific Conductance	2600	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	2045	pH	7.6	pH
17-JUN-03	TUESDAY	1_Hr_COMP	2145	Specific Conductance	3200	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	2145	pH	7.8	pH
17-JUN-03	TUESDAY	1_Hr_COMP	2245	Specific Conductance	3800	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	2245	pH	7.8	pH
17-JUN-03	TUESDAY	1_Hr_COMP	2345	Specific Conductance	2400	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	2345	pH	7.8	pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	45	Specific Conductance	2400	umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	45	pH	7.8	pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	145	Specific Conductance	2400	umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	145	pH	7.9	pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	245	Specific Conductance	2600	umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	245	pH	7.9	pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	345	Specific Conductance	2800	umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	345	pH	7.9	pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	445	Specific Conductance	3000	umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	445	pH	7.9	pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	545	Specific Conductance	2800	umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	545	pH	7.9	pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	645	Specific Conductance	3000	umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	645	pH	7.8	pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	745	Specific Conductance	3000	umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	745	pH	7.7	pH
18-JUN-03	WEDNESDAY	COMP_PH	810	pH	7.8	pH
18-JUN-03	WEDNESDAY	COMP_CONDUCT	820	Specific Conductance	2900	umhos/cm
18-JUN-03	WEDNESDAY	GRAB	825	Specific Conductance	4000	umhos/cm
18-JUN-03	WEDNESDAY	GRAB	825	pH	7.2	pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	845	Specific Conductance	3800	umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	845	pH	7.7	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	850	Specific Conductance	3400	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	850	pH	7.7	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	950	Specific Conductance	3400	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	950	pH	7.1	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1050	Specific Conductance	3600	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1050	pH	8.2	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1150	Specific Conductance	3800	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1150	pH	8.2	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1250	Specific Conductance	2500	umhos/cm

City of Mexicali
Site 4

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
25-JUN-03	WEDNESDAY	1_Hr_COMP	1250	pH	8.2	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1350	Specific Conductance	2800	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1350	pH	8.1	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1450	Specific Conductance	3000	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1450	pH	8.8	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1550	Specific Conductance	2800	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1550	pH	8.1	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1650	Specific Conductance	3600	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1650	pH	8.1	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1750	Specific Conductance	2900	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1750	pH	8	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1850	Specific Conductance	2800	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1850	pH	8	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1950	Specific Conductance	2800	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1950	pH	8	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	2050	Specific Conductance	2700	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	2050	pH	8.1	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	2150	Specific Conductance	3500	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	2150	pH	8	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	2250	Specific Conductance	3300	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	2250	pH	8	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	2350	Specific Conductance	2800	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	2350	pH	8	pH
26-JUN-03	THURSDAY	1_Hr_COMP	50	Specific Conductance	2700	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	50	pH	8	pH
26-JUN-03	THURSDAY	1_Hr_COMP	150	Specific Conductance	2600	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	150	pH	8	pH
26-JUN-03	THURSDAY	1_Hr_COMP	250	Specific Conductance	2600	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	250	pH	8	pH
26-JUN-03	THURSDAY	1_Hr_COMP	350	Specific Conductance	2700	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	350	pH	8	pH
26-JUN-03	THURSDAY	1_Hr_COMP	450	Specific Conductance	2700	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	450	pH	8	pH
26-JUN-03	THURSDAY	1_Hr_COMP	550	Specific Conductance	4000	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	550	pH	7.9	pH
26-JUN-03	THURSDAY	1_Hr_COMP	650	Specific Conductance	3500	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	650	pH	8	pH
26-JUN-03	THURSDAY	1_Hr_COMP	750	Specific Conductance	2700	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	750	pH	8	pH
26-JUN-03	THURSDAY	COMP_CONDUCT	850	Specific Conductance	2900	umhos/cm
26-JUN-03	THURSDAY	COMP_PH	850	pH	7.5	pH
26-JUN-03	THURSDAY	GRAB	900	Specific Conductance	3400	umhos/cm
26-JUN-03	THURSDAY	GRAB	900	pH	7.6	pH
03-JUL-03	THURSDAY	1_Hr_COMP	830	Specific Conductance	2400	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	830	pH	7.7	pH
03-JUL-03	THURSDAY	1_Hr_COMP	930	Specific Conductance	2900	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	930	pH	8.3	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1030	Specific Conductance	2700	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1030	pH	8.3	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1130	Specific Conductance	3000	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1130	pH	8.4	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1230	Specific Conductance	2400	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1230	pH	8.4	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1330	Specific Conductance	2800	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1330	pH	8.2	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1430	Specific Conductance	3300	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1430	pH	8	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1530	Specific Conductance	3000	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1530	pH	8	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1630	Specific Conductance	3500	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1630	pH	8	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1730	Specific Conductance	3700	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1730	pH	8	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1830	Specific Conductance	2700	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1830	pH	8	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1930	Specific Conductance	3000	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1930	pH	7.9	pH
03-JUL-03	THURSDAY	1_Hr_COMP	2030	Specific Conductance	3000	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	2030	pH	8	pH
03-JUL-03	THURSDAY	1_Hr_COMP	2130	Specific Conductance	3200	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	2130	pH	7.9	pH
03-JUL-03	THURSDAY	1_Hr_COMP	2230	Specific Conductance	2900	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	2230	pH	7.9	pH

City of Mexicali
Site 4

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
03-JUL-03	THURSDAY	1_Hr_COMP	2330	Specific Conductance	2900	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	2330	pH	8	pH
04-JUL-03	FRIDAY	1_Hr_COMP	30	Specific Conductance	3000	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	30	pH	8	pH
04-JUL-03	FRIDAY	1_Hr_COMP	130	Specific Conductance	2800	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	130	pH	8	pH
04-JUL-03	FRIDAY	1_Hr_COMP	230	Specific Conductance	2500	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	230	pH	7.9	pH
04-JUL-03	FRIDAY	1_Hr_COMP	330	Specific Conductance	2500	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	330	pH	7.7	pH
04-JUL-03	FRIDAY	1_Hr_COMP	430	Specific Conductance	2800	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	430	pH	7.6	pH
04-JUL-03	FRIDAY	1_Hr_COMP	530	Specific Conductance	2900	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	530	pH	7.7	pH
04-JUL-03	FRIDAY	1_Hr_COMP	630	Specific Conductance	2700	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	630	pH	7.7	pH
04-JUL-03	FRIDAY	1_Hr_COMP	730	Specific Conductance	3100	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	730	pH	7.8	pH
04-JUL-03	FRIDAY	COMP_CONDUCT	910	Specific Conductance	2900	umhos/cm
04-JUL-03	FRIDAY	COMP_PH	910	pH	7.7	pH
04-JUL-03	FRIDAY	GRAB	915	Specific Conductance	2500	umhos/cm
04-JUL-03	FRIDAY	GRAB	915	pH	7.2	pH
11-JUL-03	FRIDAY	1_Hr_COMP	900	Specific Conductance	2900	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	900	pH	9	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1000	Specific Conductance	2900	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1000	pH	9.4	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1100	Specific Conductance	4000	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1100	pH	9.4	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1200	Specific Conductance	2500	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1200	pH	9.3	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1300	Specific Conductance	3000	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1300	pH	9.3	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1400	Specific Conductance	3800	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1400	pH	9.3	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1500	Specific Conductance	3500	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1500	pH	9.3	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1600	Specific Conductance	3100	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1600	pH	9.2	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1700	Specific Conductance	3400	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1700	pH	9.3	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1800	Specific Conductance	4000	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1800	pH	9.3	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1900	Specific Conductance	3800	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1900	pH	9.4	pH
11-JUL-03	FRIDAY	1_Hr_COMP	2000	Specific Conductance	4200	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	2000	pH	9.4	pH
11-JUL-03	FRIDAY	1_Hr_COMP	2100	Specific Conductance	4500	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	2100	pH	9.3	pH
11-JUL-03	FRIDAY	1_Hr_COMP	2200	Specific Conductance	3200	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	2200	pH	9.1	pH
11-JUL-03	FRIDAY	1_Hr_COMP	2300	Specific Conductance	3200	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	2300	pH	8.8	pH
11-JUL-03	FRIDAY	1_Hr_COMP	2400	Specific Conductance	3200	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	2400	pH	8.6	pH
12-JUL-03	SATURDAY	1_Hr_COMP	100	Specific Conductance	3200	umhos/cm
12-JUL-03	SATURDAY	1_Hr_COMP	100	pH	8.7	pH
12-JUL-03	SATURDAY	1_Hr_COMP	200	Specific Conductance	3300	umhos/cm
12-JUL-03	SATURDAY	1_Hr_COMP	200	pH	8.7	pH
12-JUL-03	SATURDAY	COMP_CONDUCT	840	Specific Conductance	3300	umhos/cm
12-JUL-03	SATURDAY	COMP_PH	840	pH	8.6	pH
12-JUL-03	SATURDAY	GRAB	845	Specific Conductance	3300	umhos/cm
12-JUL-03	SATURDAY	GRAB	845	pH	7.4	pH
20-JUL-03	SUNDAY	GRAB	825	Specific Conductance	2200	umhos/cm
20-JUL-03	SUNDAY	GRAB	825	pH	7.2	pH

SITE 5

City of Mexicali
Site 5

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
13-JAN-03	MONDAY	1_Hr_COMP	1335 Specific Conductance	2100 umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1335 pH	7 pH
13-JAN-03	MONDAY	1_Hr_COMP	1435 Specific Conductance	2100 umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1435 pH	7.4 pH
13-JAN-03	MONDAY	1_Hr_COMP	1535 Specific Conductance	2300 umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1535 pH	7.4 pH
13-JAN-03	MONDAY	1_Hr_COMP	1635 Specific Conductance	2300 umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1635 pH	7.3 pH
13-JAN-03	MONDAY	1_Hr_COMP	1735 Specific Conductance	2100 umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1735 pH	6.2 pH
13-JAN-03	MONDAY	1_Hr_COMP	1835 Specific Conductance	2400 umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1835 pH	7.0 pH
13-JAN-03	MONDAY	1_Hr_COMP	1935 Specific Conductance	2400 umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	1935 pH	7.1 pH
13-JAN-03	MONDAY	1_Hr_COMP	2035 Specific Conductance	2400 umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	2035 pH	7.3 pH
13-JAN-03	MONDAY	1_Hr_COMP	2135 Specific Conductance	2400 umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	2135 pH	7.3 pH
13-JAN-03	MONDAY	1_Hr_COMP	2235 Specific Conductance	2400 umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	2235 pH	7.3 pH
13-JAN-03	MONDAY	1_Hr_COMP	2335 Specific Conductance	2300 umhos/cm
13-JAN-03	MONDAY	1_Hr_COMP	2335 pH	7.4 pH
14-JAN-03	TUESDAY	1_Hr_COMP	35 Specific Conductance	2400 umhos/cm
14-JAN-03	TUESDAY	1_Hr_COMP	35 pH	7.3 pH
14-JAN-03	TUESDAY	COMP_CONDUCT	1410 Specific Conductance	2200 umhos/cm
14-JAN-03	TUESDAY	COMP_PH	1410 pH	6.9 pH
14-JAN-03	TUESDAY	GRAB	1420 Specific Conductance	2300 umhos/cm
14-JAN-03	TUESDAY	GRAB	1420 pH	7.3 pH
21-JAN-03	TUESDAY	1_Hr_COMP	1315 Specific Conductance	2100 umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1315 pH	7.3 pH
21-JAN-03	TUESDAY	1_Hr_COMP	1415 Specific Conductance	2100 umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1415 pH	7.7 pH
21-JAN-03	TUESDAY	1_Hr_COMP	1515 Specific Conductance	2200 umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1515 pH	7.6 pH
21-JAN-03	TUESDAY	1_Hr_COMP	1615 Specific Conductance	2200 umhos/cm
21-JAN-03	TUESDAY	1_Hr_COMP	1615 pH	7.4 pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	615 Specific Conductance	2200 umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	615 pH	7.5 pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	715 Specific Conductance	2200 umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	715 pH	7.4 pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	815 Specific Conductance	2200 umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	815 pH	7.5 pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	915 Specific Conductance	2200 umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	915 pH	7.6 pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	1015 Specific Conductance	2200 umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	1015 pH	7.7 pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	1115 Specific Conductance	2200 umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	1115 pH	7.7 pH
22-JAN-03	WEDNESDAY	1_Hr_COMP	1215 Specific Conductance	2200 umhos/cm
22-JAN-03	WEDNESDAY	1_Hr_COMP	1215 pH	7.7 pH
22-JAN-03	WEDNESDAY	COMP_CONDUCT	1255 Specific Conductance	2200 umhos/cm
22-JAN-03	WEDNESDAY	COMP_PH	1255 pH	7.5 pH
22-JAN-03	WEDNESDAY	GRAB	1305 Specific Conductance	2300 umhos/cm
22-JAN-03	WEDNESDAY	GRAB	1305 pH	7.4 pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1225 Specific Conductance	2100 umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1225 pH	7.3 pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1325 Specific Conductance	2100 umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1325 pH	7.4 pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1425 Specific Conductance	2100 umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1425 pH	7.4 pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1525 Specific Conductance	2100 umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1525 pH	7.4 pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1625 Specific Conductance	2100 umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1625 pH	7.4 pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1725 Specific Conductance	2200 umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1725 pH	7.4 pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1825 Specific Conductance	2200 umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1825 pH	7.3 pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1925 Specific Conductance	2200 umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1925 pH	7.2 pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2025 Specific Conductance	2200 umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2025 pH	7.4 pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2125 Specific Conductance	2200 umhos/cm

City of Mexicali
Site 5

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
29-JAN-03	WEDNESDAY	1_Hr_COMP	2125	pH	7.3	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2225	Specific Conductance	2100	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2225	pH	7.3	pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2325	Specific Conductance	2200	umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2325	pH	7.2	pH
30-JAN-03	THURSDAY	1_Hr_COMP	25	Specific Conductance	2300	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	25	pH	7.3	pH
30-JAN-03	THURSDAY	1_Hr_COMP	125	Specific Conductance	2200	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	125	pH	7.4	pH
30-JAN-03	THURSDAY	1_Hr_COMP	225	Specific Conductance	2200	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	225	pH	7.5	pH
30-JAN-03	THURSDAY	1_Hr_COMP	325	Specific Conductance	2200	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	325	pH	7.6	pH
30-JAN-03	THURSDAY	1_Hr_COMP	425	Specific Conductance	2200	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	425	pH	7.6	pH
30-JAN-03	THURSDAY	1_Hr_COMP	525	Specific Conductance	2300	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	525	pH	7.6	pH
30-JAN-03	THURSDAY	1_Hr_COMP	625	Specific Conductance	2300	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	625	pH	7.6	pH
30-JAN-03	THURSDAY	1_Hr_COMP	725	Specific Conductance	2200	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	725	pH	7.6	pH
30-JAN-03	THURSDAY	1_Hr_COMP	825	Specific Conductance	2100	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	825	pH	7.7	pH
30-JAN-03	THURSDAY	1_Hr_COMP	925	Specific Conductance	2200	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	925	pH	7.7	pH
30-JAN-03	THURSDAY	1_Hr_COMP	1025	Specific Conductance	2100	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	1025	pH	7.6	pH
30-JAN-03	THURSDAY	1_Hr_COMP	1125	Specific Conductance	2100	umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	1125	pH	7.6	pH
30-JAN-03	THURSDAY	COMP_CONDUCT	1150	Specific Conductance	2200	umhos/cm
30-JAN-03	THURSDAY	COMP_PH	1150	pH	7.3	pH
30-JAN-03	THURSDAY	GRAB	1200	Specific Conductance	2200	umhos/cm
30-JAN-03	THURSDAY	GRAB	1200	pH	7.4	pH
07-FEB-03	FRIDAY	GRAB	1430	Specific Conductance	2100	umhos/cm
07-FEB-03	FRIDAY	GRAB	1430	pH	7.4	pH
22-FEB-03	SATURDAY	1_Hr_COMP	955	Specific Conductance	2000	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	955	pH	7.4	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1055	Specific Conductance	2200	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1055	pH	7.3	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1155	Specific Conductance	2200	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1155	pH	7.3	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1255	Specific Conductance	2100	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1255	pH	7.4	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1355	Specific Conductance	2100	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1355	pH	7.4	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1455	Specific Conductance	2100	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1455	pH	7.2	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1555	Specific Conductance	2100	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1555	pH	7.2	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1655	Specific Conductance	2100	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1655	pH	7.1	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1755	Specific Conductance	2100	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1755	pH	7.1	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1855	Specific Conductance	2100	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1855	pH	7.1	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1955	Specific Conductance	2000	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1955	pH	7.1	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2055	Specific Conductance	2000	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2055	pH	7.1	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2155	Specific Conductance	2000	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2155	pH	7.1	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2255	Specific Conductance	2000	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2255	pH	7.1	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2355	Specific Conductance	2000	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2355	pH	7.1	pH
23-FEB-03	SUNDAY	1_Hr_COMP	55	Specific Conductance	1800	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	55	pH	7.1	pH
23-FEB-03	SUNDAY	COMP_CONDUCT	1315	Specific Conductance	2100	umhos/cm
23-FEB-03	SUNDAY	COMP_PH	1315	pH	7.2	pH
23-FEB-03	SUNDAY	GRAB	1325	Specific Conductance	2100	umhos/cm
23-FEB-03	SUNDAY	GRAB	1325	pH	7.2	pH
02-MAR-03	SUNDAY	1_Hr_COMP	910	Specific Conductance	2300	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	910	pH	7.8	pH

City of Mexicali
Site 5

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
02-MAR-03	SUNDAY	1_Hr_COMP	1010 Specific Conductance	2300 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1010 pH	7.8 pH
02-MAR-03	SUNDAY	1_Hr_COMP	1110 Specific Conductance	2400 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1110 pH	7.7 pH
02-MAR-03	SUNDAY	1_Hr_COMP	1210 Specific Conductance	2300 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1210 pH	7.7 pH
02-MAR-03	SUNDAY	1_Hr_COMP	1310 Specific Conductance	2400 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1310 pH	7.7 pH
02-MAR-03	SUNDAY	1_Hr_COMP	1410 Specific Conductance	2500 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1410 pH	7.5 pH
02-MAR-03	SUNDAY	1_Hr_COMP	1510 Specific Conductance	2400 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1510 pH	7.6 pH
02-MAR-03	SUNDAY	1_Hr_COMP	1610 Specific Conductance	2400 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1610 pH	7.6 pH
02-MAR-03	SUNDAY	1_Hr_COMP	1710 Specific Conductance	2400 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1710 pH	7.6 pH
02-MAR-03	SUNDAY	1_Hr_COMP	1810 Specific Conductance	2300 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1810 pH	7.6 pH
02-MAR-03	SUNDAY	1_Hr_COMP	1910 Specific Conductance	2400 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1910 pH	7.6 pH
02-MAR-03	SUNDAY	1_Hr_COMP	2010 Specific Conductance	2500 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2010 pH	7.6 pH
02-MAR-03	SUNDAY	1_Hr_COMP	2110 Specific Conductance	2400 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2110 pH	7.6 pH
02-MAR-03	SUNDAY	1_Hr_COMP	2210 Specific Conductance	2300 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2210 pH	7.6 pH
02-MAR-03	SUNDAY	1_Hr_COMP	2310 Specific Conductance	2800 umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2310 pH	7.7 pH
03-MAR-03	MONDAY	1_Hr_COMP	10 Specific Conductance	2600 umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	10 pH	7.7 pH
03-MAR-03	MONDAY	1_Hr_COMP	110 Specific Conductance	2500 umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	110 pH	7.7 pH
03-MAR-03	MONDAY	1_Hr_COMP	210 Specific Conductance	3000 umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	210 pH	7.7 pH
03-MAR-03	MONDAY	1_Hr_COMP	310 Specific Conductance	2900 umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	310 pH	7.8 pH
03-MAR-03	MONDAY	1_Hr_COMP	410 Specific Conductance	2800 umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	410 pH	7.8 pH
03-MAR-03	MONDAY	1_Hr_COMP	510 Specific Conductance	2900 umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	510 pH	7.8 pH
03-MAR-03	MONDAY	1_Hr_COMP	610 Specific Conductance	2800 umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	610 pH	7.8 pH
03-MAR-03	MONDAY	1_Hr_COMP	710 Specific Conductance	2800 umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	710 pH	7.8 pH
03-MAR-03	MONDAY	1_Hr_COMP	810 Specific Conductance	2800 umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	810 pH	7.8 pH
03-MAR-03	MONDAY	COMP_CONDUCT	1015 Specific Conductance	1900 umhos/cm
03-MAR-03	MONDAY	COMP_PH	1015 pH	7.7 pH
03-MAR-03	MONDAY	GRAB	1035 Specific Conductance	1900 umhos/cm
03-MAR-03	MONDAY	GRAB	1035 pH	7.7 pH
04-MAR-03	TUESDAY	1_Hr_COMP	925 Specific Conductance	1700 umhos/cm
04-MAR-03	TUESDAY	1_Hr_COMP	925 pH	7 pH
04-MAR-03	TUESDAY	1_Hr_COMP	1025 Specific Conductance	1700 umhos/cm
04-MAR-03	TUESDAY	1_Hr_COMP	1025 pH	7 pH
04-MAR-03	TUESDAY	1_Hr_COMP	1125 Specific Conductance	1700 umhos/cm
04-MAR-03	TUESDAY	1_Hr_COMP	1125 pH	7 pH
04-MAR-03	TUESDAY	1_Hr_COMP	1225 Specific Conductance	1700 umhos/cm
04-MAR-03	TUESDAY	1_Hr_COMP	1225 pH	6.9 pH
04-MAR-03	TUESDAY	1_Hr_COMP	1325 Specific Conductance	1700 umhos/cm
04-MAR-03	TUESDAY	1_Hr_COMP	1325 pH	6.9 pH
04-MAR-03	TUESDAY	1_Hr_COMP	1425 Specific Conductance	1700 umhos/cm
04-MAR-03	TUESDAY	1_Hr_COMP	1425 pH	7 pH
04-MAR-03	TUESDAY	1_Hr_COMP	1525 Specific Conductance	1700 umhos/cm
04-MAR-03	TUESDAY	1_Hr_COMP	1525 pH	7 pH
04-MAR-03	TUESDAY	1_Hr_COMP	1625 Specific Conductance	1700 umhos/cm
04-MAR-03	TUESDAY	1_Hr_COMP	1625 pH	7 pH
04-MAR-03	TUESDAY	1_Hr_COMP	1725 Specific Conductance	1700 umhos/cm
04-MAR-03	TUESDAY	1_Hr_COMP	1725 pH	7 pH
04-MAR-03	TUESDAY	1_Hr_COMP	1825 Specific Conductance	1700 umhos/cm
04-MAR-03	TUESDAY	1_Hr_COMP	1825 pH	7 pH
04-MAR-03	TUESDAY	1_Hr_COMP	1925 Specific Conductance	1700 umhos/cm
04-MAR-03	TUESDAY	1_Hr_COMP	1925 pH	7 pH
04-MAR-03	TUESDAY	1_Hr_COMP	2025 Specific Conductance	1600 umhos/cm

City of Mexicali
Site 5

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
04-MAR-03	TUESDAY	1_Hr_COMP	2025 pH	7 pH
04-MAR-03	TUESDAY	1_Hr_COMP	2125 Specific Conductance	1600 umhos/cm
04-MAR-03	TUESDAY	1_Hr_COMP	2125 pH	7 pH
04-MAR-03	TUESDAY	1_Hr_COMP	2225 Specific Conductance	1600 umhos/cm
04-MAR-03	TUESDAY	1_Hr_COMP	2225 pH	7 pH
04-MAR-03	TUESDAY	1_Hr_COMP	2325 Specific Conductance	1600 umhos/cm
04-MAR-03	TUESDAY	1_Hr_COMP	2325 pH	7 pH
05-MAR-03	WEDNESDAY	1_Hr_COMP	25 Specific Conductance	1600 umhos/cm
05-MAR-03	WEDNESDAY	1_Hr_COMP	25 pH	7 pH
05-MAR-03	WEDNESDAY	1_Hr_COMP	125 Specific Conductance	1600 umhos/cm
05-MAR-03	WEDNESDAY	1_Hr_COMP	125 pH	7 pH
05-MAR-03	WEDNESDAY	1_Hr_COMP	225 Specific Conductance	1500 umhos/cm
05-MAR-03	WEDNESDAY	1_Hr_COMP	225 pH	7 pH
05-MAR-03	WEDNESDAY	1_Hr_COMP	325 Specific Conductance	1500 umhos/cm
05-MAR-03	WEDNESDAY	1_Hr_COMP	325 pH	7 pH
05-MAR-03	WEDNESDAY	1_Hr_COMP	425 Specific Conductance	1500 umhos/cm
05-MAR-03	WEDNESDAY	1_Hr_COMP	425 pH	6.9 pH
05-MAR-03	WEDNESDAY	1_Hr_COMP	525 Specific Conductance	1500 umhos/cm
05-MAR-03	WEDNESDAY	1_Hr_COMP	525 pH	6.9 pH
05-MAR-03	WEDNESDAY	1_Hr_COMP	625 Specific Conductance	1500 umhos/cm
05-MAR-03	WEDNESDAY	1_Hr_COMP	625 pH	6.9 pH
05-MAR-03	WEDNESDAY	1_Hr_COMP	725 Specific Conductance	1500 umhos/cm
05-MAR-03	WEDNESDAY	1_Hr_COMP	725 pH	6.8 pH
05-MAR-03	WEDNESDAY	1_Hr_COMP	825 Specific Conductance	1500 umhos/cm
05-MAR-03	WEDNESDAY	1_Hr_COMP	825 pH	6.9 pH

SITE 6

City of Mexicali
Site 6

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
29-JAN-03	WEDNESDAY	1_Hr_COMP	1310 Specific Conductance	2800 umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1310 pH	7.2 pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1410 Specific Conductance	2800 umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1410 pH	7.3 pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1510 Specific Conductance	2600 umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1510 pH	7.3 pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1610 Specific Conductance	2600 umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1610 pH	7.3 pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1710 Specific Conductance	2500 umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1710 pH	7.3 pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1810 Specific Conductance	2600 umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1810 pH	7.3 pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	1910 Specific Conductance	2400 umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	1910 pH	7.4 pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2010 Specific Conductance	2400 umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2010 pH	7.5 pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2110 Specific Conductance	2300 umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2110 pH	7.5 pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2210 Specific Conductance	2300 umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2210 pH	7.5 pH
29-JAN-03	WEDNESDAY	1_Hr_COMP	2310 Specific Conductance	2400 umhos/cm
29-JAN-03	WEDNESDAY	1_Hr_COMP	2310 pH	7.5 pH
30-JAN-03	THURSDAY	1_Hr_COMP	10 Specific Conductance	2200 umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	10 pH	7.6 pH
30-JAN-03	THURSDAY	1_Hr_COMP	110 Specific Conductance	2200 umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	110 pH	7.6 pH
30-JAN-03	THURSDAY	1_Hr_COMP	210 Specific Conductance	2200 umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	210 pH	7.6 pH
30-JAN-03	THURSDAY	1_Hr_COMP	310 Specific Conductance	2100 umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	310 pH	7.6 pH
30-JAN-03	THURSDAY	1_Hr_COMP	410 Specific Conductance	2100 umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	410 pH	7.7 pH
30-JAN-03	THURSDAY	1_Hr_COMP	510 Specific Conductance	2100 umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	510 pH	7.7 pH
30-JAN-03	THURSDAY	1_Hr_COMP	610 Specific Conductance	2000 umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	610 pH	7.7 pH
30-JAN-03	THURSDAY	1_Hr_COMP	710 Specific Conductance	2000 umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	710 pH	7.7 pH
30-JAN-03	THURSDAY	1_Hr_COMP	810 Specific Conductance	2100 umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	810 pH	7.8 pH
30-JAN-03	THURSDAY	1_Hr_COMP	910 Specific Conductance	2200 umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	910 pH	7.6 pH
30-JAN-03	THURSDAY	1_Hr_COMP	1010 Specific Conductance	2300 umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	1010 pH	7.7 pH
30-JAN-03	THURSDAY	1_Hr_COMP	1110 Specific Conductance	2300 umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	1110 pH	7.7 pH
30-JAN-03	THURSDAY	1_Hr_COMP	1210 Specific Conductance	2400 umhos/cm
30-JAN-03	THURSDAY	1_Hr_COMP	1210 pH	7.6 pH
30-JAN-03	THURSDAY	COMP_CONDUCT	1230 Specific Conductance	2100 umhos/cm
30-JAN-03	THURSDAY	COMP_PH	1230 pH	7.4 pH
30-JAN-03	THURSDAY	GRAB	1240 Specific Conductance	2300 umhos/cm
30-JAN-03	THURSDAY	GRAB	1240 pH	7.3 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1200 Specific Conductance	2100 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1200 pH	7.5 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1300 Specific Conductance	2100 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1300 pH	7.4 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1400 Specific Conductance	2200 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1400 pH	7.5 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1500 Specific Conductance	2100 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1500 pH	7.2 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1600 Specific Conductance	2100 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1600 pH	7.2 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1700 Specific Conductance	2100 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1700 pH	7.3 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1800 Specific Conductance	2200 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1800 pH	7.4 pH
06-FEB-03	THURSDAY	1_Hr_COMP	1900 Specific Conductance	1100 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	1900 pH	7.4 pH
06-FEB-03	THURSDAY	1_Hr_COMP	2000 Specific Conductance	2000 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	2000 pH	7.4 pH
06-FEB-03	THURSDAY	1_Hr_COMP	2100 Specific Conductance	2000 umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	2100 pH	7.4 pH
06-FEB-03	THURSDAY	1_Hr_COMP	2200 Specific Conductance	2100 umhos/cm

City of Mexicali
Site 6

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
06-FEB-03	THURSDAY	1_Hr_COMP	2200	pH	7.6	pH
06-FEB-03	THURSDAY	1_Hr_COMP	2300	Specific Conductance	2300	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	2300	pH	7.5	pH
06-FEB-03	THURSDAY	1_Hr_COMP	2400	Specific Conductance	2200	umhos/cm
06-FEB-03	THURSDAY	1_Hr_COMP	2400	pH	7.5	pH
07-FEB-03	FRIDAY	1_Hr_COMP	100	Specific Conductance	2200	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	100	pH	7.5	pH
07-FEB-03	FRIDAY	1_Hr_COMP	200	Specific Conductance	2100	umhos/cm
07-FEB-03	FRIDAY	1_Hr_COMP	200	pH	7.5	pH
07-FEB-03	FRIDAY	COMP_CONDUCT	1500	Specific Conductance	2200	umhos/cm
07-FEB-03	FRIDAY	COMP_PH	1500	pH	7.1	pH
07-FEB-03	FRIDAY	GRAB	1510	Specific Conductance	2200	umhos/cm
07-FEB-03	FRIDAY	GRAB	1510	pH	7.2	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1020	Specific Conductance	2100	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1020	pH	7.5	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1120	Specific Conductance	2100	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1120	pH	7.4	pH
22-FEB-03	SATURDAY	1_Hr_COMP	1220	Specific Conductance	2100	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	1220	pH	7.5	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2020	Specific Conductance	2000	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2020	pH	7.5	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2120	Specific Conductance	2000	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2120	pH	7.5	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2220	Specific Conductance	1900	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2220	pH	7.5	pH
22-FEB-03	SATURDAY	1_Hr_COMP	2320	Specific Conductance	1900	umhos/cm
22-FEB-03	SATURDAY	1_Hr_COMP	2320	pH	7.4	pH
23-FEB-03	SUNDAY	1_Hr_COMP	20	Specific Conductance	1900	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	20	pH	7.4	pH
23-FEB-03	SUNDAY	1_Hr_COMP	120	Specific Conductance	1900	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	120	pH	7.4	pH
23-FEB-03	SUNDAY	1_Hr_COMP	220	Specific Conductance	1900	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	220	pH	7.4	pH
23-FEB-03	SUNDAY	1_Hr_COMP	320	Specific Conductance	1800	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	320	pH	7.5	pH
23-FEB-03	SUNDAY	1_Hr_COMP	420	Specific Conductance	1800	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	420	pH	7.5	pH
23-FEB-03	SUNDAY	1_Hr_COMP	520	Specific Conductance	1800	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	520	pH	7.5	pH
23-FEB-03	SUNDAY	1_Hr_COMP	620	Specific Conductance	1700	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	620	pH	7.5	pH
23-FEB-03	SUNDAY	1_Hr_COMP	720	Specific Conductance	1700	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	720	pH	7.5	pH
23-FEB-03	SUNDAY	1_Hr_COMP	820	Specific Conductance	1700	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	820	pH	7.4	pH
23-FEB-03	SUNDAY	1_Hr_COMP	920	Specific Conductance	1800	umhos/cm
23-FEB-03	SUNDAY	1_Hr_COMP	920	pH	7.4	pH
23-FEB-03	SUNDAY	COMP_CONDUCT	1350	Specific Conductance	1900	umhos/cm
23-FEB-03	SUNDAY	COMP_PH	1350	pH	7.5	pH
23-FEB-03	SUNDAY	GRAB	1400	Specific Conductance	2000	umhos/cm
23-FEB-03	SUNDAY	GRAB	1400	pH	7.4	pH
02-MAR-03	SUNDAY	1_Hr_COMP	935	Specific Conductance	2100	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	935	pH	8.1	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1035	Specific Conductance	2000	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1035	pH	8.2	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1135	Specific Conductance	2200	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1135	pH	8.1	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1235	Specific Conductance	2200	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1235	pH	8	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1335	Specific Conductance	2100	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1335	pH	8	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1435	Specific Conductance	2100	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1435	pH	8	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1535	Specific Conductance	1900	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1535	pH	8.2	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1635	Specific Conductance	2600	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1635	pH	8.1	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1835	Specific Conductance	2100	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1835	pH	8.2	pH
02-MAR-03	SUNDAY	1_Hr_COMP	1935	Specific Conductance	2100	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	1935	pH	7.8	pH
02-MAR-03	SUNDAY	1_Hr_COMP	2035	Specific Conductance	2000	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2035	pH	8	pH

City of Mexicali
Site 6

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE	UNITS
02-MAR-03	SUNDAY	1_Hr_COMP	2135 Specific Conductance	2100	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2135 pH	8.1	pH
02-MAR-03	SUNDAY	1_Hr_COMP	2235 Specific Conductance	2100	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2235 pH	7.9	pH
02-MAR-03	SUNDAY	1_Hr_COMP	2335 Specific Conductance	2800	umhos/cm
02-MAR-03	SUNDAY	1_Hr_COMP	2335 pH	8.3	pH
03-MAR-03	MONDAY	1_Hr_COMP	35 Specific Conductance	2600	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	35 pH	8.2	pH
03-MAR-03	MONDAY	1_Hr_COMP	135 Specific Conductance	2700	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	135 pH	7.8	pH
03-MAR-03	MONDAY	1_Hr_COMP	235 Specific Conductance	2700	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	235 pH	8	pH
03-MAR-03	MONDAY	1_Hr_COMP	335 Specific Conductance	2600	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	335 pH	7.7	pH
03-MAR-03	MONDAY	1_Hr_COMP	435 Specific Conductance	2700	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	435 pH	7.8	pH
03-MAR-03	MONDAY	1_Hr_COMP	535 Specific Conductance	2600	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	535 pH	7.8	pH
03-MAR-03	MONDAY	1_Hr_COMP	635 Specific Conductance	2600	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	635 pH	7.8	pH
03-MAR-03	MONDAY	1_Hr_COMP	735 Specific Conductance	2600	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	735 pH	8	pH
03-MAR-03	MONDAY	1_Hr_COMP	835 Specific Conductance	2600	umhos/cm
03-MAR-03	MONDAY	1_Hr_COMP	835 pH	8.1	pH
03-MAR-03	MONDAY	COMP_CONDUCT	1105 Specific Conductance	2800	umhos/cm
03-MAR-03	MONDAY	COMP_PH	1105 pH	8	pH
03-MAR-03	MONDAY	GRAB	1115 Specific Conductance	2300	umhos/cm
03-MAR-03	MONDAY	GRAB	1115 pH	7.7	pH
28-MAR-03	FRIDAY	1_Hr_COMP	1100 Specific Conductance	2000	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1200 Specific Conductance	2000	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1300 Specific Conductance	2000	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1400 Specific Conductance	1900	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1500 Specific Conductance	1800	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1600 Specific Conductance	1900	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1700 Specific Conductance	1900	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1800 Specific Conductance	2100	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1900 Specific Conductance	2000	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2000 Specific Conductance	2100	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2100 Specific Conductance	2200	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2200 Specific Conductance	2000	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2300 Specific Conductance	2100	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2400 Specific Conductance	2000	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	100 Specific Conductance	2100	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	200 Specific Conductance	1900	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	300 Specific Conductance	1900	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	400 Specific Conductance	1900	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	500 Specific Conductance	1800	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	600 Specific Conductance	1700	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	700 Specific Conductance	1800	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	800 Specific Conductance	1800	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	900 Specific Conductance	2100	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	1000 Specific Conductance	2100	umhos/cm
29-MAR-03	SATURDAY	COMP_CONDUCT	1123 Specific Conductance	1900	umhos/cm
29-MAR-03	SATURDAY	GRAB	1130 Specific Conductance	2100	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	855 Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	855 pH	7.6	pH
05-APR-03	SATURDAY	1_Hr_COMP	955 Specific Conductance	2100	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	955 pH	7.3	pH
05-APR-03	SATURDAY	1_Hr_COMP	1055 Specific Conductance	2300	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1055 pH	7.3	pH
05-APR-03	SATURDAY	1_Hr_COMP	1155 Specific Conductance	2100	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1155 pH	7.4	pH
05-APR-03	SATURDAY	1_Hr_COMP	1255 Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1255 pH	7.3	pH
05-APR-03	SATURDAY	1_Hr_COMP	1355 Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1355 pH	7.3	pH
05-APR-03	SATURDAY	1_Hr_COMP	1455 Specific Conductance	1900	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1455 pH	7.2	pH
05-APR-03	SATURDAY	1_Hr_COMP	1555 Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1555 pH	7.3	pH
05-APR-03	SATURDAY	1_Hr_COMP	1655 Specific Conductance	1900	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1655 pH	7.4	pH
05-APR-03	SATURDAY	1_Hr_COMP	1755 Specific Conductance	1900	umhos/cm

City of Mexicali
Site 6

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
05-APR-03	SATURDAY	1_Hr_COMP	1755	pH	7.2	pH
05-APR-03	SATURDAY	1_Hr_COMP	1855	Specific Conductance	1900	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1855	pH	7.2	pH
05-APR-03	SATURDAY	1_Hr_COMP	1955	Specific Conductance	1900	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1955	pH	7.4	pH
05-APR-03	SATURDAY	1_Hr_COMP	2055	Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	2055	pH	7.3	pH
05-APR-03	SATURDAY	1_Hr_COMP	2155	Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	2155	pH	7.4	pH
05-APR-03	SATURDAY	1_Hr_COMP	2255	Specific Conductance	2100	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	2255	pH	7.4	pH
05-APR-03	SATURDAY	1_Hr_COMP	2355	Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	2355	pH	7.5	pH
06-APR-03	SUNDAY	1_Hr_COMP	55	Specific Conductance	2100	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	55	pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP	155	Specific Conductance	2000	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	155	pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP	255	Specific Conductance	1800	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	255	pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP	355	Specific Conductance	1900	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	355	pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP	455	Specific Conductance	1800	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	455	pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP	555	Specific Conductance	1700	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	555	pH	7.5	pH
06-APR-03	SUNDAY	1_Hr_COMP	655	Specific Conductance	1700	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	655	pH	7.5	pH
06-APR-03	SUNDAY	1_Hr_COMP	755	Specific Conductance	1700	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	755	pH	7.6	pH
06-APR-03	SUNDAY	COMP_CONDUCT	1050	Specific Conductance	2000	umhos/cm
06-APR-03	SUNDAY	COMP_PH	1050	pH	7.4	pH
06-APR-03	SUNDAY	GRAB	1100	Specific Conductance	2000	umhos/cm
06-APR-03	SUNDAY	GRAB	1100	pH	7.6	pH
14-APR-03	MONDAY	1_Hr_COMP	920	Specific Conductance	1700	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	920	pH	7.5	pH
14-APR-03	MONDAY	1_Hr_COMP	1020	Specific Conductance	1900	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1020	pH	7.4	pH
14-APR-03	MONDAY	1_Hr_COMP	1120	Specific Conductance	1900	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1120	pH	7.3	pH
14-APR-03	MONDAY	1_Hr_COMP	1220	Specific Conductance	1900	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1220	pH	7.3	pH
14-APR-03	MONDAY	1_Hr_COMP	1320	Specific Conductance	1800	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1320	pH	7.3	pH
14-APR-03	MONDAY	1_Hr_COMP	1420	Specific Conductance	1700	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1420	pH	7.2	pH
14-APR-03	MONDAY	1_Hr_COMP	1520	Specific Conductance	1700	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1520	pH	7.1	pH
14-APR-03	MONDAY	1_Hr_COMP	1620	Specific Conductance	1700	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1620	pH	7.2	pH
14-APR-03	MONDAY	1_Hr_COMP	1720	Specific Conductance	1800	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1720	pH	7.3	pH
14-APR-03	MONDAY	1_Hr_COMP	1820	Specific Conductance	1700	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1820	pH	7.3	pH
14-APR-03	MONDAY	1_Hr_COMP	1920	Specific Conductance	1700	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1920	pH	7.3	pH
14-APR-03	MONDAY	1_Hr_COMP	2020	Specific Conductance	1700	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2020	pH	7.2	pH
14-APR-03	MONDAY	1_Hr_COMP	2120	Specific Conductance	1700	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2120	pH	7.2	pH
14-APR-03	MONDAY	1_Hr_COMP	2220	Specific Conductance	1700	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2220	pH	7.2	pH
14-APR-03	MONDAY	1_Hr_COMP	2320	Specific Conductance	1700	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2320	pH	7.3	pH
15-APR-03	TUESDAY	1_Hr_COMP	20	Specific Conductance	1700	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	20	pH	7.4	pH
15-APR-03	TUESDAY	1_Hr_COMP	120	Specific Conductance	1700	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	120	pH	7.2	pH
15-APR-03	TUESDAY	1_Hr_COMP	220	Specific Conductance	1700	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	220	pH	7.2	pH
15-APR-03	TUESDAY	1_Hr_COMP	320	Specific Conductance	1800	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	320	pH	7.4	pH
15-APR-03	TUESDAY	1_Hr_COMP	420	Specific Conductance	1900	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	420	pH	7.5	pH

City of Mexicali
Site 6

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
15-APR-03	TUESDAY	1_Hr_COMP	520 Specific Conductance	1700 umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	520 pH	7.5 pH
15-APR-03	TUESDAY	1_Hr_COMP	620 Specific Conductance	1500 umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	620 pH	7.6 pH
15-APR-03	TUESDAY	1_Hr_COMP	720 Specific Conductance	1600 umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	720 pH	7.7 pH
15-APR-03	TUESDAY	1_Hr_COMP	820 Specific Conductance	1700 umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	820 pH	7.7 pH
15-APR-03	TUESDAY	COMP_CONDUCT	940 Specific Conductance	1700 umhos/cm
15-APR-03	TUESDAY	COMP_PH	940 pH	7.4 pH
15-APR-03	TUESDAY	GRAB	945 Specific Conductance	1700 umhos/cm
15-APR-03	TUESDAY	GRAB	945 pH	7.6 pH
22-APR-03	TUESDAY	1_Hr_COMP	1004 Specific Conductance	2000 umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1004 pH	7.9 pH
22-APR-03	TUESDAY	1_Hr_COMP	1104 Specific Conductance	2500 umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1104 pH	7.7 pH
22-APR-03	TUESDAY	1_Hr_COMP	1204 Specific Conductance	2100 umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1204 pH	7.4 pH
22-APR-03	TUESDAY	1_Hr_COMP	1304 Specific Conductance	2100 umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1304 pH	7.4 pH
22-APR-03	TUESDAY	1_Hr_COMP	1404 Specific Conductance	2000 umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1404 pH	7.4 pH
22-APR-03	TUESDAY	1_Hr_COMP	1504 Specific Conductance	1900 umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1504 pH	7.4 pH
22-APR-03	TUESDAY	1_Hr_COMP	1604 Specific Conductance	1900 umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1604 pH	7.5 pH
22-APR-03	TUESDAY	1_Hr_COMP	1704 Specific Conductance	2000 umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1704 pH	7.6 pH
22-APR-03	TUESDAY	1_Hr_COMP	1804 Specific Conductance	2100 umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1804 pH	7.6 pH
22-APR-03	TUESDAY	1_Hr_COMP	1904 Specific Conductance	2100 umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1904 pH	7.6 pH
22-APR-03	TUESDAY	1_Hr_COMP	2004 Specific Conductance	2200 umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2004 pH	7.8 pH
22-APR-03	TUESDAY	1_Hr_COMP	2104 Specific Conductance	3400 umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2104 pH	7.6 pH
22-APR-03	TUESDAY	1_Hr_COMP	2204 Specific Conductance	2100 umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2204 pH	7.6 pH
22-APR-03	TUESDAY	1_Hr_COMP	2304 Specific Conductance	2400 umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2304 pH	7.8 pH
23-APR-03	WEDNESDAY	1_Hr_COMP	4 Specific Conductance	2000 umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	4 pH	7.6 pH
23-APR-03	WEDNESDAY	1_Hr_COMP	104 Specific Conductance	2000 umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	104 pH	8 pH
23-APR-03	WEDNESDAY	COMP_CONDUCT	1050 Specific Conductance	2200 umhos/cm
23-APR-03	WEDNESDAY	COMP_PH	1050 pH	7.6 pH
23-APR-03	WEDNESDAY	GRAB	1100 Specific Conductance	2200 umhos/cm
23-APR-03	WEDNESDAY	GRAB	1100 pH	7.6 pH

SITE 7

City of Mexicali
Site 7

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
28-MAR-03	FRIDAY	1_Hr_COMP	1200	Specific Conductance	2100	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1300	Specific Conductance	2100	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1400	Specific Conductance	2100	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1500	Specific Conductance	2200	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1600	Specific Conductance	2200	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1700	Specific Conductance	2100	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1800	Specific Conductance	2300	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1900	Specific Conductance	2300	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2000	Specific Conductance	2300	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2100	Specific Conductance	2300	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2200	Specific Conductance	2300	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2300	Specific Conductance	2100	umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2400	Specific Conductance	1900	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	100	Specific Conductance	1900	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	200	Specific Conductance	1800	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	300	Specific Conductance	1900	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	400	Specific Conductance	1800	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	500	Specific Conductance	1700	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	600	Specific Conductance	1800	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	700	Specific Conductance	2100	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	800	Specific Conductance	2300	umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	900	Specific Conductance	2100	umhos/cm
29-MAR-03	SATURDAY	COMP_CONDUCT	1155	Specific Conductance	2000	umhos/cm
29-MAR-03	SATURDAY	GRAB	1205	Specific Conductance	3000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1040	Specific Conductance	2200	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1040	pH	7.2	pH
05-APR-03	SATURDAY	1_Hr_COMP	1140	Specific Conductance	2100	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1140	pH	7	pH
05-APR-03	SATURDAY	1_Hr_COMP	1240	Specific Conductance	2100	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1240	pH	6.5	pH
05-APR-03	SATURDAY	1_Hr_COMP	1340	Specific Conductance	2200	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1340	pH	6.3	pH
05-APR-03	SATURDAY	1_Hr_COMP	1440	Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1440	pH	6.6	pH
05-APR-03	SATURDAY	1_Hr_COMP	1540	Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1540	pH	6.7	pH
05-APR-03	SATURDAY	1_Hr_COMP	1640	Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1640	pH	7	pH
05-APR-03	SATURDAY	1_Hr_COMP	1740	Specific Conductance	2200	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1740	pH	7	pH
05-APR-03	SATURDAY	1_Hr_COMP	1840	Specific Conductance	2200	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1840	pH	7.1	pH
05-APR-03	SATURDAY	1_Hr_COMP	1940	Specific Conductance	2200	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1940	pH	7.2	pH
05-APR-03	SATURDAY	1_Hr_COMP	2040	Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	2040	pH	7.2	pH
05-APR-03	SATURDAY	1_Hr_COMP	2140	Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	2140	pH	7.2	pH
05-APR-03	SATURDAY	1_Hr_COMP	2240	Specific Conductance	2000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	2240	pH	7.2	pH
06-APR-03	SUNDAY	COMP_CONDUCT	1120	Specific Conductance	2100	umhos/cm
06-APR-03	SUNDAY	COMP_PH	1120	pH	6.9	pH
06-APR-03	SUNDAY	GRAB	1125	Specific Conductance	2200	umhos/cm
06-APR-03	SUNDAY	GRAB	1125	pH	7.7	pH
14-APR-03	MONDAY	1_Hr_COMP	940	Specific Conductance	2200	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	940	pH	7.3	pH
14-APR-03	MONDAY	1_Hr_COMP	1040	Specific Conductance	2400	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1040	pH	7.4	pH
14-APR-03	MONDAY	1_Hr_COMP	1140	Specific Conductance	2100	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1140	pH	7.2	pH
14-APR-03	MONDAY	1_Hr_COMP	1240	Specific Conductance	1900	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1240	pH	6.7	pH
14-APR-03	MONDAY	1_Hr_COMP	1340	Specific Conductance	1900	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1340	pH	7	pH
14-APR-03	MONDAY	1_Hr_COMP	1440	Specific Conductance	1900	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1440	pH	7.1	pH
14-APR-03	MONDAY	1_Hr_COMP	1540	Specific Conductance	2200	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1540	pH	7.2	pH
14-APR-03	MONDAY	1_Hr_COMP	1640	Specific Conductance	2400	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1640	pH	7.2	pH
14-APR-03	MONDAY	1_Hr_COMP	1740	Specific Conductance	1900	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1740	pH	7.2	pH
14-APR-03	MONDAY	1_Hr_COMP	1840	Specific Conductance	2100	umhos/cm

City of Mexicali
Site 7

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
14-APR-03	MONDAY	1_Hr_COMP	1840	pH	7.3	pH
14-APR-03	MONDAY	1_Hr_COMP	1940	Specific Conductance	1700	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1940	pH	7.3	pH
14-APR-03	MONDAY	1_Hr_COMP	2040	Specific Conductance	1500	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2040	pH	7.4	pH
14-APR-03	MONDAY	1_Hr_COMP	2140	Specific Conductance	1600	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2140	pH	7.5	pH
14-APR-03	MONDAY	1_Hr_COMP	2240	Specific Conductance	1700	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2240	pH	7.7	pH
14-APR-03	MONDAY	1_Hr_COMP	2340	Specific Conductance	2000	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2340	pH	7.7	pH
15-APR-03	TUESDAY	1_Hr_COMP	40	Specific Conductance	3400	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	40	pH	7.6	pH
15-APR-03	TUESDAY	COMP_CONDUCT	1010	Specific Conductance	2000	umhos/cm
15-APR-03	TUESDAY	COMP_PH	1010	pH	7.5	pH
15-APR-03	TUESDAY	GRAB	1015	Specific Conductance	2100	umhos/cm
15-APR-03	TUESDAY	GRAB	1015	pH	7.6	pH
22-APR-03	TUESDAY	1_Hr_COMP	1030	Specific Conductance	3600	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1030	pH	7.2	pH
22-APR-03	TUESDAY	1_Hr_COMP	1130	Specific Conductance	2300	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1130	pH	7.4	pH
22-APR-03	TUESDAY	1_Hr_COMP	1230	Specific Conductance	2400	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1230	pH	7.5	pH
22-APR-03	TUESDAY	1_Hr_COMP	1330	Specific Conductance	2300	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1330	pH	7.5	pH
22-APR-03	TUESDAY	1_Hr_COMP	1430	Specific Conductance	2200	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1430	pH	7.5	pH
22-APR-03	TUESDAY	1_Hr_COMP	1530	Specific Conductance	2400	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1530	pH	7	pH
22-APR-03	TUESDAY	1_Hr_COMP	1630	Specific Conductance	2600	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1630	pH	6.7	pH
22-APR-03	TUESDAY	1_Hr_COMP	1730	Specific Conductance	2700	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1730	pH	7.2	pH
22-APR-03	TUESDAY	1_Hr_COMP	1830	Specific Conductance	3600	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1830	pH	7.2	pH
22-APR-03	TUESDAY	1_Hr_COMP	1930	Specific Conductance	2200	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1930	pH	7.4	pH
22-APR-03	TUESDAY	1_Hr_COMP	2030	Specific Conductance	2200	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2030	pH	7.1	pH
22-APR-03	TUESDAY	1_Hr_COMP	2130	Specific Conductance	2400	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2130	pH	7	pH
22-APR-03	TUESDAY	1_Hr_COMP	2230	Specific Conductance	2100	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2230	pH	7	pH
22-APR-03	TUESDAY	1_Hr_COMP	2330	Specific Conductance	2100	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2330	pH	6.9	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	30	Specific Conductance	2200	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	30	pH	7.1	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	130	Specific Conductance	2100	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	130	pH	7.1	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	230	Specific Conductance	2000	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	230	pH	6.9	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	330	Specific Conductance	2000	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	330	pH	7.1	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	430	Specific Conductance	2100	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	430	pH	7.2	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	530	Specific Conductance	2100	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	530	pH	7.3	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	630	Specific Conductance	2100	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	630	pH	7.5	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	730	Specific Conductance	2100	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	730	pH	7.4	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	830	Specific Conductance	1900	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	830	pH	7.2	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	930	Specific Conductance	2100	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	930	pH	7.2	pH
23-APR-03	WEDNESDAY	COMP_CONDUCT	1118	Specific Conductance	2300	umhos/cm
23-APR-03	WEDNESDAY	COMP_PH	1118	pH	7.4	pH
23-APR-03	WEDNESDAY	GRAB	1125	Specific Conductance	2300	umhos/cm
23-APR-03	WEDNESDAY	GRAB	1125	pH	7.5	pH

SITE 8

City of Mexicali
Site 8

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
28-MAR-03	FRIDAY	1_Hr_COMP	1330 Specific Conductance	5000 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1330 pH	7.8 pH
28-MAR-03	FRIDAY	1_Hr_COMP	1430 Specific Conductance	4900 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1430 pH	7.7 pH
28-MAR-03	FRIDAY	1_Hr_COMP	1530 Specific Conductance	4700 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1630 Specific Conductance	4700 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1730 Specific Conductance	5000 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1830 Specific Conductance	5300 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	1930 Specific Conductance	5600 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2030 Specific Conductance	5600 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2130 Specific Conductance	5900 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2230 Specific Conductance	5900 umhos/cm
28-MAR-03	FRIDAY	1_Hr_COMP	2330 Specific Conductance	6000 umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	30 Specific Conductance	6100 umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	130 Specific Conductance	6200 umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	230 Specific Conductance	6100 umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	330 Specific Conductance	6100 umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	430 Specific Conductance	6200 umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	530 Specific Conductance	6100 umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	630 Specific Conductance	6200 umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	730 Specific Conductance	6100 umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	830 Specific Conductance	6100 umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	930 Specific Conductance	6000 umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	1030 Specific Conductance	6100 umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	1130 Specific Conductance	6000 umhos/cm
29-MAR-03	SATURDAY	1_Hr_COMP	1230 Specific Conductance	5900 umhos/cm
29-MAR-03	SATURDAY	COMP_CONDUCT	1300 Specific Conductance	5600 umhos/cm
29-MAR-03	SATURDAY	GRAB	1310 Specific Conductance	4600 umhos/cm

SITE 9

City of Mexicali
Site 9

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
05-APR-03	SATURDAY	1_Hr_COMP	1130	Specific Conductance	4200	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1130	pH	7.5	pH
05-APR-03	SATURDAY	1_Hr_COMP	1230	Specific Conductance	3800	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1230	pH	7.5	pH
05-APR-03	SATURDAY	1_Hr_COMP	1330	Specific Conductance	3900	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1330	pH	7.5	pH
05-APR-03	SATURDAY	1_Hr_COMP	1430	Specific Conductance	4000	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1430	pH	7.5	pH
05-APR-03	SATURDAY	1_Hr_COMP	1530	Specific Conductance	4100	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1530	pH	7.5	pH
05-APR-03	SATURDAY	1_Hr_COMP	1630	Specific Conductance	4200	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1630	pH	7.5	pH
05-APR-03	SATURDAY	1_Hr_COMP	1730	Specific Conductance	4200	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1730	pH	7.5	pH
05-APR-03	SATURDAY	1_Hr_COMP	1830	Specific Conductance	4200	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1830	pH	7.4	pH
05-APR-03	SATURDAY	1_Hr_COMP	1930	Specific Conductance	4400	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	1930	pH	7.4	pH
05-APR-03	SATURDAY	1_Hr_COMP	2030	Specific Conductance	4400	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	2030	pH	7.3	pH
05-APR-03	SATURDAY	1_Hr_COMP	2130	Specific Conductance	4400	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	2130	pH	7.4	pH
05-APR-03	SATURDAY	1_Hr_COMP	2230	Specific Conductance	4400	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	2230	pH	7.4	pH
05-APR-03	SATURDAY	1_Hr_COMP	2330	Specific Conductance	4500	umhos/cm
05-APR-03	SATURDAY	1_Hr_COMP	2330	pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP	30	Specific Conductance	4500	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	30	pH	7.3	pH
06-APR-03	SUNDAY	1_Hr_COMP	130	Specific Conductance	4400	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	130	pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP	230	Specific Conductance	4400	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	230	pH	7.3	pH
06-APR-03	SUNDAY	1_Hr_COMP	330	Specific Conductance	4500	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	330	pH	7.3	pH
06-APR-03	SUNDAY	1_Hr_COMP	430	Specific Conductance	4400	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	430	pH	7.3	pH
06-APR-03	SUNDAY	1_Hr_COMP	530	Specific Conductance	4400	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	530	pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP	630	Specific Conductance	4400	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	630	pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP	730	Specific Conductance	4400	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	730	pH	7.3	pH
06-APR-03	SUNDAY	1_Hr_COMP	830	Specific Conductance	4400	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	830	pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP	930	Specific Conductance	4300	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	930	pH	7.4	pH
06-APR-03	SUNDAY	1_Hr_COMP	1030	Specific Conductance	4200	umhos/cm
06-APR-03	SUNDAY	1_Hr_COMP	1030	pH	7.4	pH
06-APR-03	SUNDAY	COMP_CONDUCT	1150	Specific Conductance	4300	umhos/cm
06-APR-03	SUNDAY	COMP_PH	1150	pH	7.38	pH
06-APR-03	SUNDAY	GRAB	1155	Specific Conductance	4700	umhos/cm
06-APR-03	SUNDAY	GRAB	1155	pH	7.34	pH
14-APR-03	MONDAY	1_Hr_COMP	1000	Specific Conductance	3500	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1000	pH	7.8	pH
14-APR-03	MONDAY	1_Hr_COMP	1100	Specific Conductance	3500	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1100	pH	8	pH
14-APR-03	MONDAY	1_Hr_COMP	1200	Specific Conductance	3600	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1200	pH	8	pH
14-APR-03	MONDAY	1_Hr_COMP	1300	Specific Conductance	3600	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1300	pH	8	pH
14-APR-03	MONDAY	1_Hr_COMP	1400	Specific Conductance	3600	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1400	pH	7.9	pH
14-APR-03	MONDAY	1_Hr_COMP	1500	Specific Conductance	3600	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1500	pH	7.9	pH
14-APR-03	MONDAY	1_Hr_COMP	1600	Specific Conductance	3500	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1600	pH	7.9	pH
14-APR-03	MONDAY	1_Hr_COMP	1700	Specific Conductance	3400	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1700	pH	7.9	pH
14-APR-03	MONDAY	1_Hr_COMP	1800	Specific Conductance	3300	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1800	pH	7.9	pH
14-APR-03	MONDAY	1_Hr_COMP	1900	Specific Conductance	3100	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	1900	pH	7.9	pH
14-APR-03	MONDAY	1_Hr_COMP	2000	Specific Conductance	3200	umhos/cm

City of Mexicali
Site 9

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
14-APR-03	MONDAY	1_Hr_COMP	2000	pH	7.9	pH
14-APR-03	MONDAY	1_Hr_COMP	2100	Specific Conductance	3600	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2100	pH	7.7	pH
14-APR-03	MONDAY	1_Hr_COMP	2200	Specific Conductance	3400	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2200	pH	7.8	pH
14-APR-03	MONDAY	1_Hr_COMP	2300	Specific Conductance	3400	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2300	pH	7.7	pH
14-APR-03	MONDAY	1_Hr_COMP	2400	Specific Conductance	3400	umhos/cm
14-APR-03	MONDAY	1_Hr_COMP	2400	pH	7.8	pH
15-APR-03	TUESDAY	1_Hr_COMP	100	Specific Conductance	3400	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	100	pH	7.7	pH
15-APR-03	TUESDAY	1_Hr_COMP	200	Specific Conductance	3300	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	200	pH	7.6	pH
15-APR-03	TUESDAY	1_Hr_COMP	300	Specific Conductance	3200	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	300	pH	7.6	pH
15-APR-03	TUESDAY	1_Hr_COMP	400	Specific Conductance	3300	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	400	pH	7.8	pH
15-APR-03	TUESDAY	1_Hr_COMP	500	Specific Conductance	3300	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	500	pH	7.7	pH
15-APR-03	TUESDAY	1_Hr_COMP	600	Specific Conductance	3200	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	600	pH	7.7	pH
15-APR-03	TUESDAY	1_Hr_COMP	700	Specific Conductance	3300	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	700	pH	7.6	pH
15-APR-03	TUESDAY	1_Hr_COMP	800	Specific Conductance	3300	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	800	pH	7.6	pH
15-APR-03	TUESDAY	1_Hr_COMP	900	Specific Conductance	3300	umhos/cm
15-APR-03	TUESDAY	1_Hr_COMP	900	pH	7.6	pH
15-APR-03	TUESDAY	COMP_CONDUCT	1035	Specific Conductance	3400	umhos/cm
15-APR-03	TUESDAY	COMP_PH	1035	pH	7.9	pH
15-APR-03	TUESDAY	GRAB	1040	Specific Conductance	2400	umhos/cm
15-APR-03	TUESDAY	GRAB	1040	pH	7.8	pH
22-APR-03	TUESDAY	1_Hr_COMP	1055	Specific Conductance	6200	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1055	pH	7.9	pH
22-APR-03	TUESDAY	1_Hr_COMP	1155	Specific Conductance	5200	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1155	pH	7.9	pH
22-APR-03	TUESDAY	1_Hr_COMP	1255	Specific Conductance	6900	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1255	pH	7.8	pH
22-APR-03	TUESDAY	1_Hr_COMP	1355	Specific Conductance	6900	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1355	pH	7.8	pH
22-APR-03	TUESDAY	1_Hr_COMP	1455	Specific Conductance	6900	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1455	pH	7.9	pH
22-APR-03	TUESDAY	1_Hr_COMP	1555	Specific Conductance	6300	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1555	pH	7.8	pH
22-APR-03	TUESDAY	1_Hr_COMP	1655	Specific Conductance	6400	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1655	pH	7.7	pH
22-APR-03	TUESDAY	1_Hr_COMP	1755	Specific Conductance	6300	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1755	pH	7.6	pH
22-APR-03	TUESDAY	1_Hr_COMP	1855	Specific Conductance	6300	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1855	pH	7.5	pH
22-APR-03	TUESDAY	1_Hr_COMP	1955	Specific Conductance	6000	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	1955	pH	7.6	pH
22-APR-03	TUESDAY	1_Hr_COMP	2055	Specific Conductance	6300	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2055	pH	7.5	pH
22-APR-03	TUESDAY	1_Hr_COMP	2155	Specific Conductance	5100	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2155	pH	7.6	pH
22-APR-03	TUESDAY	1_Hr_COMP	2255	Specific Conductance	4900	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2255	pH	7.6	pH
22-APR-03	TUESDAY	1_Hr_COMP	2355	Specific Conductance	6100	umhos/cm
22-APR-03	TUESDAY	1_Hr_COMP	2355	pH	7.5	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	55	Specific Conductance	5200	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	55	pH	7.6	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	155	Specific Conductance	5700	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	155	pH	7.4	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	255	Specific Conductance	5500	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	255	pH	7.4	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	355	Specific Conductance	6300	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	355	pH	7.4	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	455	Specific Conductance	5200	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	455	pH	7.4	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	555	Specific Conductance	4700	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	555	pH	7.5	pH
23-APR-03	WEDNESDAY	1_Hr_COMP	655	Specific Conductance	6700	umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	655	pH	7.4	pH

City of Mexicali
Site 9

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
23-APR-03	WEDNESDAY	1_Hr_COMP	755 Specific Conductance	6500 umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	755 pH	7.3 pH
23-APR-03	WEDNESDAY	1_Hr_COMP	855 Specific Conductance	5900 umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	855 pH	7.4 pH
23-APR-03	WEDNESDAY	1_Hr_COMP	955 Specific Conductance	5900 umhos/cm
23-APR-03	WEDNESDAY	1_Hr_COMP	955 pH	7.3 pH
23-APR-03	WEDNESDAY	COMP_CONDUCT	1152 Specific Conductance	5900 umhos/cm
23-APR-03	WEDNESDAY	COMP_PH	1152 pH	7.7 pH
23-APR-03	WEDNESDAY	GRAB	1200 Specific Conductance	4600 umhos/cm
23-APR-03	WEDNESDAY	GRAB	1200 pH	7.2 pH

SITE 10

**(NO SAMPLES COLLECTED AT
THIS SITE)**

SITE 11

City of Mexicali
Site 11

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
30-APR-03	WEDNESDAY	1_Hr_COMP	1350 Specific Conductance	6400 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1350 pH	7.9 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1450 Specific Conductance	6400 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1450 pH	7.9 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1550 Specific Conductance	6300 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1550 pH	8.2 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1650 Specific Conductance	4100 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1650 pH	8.2 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1750 Specific Conductance	4600 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1750 pH	8.1 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1850 Specific Conductance	2200 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1850 pH	8.2 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1950 Specific Conductance	2300 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1950 pH	8.1 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	2050 Specific Conductance	2400 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	2050 pH	8 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	2150 Specific Conductance	2500 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	2150 pH	8 pH
01-MAY-03	THURSDAY	1_Hr_COMP	150 Specific Conductance	2000 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	150 pH	8.1 pH
01-MAY-03	THURSDAY	1_Hr_COMP	250 Specific Conductance	3000 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	250 pH	8 pH
01-MAY-03	THURSDAY	1_Hr_COMP	350 Specific Conductance	4600 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	350 pH	8.5 pH
01-MAY-03	THURSDAY	1_Hr_COMP	450 Specific Conductance	2400 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	450 pH	8.3 pH
01-MAY-03	THURSDAY	1_Hr_COMP	550 Specific Conductance	3500 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	550 pH	8.2 pH
01-MAY-03	THURSDAY	1_Hr_COMP	650 Specific Conductance	2800 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	650 pH	8.2 pH
01-MAY-03	THURSDAY	1_Hr_COMP	750 Specific Conductance	2000 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	750 pH	8.2 pH
01-MAY-03	THURSDAY	1_Hr_COMP	850 Specific Conductance	2300 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	850 pH	8.2 pH
01-MAY-03	THURSDAY	1_Hr_COMP	950 Specific Conductance	3500 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	950 pH	8.1 pH
01-MAY-03	THURSDAY	COMP_CONDUCT	1025 Specific Conductance	3400 umhos/cm
01-MAY-03	THURSDAY	COMP_PH	1025 pH	8.2 pH
01-MAY-03	THURSDAY	GRAB	1030 Specific Conductance	6100 umhos/cm
01-MAY-03	THURSDAY	GRAB	1030 pH	7.4 pH
01-MAY-03	THURSDAY	1_Hr_COMP	1050 Specific Conductance	2200 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	1050 pH	8.2 pH
01-MAY-03	THURSDAY	1_Hr_COMP	1150 Specific Conductance	2300 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	1150 pH	8.1 pH
01-MAY-03	THURSDAY	1_Hr_COMP	1250 Specific Conductance	2600 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	1250 pH	8.1 pH
08-MAY-03	THURSDAY	1_Hr_COMP	910 Specific Conductance	5200 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	910 pH	7.6 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1010 Specific Conductance	6600 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1010 pH	8 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1110 Specific Conductance	6700 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1110 pH	8.3 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1210 Specific Conductance	6700 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1210 pH	8.3 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1310 Specific Conductance	6800 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1310 pH	8.4 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1410 Specific Conductance	6700 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1410 pH	8.4 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1510 Specific Conductance	6500 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1510 pH	8.3 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1610 Specific Conductance	6700 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1610 pH	8.4 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1710 Specific Conductance	6800 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1710 pH	8.3 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1810 Specific Conductance	6800 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1810 pH	8.3 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1910 Specific Conductance	6600 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1910 pH	8.4 pH
08-MAY-03	THURSDAY	1_Hr_COMP	2010 Specific Conductance	5300 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	2010 pH	8 pH
08-MAY-03	THURSDAY	1_Hr_COMP	2110 Specific Conductance	5500 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	2110 pH	7.9 pH
08-MAY-03	THURSDAY	1_Hr_COMP	2210 Specific Conductance	5900 umhos/cm

City of Mexicali
Site 11

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
08-MAY-03	THURSDAY	1_Hr_COMP	2210	pH	8	pH
08-MAY-03	THURSDAY	1_Hr_COMP	2310	Specific Conductance	6100	umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	2310	pH	7.9	pH
09-MAY-03	FRIDAY	1_Hr_COMP	10	Specific Conductance	6200	umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	10	pH	7.9	pH
09-MAY-03	FRIDAY	1_Hr_COMP	110	Specific Conductance	6300	umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	110	pH	7.9	pH
09-MAY-03	FRIDAY	1_Hr_COMP	210	Specific Conductance	6500	umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	210	pH	7.9	pH
09-MAY-03	FRIDAY	1_Hr_COMP	310	Specific Conductance	6500	umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	310	pH	7.7	pH
09-MAY-03	FRIDAY	1_Hr_COMP	410	Specific Conductance	6400	umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	410	pH	7.7	pH
09-MAY-03	FRIDAY	1_Hr_COMP	510	Specific Conductance	6400	umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	510	pH	7.6	pH
09-MAY-03	FRIDAY	1_Hr_COMP	610	Specific Conductance	6400	umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	610	pH	7.8	pH
09-MAY-03	FRIDAY	1_Hr_COMP	710	Specific Conductance	6500	umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	710	pH	7.6	pH
09-MAY-03	FRIDAY	1_Hr_COMP	810	Specific Conductance	6400	umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	810	pH	7.7	pH
09-MAY-03	FRIDAY	COMP_CONDUCT	940	Specific Conductance	6100	umhos/cm
09-MAY-03	FRIDAY	COMP_PH	940	pH	7.9	pH
09-MAY-03	FRIDAY	GRAB	945	Specific Conductance	6900	umhos/cm
09-MAY-03	FRIDAY	GRAB	945	pH	7.2	pH
16-MAY-03	FRIDAY	1_Hr_COMP	910	Specific Conductance	4600	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	910	pH	7.3	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1010	Specific Conductance	5300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1010	pH	7.5	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1110	Specific Conductance	5200	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1110	pH	7.5	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1210	Specific Conductance	5200	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1210	pH	7.5	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1310	Specific Conductance	4900	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1310	pH	7.5	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1410	Specific Conductance	5300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1410	pH	8	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1510	Specific Conductance	5400	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1510	pH	7.9	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1610	Specific Conductance	5800	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1610	pH	7.9	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1710	Specific Conductance	5500	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1710	pH	7.8	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1810	Specific Conductance	5400	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1810	pH	8.1	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1910	Specific Conductance	5600	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1910	pH	8.1	pH
16-MAY-03	FRIDAY	1_Hr_COMP	2010	Specific Conductance	5700	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2010	pH	8.1	pH
16-MAY-03	FRIDAY	1_Hr_COMP	2110	Specific Conductance	5900	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2110	pH	8	pH
16-MAY-03	FRIDAY	1_Hr_COMP	2210	Specific Conductance	5800	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2210	pH	7.8	pH
16-MAY-03	FRIDAY	1_Hr_COMP	2310	Specific Conductance	5900	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2310	pH	7.9	pH
17-MAY-03	SATURDAY	COMP_CONDUCT	915	Specific Conductance	5100	umhos/cm
17-MAY-03	SATURDAY	COMP_PH	915	pH	7.9	pH
17-MAY-03	SATURDAY	GRAB	920	Specific Conductance	5600	umhos/cm
17-MAY-03	SATURDAY	GRAB	920	pH	7.8	pH
24-MAY-03	SATURDAY	1_Hr_COMP	855	Specific Conductance	4900	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	855	pH	8	pH
24-MAY-03	SATURDAY	1_Hr_COMP	955	Specific Conductance	5100	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	955	pH	8.1	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1055	Specific Conductance	5100	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1055	pH	8.2	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1155	Specific Conductance	5100	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1155	pH	8.3	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1255	Specific Conductance	5100	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1255	pH	8.2	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1355	Specific Conductance	5100	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1355	pH	8.1	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1455	Specific Conductance	5100	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1455	pH	8.2	pH

City of Mexicali
Site 11

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
24-MAY-03	SATURDAY	1_Hr_COMP	1555 Specific Conductance	5100 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1555 pH	8.1 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1655 Specific Conductance	5000 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1655 pH	8 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1755 Specific Conductance	5000 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1755 pH	7.9 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1855 Specific Conductance	2500 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1855 pH	7.9 pH
24-MAY-03	SATURDAY	1_Hr_COMP	1955 Specific Conductance	2500 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1955 pH	7.9 pH
24-MAY-03	SATURDAY	1_Hr_COMP	2055 Specific Conductance	2600 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2055 pH	7.9 pH
24-MAY-03	SATURDAY	1_Hr_COMP	2155 Specific Conductance	2700 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2155 pH	7.9 pH
24-MAY-03	SATURDAY	1_Hr_COMP	2255 Specific Conductance	2700 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2255 pH	7.9 pH
24-MAY-03	SATURDAY	1_Hr_COMP	2355 Specific Conductance	2600 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2355 pH	7.9 pH
25-MAY-03	SUNDAY	1_Hr_COMP	55 Specific Conductance	2600 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	55 pH	7.9 pH
25-MAY-03	SUNDAY	1_Hr_COMP	155 Specific Conductance	2500 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	155 pH	7.9 pH
25-MAY-03	SUNDAY	1_Hr_COMP	255 Specific Conductance	2400 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	255 pH	7.9 pH
25-MAY-03	SUNDAY	1_Hr_COMP	355 Specific Conductance	2400 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	355 pH	7.9 pH
25-MAY-03	SUNDAY	1_Hr_COMP	455 Specific Conductance	2300 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	455 pH	7.9 pH
25-MAY-03	SUNDAY	1_Hr_COMP	555 Specific Conductance	2600 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	555 pH	7.9 pH
25-MAY-03	SUNDAY	1_Hr_COMP	655 Specific Conductance	2600 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	655 pH	8 pH
25-MAY-03	SUNDAY	1_Hr_COMP	755 Specific Conductance	2100 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	755 pH	8 pH
25-MAY-03	SUNDAY	COMP_CONDUCT	915 Specific Conductance	2400 umhos/cm
25-MAY-03	SUNDAY	COMP_PH	915 pH	8.2 pH
25-MAY-03	SUNDAY	GRAB	920 Specific Conductance	4800 umhos/cm
25-MAY-03	SUNDAY	GRAB	920 pH	7.6 pH
01-JUN-03	SUNDAY	1_Hr_COMP	935 Specific Conductance	3000 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	935 pH	7.2 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1035 Specific Conductance	2400 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1035 pH	7.3 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1135 Specific Conductance	2400 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1135 pH	7.3 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1235 Specific Conductance	2500 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1235 pH	7.3 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1335 Specific Conductance	2500 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1335 pH	7.3 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1435 Specific Conductance	2500 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1435 pH	7.2 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1535 Specific Conductance	2500 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1535 pH	7.3 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1635 Specific Conductance	2600 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1635 pH	7.3 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1735 Specific Conductance	2600 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1735 pH	7.6 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1835 Specific Conductance	2600 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1835 pH	7.5 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1935 Specific Conductance	2900 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1935 pH	7.5 pH
01-JUN-03	SUNDAY	1_Hr_COMP	2035 Specific Conductance	3800 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2035 pH	7.4 pH
01-JUN-03	SUNDAY	1_Hr_COMP	2135 Specific Conductance	4300 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2135 pH	7.4 pH
01-JUN-03	SUNDAY	1_Hr_COMP	2235 Specific Conductance	4400 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2235 pH	7.4 pH
01-JUN-03	SUNDAY	1_Hr_COMP	2335 Specific Conductance	4400 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2335 pH	7.4 pH
02-JUN-03	MONDAY	1_Hr_COMP	35 Specific Conductance	4500 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	35 pH	7.3 pH
02-JUN-03	MONDAY	1_Hr_COMP	135 Specific Conductance	4400 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	135 pH	7.4 pH
02-JUN-03	MONDAY	1_Hr_COMP	235 Specific Conductance	4500 umhos/cm

City of Mexicali
Site 11

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
02-JUN-03	MONDAY	1_Hr_COMP	235 pH	7.4 pH
02-JUN-03	MONDAY	1_Hr_COMP	345 Specific Conductance	4400 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	345 pH	7.3 pH
02-JUN-03	MONDAY	1_Hr_COMP	435 Specific Conductance	4600 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	435 pH	7.3 pH
02-JUN-03	MONDAY	1_Hr_COMP	535 Specific Conductance	4500 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	535 pH	7.3 pH
02-JUN-03	MONDAY	1_Hr_COMP	635 Specific Conductance	4500 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	635 pH	7.3 pH
02-JUN-03	MONDAY	1_Hr_COMP	735 Specific Conductance	4500 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	735 pH	7.3 pH
02-JUN-03	MONDAY	1_Hr_COMP	835 Specific Conductance	4600 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	835 pH	7.2 pH
02-JUN-03	MONDAY	COMP_CONDUCT	1035 Specific Conductance	4000 umhos/cm
02-JUN-03	MONDAY	COMP_PH	1035 pH	7.4 pH
02-JUN-03	MONDAY	GRAB	1040 Specific Conductance	4400 umhos/cm
02-JUN-03	MONDAY	GRAB	1040 pH	7.5 pH
09-JUN-03	MONDAY	1_Hr_COMP	920 Specific Conductance	4600 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	920 pH	8.1 pH
09-JUN-03	MONDAY	1_Hr_COMP	1020 Specific Conductance	4500 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1020 pH	8.3 pH
09-JUN-03	MONDAY	1_Hr_COMP	1120 Specific Conductance	4600 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1120 pH	8.2 pH
09-JUN-03	MONDAY	1_Hr_COMP	1220 Specific Conductance	4500 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1220 pH	8.2 pH
09-JUN-03	MONDAY	1_Hr_COMP	1320 Specific Conductance	4400 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1320 pH	8.2 pH
09-JUN-03	MONDAY	1_Hr_COMP	1420 Specific Conductance	4400 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1420 pH	8.3 pH
09-JUN-03	MONDAY	1_Hr_COMP	1520 Specific Conductance	4400 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1520 pH	8.2 pH
09-JUN-03	MONDAY	1_Hr_COMP	1620 Specific Conductance	4300 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1620 pH	8.2 pH
09-JUN-03	MONDAY	1_Hr_COMP	1720 Specific Conductance	4200 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1720 pH	8 pH
09-JUN-03	MONDAY	1_Hr_COMP	1820 Specific Conductance	4200 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1820 pH	8 pH
09-JUN-03	MONDAY	1_Hr_COMP	1920 Specific Conductance	4200 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1920 pH	8 pH
09-JUN-03	MONDAY	1_Hr_COMP	2020 Specific Conductance	4200 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	2020 pH	7.9 pH
09-JUN-03	MONDAY	1_Hr_COMP	2120 Specific Conductance	4200 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	2120 pH	7.8 pH
09-JUN-03	MONDAY	1_Hr_COMP	2220 Specific Conductance	4200 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	2220 pH	7.7 pH
09-JUN-03	MONDAY	1_Hr_COMP	2320 Specific Conductance	4200 umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	2320 pH	7.8 pH
10-JUN-03	TUESDAY	1_Hr_COMP	20 Specific Conductance	4400 umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	20 pH	7.7 pH
10-JUN-03	TUESDAY	1_Hr_COMP	120 Specific Conductance	4400 umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	120 pH	7.7 pH
10-JUN-03	TUESDAY	1_Hr_COMP	220 Specific Conductance	4400 umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	220 pH	7.7 pH
10-JUN-03	TUESDAY	1_Hr_COMP	320 Specific Conductance	4500 umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	320 pH	7.7 pH
10-JUN-03	TUESDAY	1_Hr_COMP	420 Specific Conductance	4300 umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	420 pH	7.7 pH
10-JUN-03	TUESDAY	1_Hr_COMP	520 Specific Conductance	4400 umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	520 pH	7.7 pH
10-JUN-03	TUESDAY	1_Hr_COMP	620 Specific Conductance	4500 umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	620 pH	7.7 pH
10-JUN-03	TUESDAY	1_Hr_COMP	720 Specific Conductance	4600 umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	720 pH	7.7 pH
10-JUN-03	TUESDAY	1_Hr_COMP	820 Specific Conductance	4500 umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	820 pH	7.6 pH
10-JUN-03	TUESDAY	COMP_CONDUCT	1025 Specific Conductance	4400 umhos/cm
10-JUN-03	TUESDAY	COMP_PH	1025 pH	7.8 pH
10-JUN-03	TUESDAY	GRAB	1030 Specific Conductance	4300 umhos/cm
10-JUN-03	TUESDAY	GRAB	1030 pH	7.4 pH

SITE 12

City of Mexicali
Site 12

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
30-APR-03	WEDNESDAY	1_Hr_COMP	1100 Specific Conductance	1900 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1100 pH	7.6 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1200 Specific Conductance	1900 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1200 pH	7.6 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1300 Specific Conductance	1800 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1300 pH	7.6 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1400 Specific Conductance	1800 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1400 pH	7.7 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1500 Specific Conductance	1900 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1500 pH	7.7 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1600 Specific Conductance	1900 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1600 pH	7.7 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1700 Specific Conductance	1900 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1700 pH	7.7 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1900 Specific Conductance	2100 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1900 pH	7.7 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	2000 Specific Conductance	2100 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	2000 pH	7.3 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	2100 Specific Conductance	2000 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	2100 pH	7.4 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	2200 Specific Conductance	2000 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	2200 pH	7.4 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	2300 Specific Conductance	2000 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	2300 pH	7.5 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	2400 Specific Conductance	2000 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	2400 pH	7.5 pH
01-MAY-03	THURSDAY	1_Hr_COMP	100 Specific Conductance	2000 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	100 pH	7.5 pH
01-MAY-03	THURSDAY	1_Hr_COMP	200 Specific Conductance	1900 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	200 pH	7.3 pH
01-MAY-03	THURSDAY	1_Hr_COMP	300 Specific Conductance	1900 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	300 pH	7.4 pH
01-MAY-03	THURSDAY	1_Hr_COMP	400 Specific Conductance	2000 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	400 pH	7.3 pH
01-MAY-03	THURSDAY	1_Hr_COMP	500 Specific Conductance	2000 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	500 pH	7.3 pH
01-MAY-03	THURSDAY	1_Hr_COMP	600 Specific Conductance	2000 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	600 pH	7.3 pH
01-MAY-03	THURSDAY	1_Hr_COMP	700 Specific Conductance	2000 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	700 pH	7.4 pH
01-MAY-03	THURSDAY	1_Hr_COMP	800 Specific Conductance	2000 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	800 pH	7.4 pH
01-MAY-03	THURSDAY	1_Hr_COMP	900 Specific Conductance	2000 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	900 pH	7.4 pH
01-MAY-03	THURSDAY	COMP_CONDUCT	955 Specific Conductance	2000 umhos/cm
01-MAY-03	THURSDAY	COMP_PH	955 pH	7.5 pH
01-MAY-03	THURSDAY	1_Hr_COMP	1000 Specific Conductance	1900 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	1000 pH	7.4 pH
01-MAY-03	THURSDAY	GRAB	1000 Specific Conductance	2100 umhos/cm
01-MAY-03	THURSDAY	GRAB	1000 pH	7.5 pH
08-MAY-03	THURSDAY	1_Hr_COMP	930 Specific Conductance	2200 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	930 pH	7.1 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1030 Specific Conductance	2100 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1030 pH	7.2 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1130 Specific Conductance	2100 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1130 pH	7.3 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1230 Specific Conductance	2100 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1230 pH	7.2 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1330 Specific Conductance	2100 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1330 pH	7.1 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1430 Specific Conductance	2100 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1430 pH	7.1 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1530 Specific Conductance	2100 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1530 pH	7.2 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1630 Specific Conductance	2000 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1630 pH	7 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1730 Specific Conductance	2000 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1730 pH	7.1 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1830 Specific Conductance	2000 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1830 pH	7.2 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1930 Specific Conductance	2100 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1930 pH	7.2 pH
08-MAY-03	THURSDAY	1_Hr_COMP	2030 Specific Conductance	2000 umhos/cm

City of Mexicali
Site 12

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
08-MAY-03	THURSDAY	1_Hr_COMP	2030	pH	7.3	pH
08-MAY-03	THURSDAY	1_Hr_COMP	2130	Specific Conductance	2000	umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	2130	pH	7.2	pH
08-MAY-03	THURSDAY	1_Hr_COMP	2230	Specific Conductance	2000	umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	2230	pH	7.3	pH
08-MAY-03	THURSDAY	1_Hr_COMP	2330	Specific Conductance	2000	umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	2330	pH	7.2	pH
09-MAY-03	FRIDAY	1_Hr_COMP	30	Specific Conductance	1900	umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	30	pH	7.3	pH
09-MAY-03	FRIDAY	1_Hr_COMP	130	Specific Conductance	1900	umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	130	pH	7.3	pH
09-MAY-03	FRIDAY	1_Hr_COMP	230	Specific Conductance	1900	umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	230	pH	7.4	pH
09-MAY-03	FRIDAY	1_Hr_COMP	330	Specific Conductance	1800	umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	330	pH	7.4	pH
09-MAY-03	FRIDAY	1_Hr_COMP	430	Specific Conductance	1800	umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	430	pH	7.5	pH
09-MAY-03	FRIDAY	1_Hr_COMP	530	Specific Conductance	1800	umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	530	pH	7.5	pH
09-MAY-03	FRIDAY	1_Hr_COMP	630	Specific Conductance	1800	umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	630	pH	7.5	pH
09-MAY-03	FRIDAY	1_Hr_COMP	730	Specific Conductance	2000	umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	730	pH	7.6	pH
09-MAY-03	FRIDAY	1_Hr_COMP	830	Specific Conductance	2000	umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	830	pH	7.5	pH
09-MAY-03	FRIDAY	COMP_CONDUCT	1005	Specific Conductance	2000	umhos/cm
09-MAY-03	FRIDAY	COMP_PH	1005	pH	7.2	pH
09-MAY-03	FRIDAY	GRAB	1010	Specific Conductance	2000	umhos/cm
09-MAY-03	FRIDAY	GRAB	1010	pH	7.3	pH
16-MAY-03	FRIDAY	1_Hr_COMP	930	Specific Conductance	2600	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	930	pH	7	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1030	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1030	pH	7.3	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1130	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1130	pH	7.2	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1230	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1230	pH	7.2	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1330	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1330	pH	7.2	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1430	Specific Conductance	2200	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1430	pH	7.2	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1530	Specific Conductance	2200	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1530	pH	7.3	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1630	Specific Conductance	2200	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1630	pH	7.2	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1730	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1730	pH	7.2	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1930	Specific Conductance	2200	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1930	pH	7.3	pH
16-MAY-03	FRIDAY	1_Hr_COMP	2030	Specific Conductance	3400	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2030	pH	7.4	pH
16-MAY-03	FRIDAY	1_Hr_COMP	2130	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2130	pH	7.3	pH
16-MAY-03	FRIDAY	1_Hr_COMP	2230	Specific Conductance	2100	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2230	pH	7.2	pH
16-MAY-03	FRIDAY	1_Hr_COMP	2330	Specific Conductance	2100	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2330	pH	7.3	pH
17-MAY-03	SATURDAY	1_Hr_COMP	30	Specific Conductance	2100	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	30	pH	7.2	pH
17-MAY-03	SATURDAY	1_Hr_COMP	130	Specific Conductance	2100	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	130	pH	7.3	pH
17-MAY-03	SATURDAY	1_Hr_COMP	230	Specific Conductance	2000	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	230	pH	7.3	pH
17-MAY-03	SATURDAY	1_Hr_COMP	330	Specific Conductance	2000	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	330	pH	7.3	pH
17-MAY-03	SATURDAY	1_Hr_COMP	430	Specific Conductance	2000	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	430	pH	7.4	pH
17-MAY-03	SATURDAY	1_Hr_COMP	530	Specific Conductance	2000	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	530	pH	7.4	pH
17-MAY-03	SATURDAY	1_Hr_COMP	630	Specific Conductance	4700	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	630	pH	7.4	pH
17-MAY-03	SATURDAY	1_Hr_COMP	730	Specific Conductance	2400	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	730	pH	7.4	pH

City of Mexicali
Site 12

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE	UNITS
17-MAY-03	SATURDAY	1_Hr_COMP	830 Specific Conductance	2400	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	830 pH	7.4	pH
17-MAY-03	SATURDAY	COMP_CONDUCT	945 Specific Conductance	2300	umhos/cm
17-MAY-03	SATURDAY	COMP_PH	945 pH	7.3	pH
17-MAY-03	SATURDAY	GRAB	950 Specific Conductance	2200	umhos/cm
17-MAY-03	SATURDAY	GRAB	950 pH	7.2	pH
24-MAY-03	SATURDAY	1_Hr_COMP	913 Specific Conductance	2500	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	913 pH	7.3	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1013 Specific Conductance	2300	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1013 pH	7.4	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1113 Specific Conductance	2200	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1113 pH	7.5	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1213 Specific Conductance	2300	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1213 pH	7.4	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1313 Specific Conductance	2300	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1313 pH	7.3	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1413 Specific Conductance	2300	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1413 pH	7.3	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1513 Specific Conductance	2200	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1513 pH	7.2	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1613 Specific Conductance	2200	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1613 pH	7.1	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1713 Specific Conductance	2100	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1713 pH	7.1	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1813 Specific Conductance	2100	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1813 pH	7.6	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1913 Specific Conductance	2100	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1913 pH	7.4	pH
24-MAY-03	SATURDAY	1_Hr_COMP	2013 Specific Conductance	2300	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2013 pH	7.6	pH
24-MAY-03	SATURDAY	1_Hr_COMP	2113 Specific Conductance	2300	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2113 pH	7.6	pH
24-MAY-03	SATURDAY	1_Hr_COMP	2213 Specific Conductance	2200	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2213 pH	7.7	pH
24-MAY-03	SATURDAY	1_Hr_COMP	2313 Specific Conductance	2200	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2313 pH	7.7	pH
25-MAY-03	SUNDAY	1_Hr_COMP	13 Specific Conductance	2000	umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	13 pH	7.7	pH
25-MAY-03	SUNDAY	1_Hr_COMP	113 Specific Conductance	2100	umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	113 pH	7.7	pH
25-MAY-03	SUNDAY	1_Hr_COMP	213 Specific Conductance	2000	umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	213 pH	7.7	pH
25-MAY-03	SUNDAY	1_Hr_COMP	713 Specific Conductance	2000	umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	713 pH	7.7	pH
25-MAY-03	SUNDAY	1_Hr_COMP	813 Specific Conductance	2000	umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	813 pH	7.8	pH
25-MAY-03	SUNDAY	COMP_CONDUCT	935 Specific Conductance	2200	umhos/cm
25-MAY-03	SUNDAY	COMP_PH	935 pH	7.5	pH
25-MAY-03	SUNDAY	GRAB	940 Specific Conductance	2100	umhos/cm
25-MAY-03	SUNDAY	GRAB	940 pH	7.5	pH
01-JUN-03	SUNDAY	1_Hr_COMP	950 Specific Conductance	2100	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	950 pH	7.3	pH
01-JUN-03	SUNDAY	1_Hr_COMP	1050 Specific Conductance	2100	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1050 pH	7.5	pH
01-JUN-03	SUNDAY	1_Hr_COMP	1150 Specific Conductance	2100	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1150 pH	7.5	pH
01-JUN-03	SUNDAY	1_Hr_COMP	1250 Specific Conductance	2200	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1250 pH	7.4	pH
01-JUN-03	SUNDAY	1_Hr_COMP	1350 Specific Conductance	2200	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1350 pH	7.3	pH
01-JUN-03	SUNDAY	1_Hr_COMP	1450 Specific Conductance	2100	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1450 pH	7.4	pH
01-JUN-03	SUNDAY	1_Hr_COMP	1550 Specific Conductance	2100	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1550 pH	7.4	pH
01-JUN-03	SUNDAY	1_Hr_COMP	1650 Specific Conductance	2200	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1650 pH	7.4	pH
01-JUN-03	SUNDAY	1_Hr_COMP	1750 Specific Conductance	2100	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1750 pH	7.5	pH
01-JUN-03	SUNDAY	1_Hr_COMP	1850 Specific Conductance	2000	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1850 pH	7.4	pH
01-JUN-03	SUNDAY	1_Hr_COMP	1950 Specific Conductance	2200	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1950 pH	7.4	pH
01-JUN-03	SUNDAY	1_Hr_COMP	2050 Specific Conductance	2100	umhos/cm

City of Mexicali
Site 12

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
01-JUN-03	SUNDAY	1_Hr_COMP	2050	pH	7.3	pH
01-JUN-03	SUNDAY	1_Hr_COMP	2150	Specific Conductance	2100	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2150	pH	7.5	pH
01-JUN-03	SUNDAY	1_Hr_COMP	2250	Specific Conductance	2100	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2250	pH	7.5	pH
01-JUN-03	SUNDAY	1_Hr_COMP	2350	Specific Conductance	2100	umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2350	pH	7.3	pH
02-JUN-03	MONDAY	1_Hr_COMP	50	Specific Conductance	1900	umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	50	pH	7.5	pH
02-JUN-03	MONDAY	1_Hr_COMP	150	Specific Conductance	1900	umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	150	pH	7.4	pH
02-JUN-03	MONDAY	1_Hr_COMP	250	Specific Conductance	1900	umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	250	pH	7.5	pH
02-JUN-03	MONDAY	1_Hr_COMP	350	Specific Conductance	2000	umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	350	pH	7.6	pH
02-JUN-03	MONDAY	1_Hr_COMP	450	Specific Conductance	1900	umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	450	pH	7.5	pH
02-JUN-03	MONDAY	1_Hr_COMP	550	Specific Conductance	1900	umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	550	pH	7.5	pH
02-JUN-03	MONDAY	1_Hr_COMP	650	Specific Conductance	2300	umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	650	pH	7.5	pH
02-JUN-03	MONDAY	1_Hr_COMP	750	Specific Conductance	1900	umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	750	pH	7.5	pH
02-JUN-03	MONDAY	1_Hr_COMP	850	Specific Conductance	2000	umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	850	pH	7.5	pH
02-JUN-03	MONDAY	COMP_CONDUCT	1105	Specific Conductance	2100	umhos/cm
02-JUN-03	MONDAY	COMP_PH	1105	pH	7.6	pH
02-JUN-03	MONDAY	GRAB	1115	Specific Conductance	2300	umhos/cm
02-JUN-03	MONDAY	GRAB	1115	pH	7.3	pH
09-JUN-03	MONDAY	1_Hr_COMP	1003	Specific Conductance	2000	umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1003	pH	7.3	pH
09-JUN-03	MONDAY	1_Hr_COMP	1103	Specific Conductance	2000	umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1103	pH	7.4	pH
09-JUN-03	MONDAY	1_Hr_COMP	1203	Specific Conductance	2000	umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1203	pH	7.3	pH
09-JUN-03	MONDAY	1_Hr_COMP	1303	Specific Conductance	2000	umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1303	pH	7.2	pH
09-JUN-03	MONDAY	1_Hr_COMP	1403	Specific Conductance	2000	umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1403	pH	7.2	pH
09-JUN-03	MONDAY	1_Hr_COMP	1503	Specific Conductance	2000	umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1503	pH	7.2	pH
09-JUN-03	MONDAY	1_Hr_COMP	1603	Specific Conductance	2000	umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1603	pH	7.4	pH
09-JUN-03	MONDAY	1_Hr_COMP	1703	Specific Conductance	2400	umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1703	pH	7.2	pH
09-JUN-03	MONDAY	1_Hr_COMP	1803	Specific Conductance	2000	umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1803	pH	7.2	pH
09-JUN-03	MONDAY	1_Hr_COMP	1903	Specific Conductance	2000	umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	1903	pH	7.2	pH
09-JUN-03	MONDAY	1_Hr_COMP	2003	Specific Conductance	2000	umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	2003	pH	7.2	pH
09-JUN-03	MONDAY	1_Hr_COMP	2103	Specific Conductance	2000	umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	2103	pH	7.2	pH
09-JUN-03	MONDAY	1_Hr_COMP	2203	Specific Conductance	2000	umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	2203	pH	7.2	pH
09-JUN-03	MONDAY	1_Hr_COMP	2303	Specific Conductance	2100	umhos/cm
09-JUN-03	MONDAY	1_Hr_COMP	2303	pH	7.3	pH
10-JUN-03	TUESDAY	1_Hr_COMP	3	Specific Conductance	2100	umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	3	pH	7.3	pH
10-JUN-03	TUESDAY	1_Hr_COMP	103	Specific Conductance	2100	umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	103	pH	7.4	pH
10-JUN-03	TUESDAY	1_Hr_COMP	203	Specific Conductance	2100	umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	203	pH	7.3	pH
10-JUN-03	TUESDAY	1_Hr_COMP	303	Specific Conductance	2000	umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	303	pH	7.2	pH
10-JUN-03	TUESDAY	1_Hr_COMP	403	Specific Conductance	1900	umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	403	pH	7.3	pH
10-JUN-03	TUESDAY	1_Hr_COMP	503	Specific Conductance	1800	umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	503	pH	7.3	pH
10-JUN-03	TUESDAY	1_Hr_COMP	603	Specific Conductance	1900	umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	603	pH	7	pH
10-JUN-03	TUESDAY	1_Hr_COMP	703	Specific Conductance	2800	umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	703	pH	7.3	pH

City of Mexicali
Site 12

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
10-JUN-03	TUESDAY	1_Hr_COMP	803 Specific Conductance	2000 umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	803 pH	7.5 pH
10-JUN-03	TUESDAY	1_Hr_COMP	903 Specific Conductance	2000 umhos/cm
10-JUN-03	TUESDAY	1_Hr_COMP	903 pH	7.5 pH
10-JUN-03	TUESDAY	COMP_CONDUCT	1050 Specific Conductance	2100 umhos/cm
10-JUN-03	TUESDAY	COMP_PH	1050 pH	7.5 pH
10-JUN-03	TUESDAY	GRAB	1100 Specific Conductance	2100 umhos/cm
10-JUN-03	TUESDAY	GRAB	1100 pH	7.4 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1050 Specific Conductance	1800 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1050 pH	6.2 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1150 Specific Conductance	1900 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1150 pH	6 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1250 Specific Conductance	1900 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1250 pH	6 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1350 Specific Conductance	2200 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1350 pH	5.8 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1450 Specific Conductance	2500 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1450 pH	5.7 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1550 Specific Conductance	2100 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1550 pH	5.8 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1650 Specific Conductance	2000 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1650 pH	5.8 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1750 Specific Conductance	2100 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1750 pH	5.7 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1850 Specific Conductance	2100 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1850 pH	5.7 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1950 Specific Conductance	2100 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1950 pH	5.7 pH
17-JUN-03	TUESDAY	1_Hr_COMP	2050 Specific Conductance	2100 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	2050 pH	5.7 pH
17-JUN-03	TUESDAY	1_Hr_COMP	2150 Specific Conductance	2000 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	2150 pH	5.6 pH
17-JUN-03	TUESDAY	1_Hr_COMP	2250 Specific Conductance	1900 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	2250 pH	5.7 pH
18-JUN-03	WEDNESDAY	GRAB	1025 Specific Conductance	2000 umhos/cm
18-JUN-03	WEDNESDAY	GRAB	1025 pH	5.3 pH

SITE 13

City of Mexicali
Site 13

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
30-APR-03	WEDNESDAY	1_Hr_COMP	1233 Specific Conductance	2900 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1233 pH	7.8 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1333 Specific Conductance	2100 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1333 pH	7.7 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1433 Specific Conductance	2500 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1433 pH	7.7 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1533 Specific Conductance	2200 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1533 pH	7.7 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1633 Specific Conductance	2100 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1633 pH	7.7 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1733 Specific Conductance	2200 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1733 pH	7.7 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1833 Specific Conductance	2200 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1833 pH	7.7 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1933 Specific Conductance	2100 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1933 pH	7.7 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	2033 Specific Conductance	2100 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	2033 pH	7.7 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	2133 Specific Conductance	2100 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	2133 pH	7.7 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	2233 Specific Conductance	2200 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	2233 pH	7.8 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	2333 Specific Conductance	2200 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	2333 pH	7.8 pH
01-MAY-03	THURSDAY	1_Hr_COMP	33 Specific Conductance	2300 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	33 pH	7.8 pH
01-MAY-03	THURSDAY	1_Hr_COMP	133 Specific Conductance	2200 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	133 pH	7.8 pH
01-MAY-03	THURSDAY	1_Hr_COMP	233 Specific Conductance	2300 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	233 pH	7.8 pH
01-MAY-03	THURSDAY	1_Hr_COMP	333 Specific Conductance	2300 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	333 pH	7.9 pH
01-MAY-03	THURSDAY	1_Hr_COMP	433 Specific Conductance	2300 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	433 pH	7.9 pH
01-MAY-03	THURSDAY	1_Hr_COMP	533 Specific Conductance	2300 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	533 pH	8 pH
01-MAY-03	THURSDAY	1_Hr_COMP	633 Specific Conductance	2300 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	633 pH	8 pH
01-MAY-03	THURSDAY	1_Hr_COMP	733 Specific Conductance	2400 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	733 pH	8 pH
01-MAY-03	THURSDAY	1_Hr_COMP	833 Specific Conductance	2300 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	833 pH	7.9 pH
01-MAY-03	THURSDAY	1_Hr_COMP	933 Specific Conductance	2300 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	933 pH	7.9 pH
01-MAY-03	THURSDAY	1_Hr_COMP	1033 Specific Conductance	2400 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	1033 pH	7.9 pH
01-MAY-03	THURSDAY	1_Hr_COMP	1133 Specific Conductance	2400 umhos/cm
01-MAY-03	THURSDAY	1_Hr_COMP	1133 pH	7.7 pH
01-MAY-03	THURSDAY	COMP_CONDUCT	1200 Specific Conductance	2200 umhos/cm
01-MAY-03	THURSDAY	COMP_PH	1200 pH	7.7 pH
01-MAY-03	THURSDAY	GRAB	1210 Specific Conductance	2300 umhos/cm
01-MAY-03	THURSDAY	GRAB	1210 pH	7.7 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1023 Specific Conductance	2300 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1023 pH	7.2 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1123 Specific Conductance	2300 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1123 pH	7.4 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1223 Specific Conductance	2300 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1223 pH	7.5 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1323 Specific Conductance	2200 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1323 pH	7.5 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1423 Specific Conductance	2100 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1423 pH	7.6 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1523 Specific Conductance	2100 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1523 pH	7.6 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1923 Specific Conductance	2100 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1923 pH	7.6 pH
09-MAY-03	FRIDAY	COMP_CONDUCT	1120 Specific Conductance	2200 umhos/cm
09-MAY-03	FRIDAY	COMP_PH	1120 pH	7.3 pH
09-MAY-03	FRIDAY	GRAB	1130 Specific Conductance	2300 umhos/cm
09-MAY-03	FRIDAY	GRAB	1130 pH	7.3 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1010 Specific Conductance	2400 umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1010 pH	7.1 pH
16-MAY-03	FRIDAY	1_Hr_COMP	1110 Specific Conductance	2400 umhos/cm

City of Mexicali
Site 13

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
16-MAY-03	FRIDAY	1_Hr_COMP	1110	pH	7.5	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1210	Specific Conductance	2400	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1210	pH	7.6	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1310	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1310	pH	7.5	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1410	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1410	pH	7.5	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1510	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1510	pH	7.5	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1610	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1610	pH	7.5	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1710	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1710	pH	7.5	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1810	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1810	pH	7.6	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1910	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1910	pH	7.6	pH
16-MAY-03	FRIDAY	1_Hr_COMP	2010	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2010	pH	7.6	pH
16-MAY-03	FRIDAY	1_Hr_COMP	2110	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2110	pH	7.6	pH
16-MAY-03	FRIDAY	1_Hr_COMP	2210	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2210	pH	7.6	pH
16-MAY-03	FRIDAY	1_Hr_COMP	2310	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2310	pH	7.5	pH
17-MAY-03	SATURDAY	1_Hr_COMP	10	Specific Conductance	2400	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	10	pH	7.6	pH
17-MAY-03	SATURDAY	1_Hr_COMP	110	Specific Conductance	2500	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	110	pH	7.5	pH
17-MAY-03	SATURDAY	1_Hr_COMP	210	Specific Conductance	2400	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	210	pH	7.6	pH
17-MAY-03	SATURDAY	1_Hr_COMP	310	Specific Conductance	2400	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	310	pH	7.6	pH
17-MAY-03	SATURDAY	1_Hr_COMP	410	Specific Conductance	2800	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	410	pH	7.6	pH
17-MAY-03	SATURDAY	1_Hr_COMP	510	Specific Conductance	2900	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	510	pH	7.6	pH
17-MAY-03	SATURDAY	1_Hr_COMP	610	Specific Conductance	2300	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	610	pH	7.6	pH
17-MAY-03	SATURDAY	1_Hr_COMP	710	Specific Conductance	2600	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	710	pH	7.6	pH
17-MAY-03	SATURDAY	1_Hr_COMP	810	Specific Conductance	2600	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	810	pH	7.6	pH
17-MAY-03	SATURDAY	1_Hr_COMP	910	Specific Conductance	2600	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	910	pH	7.6	pH
17-MAY-03	SATURDAY	COMP_CONDUCT	1100	Specific Conductance	2400	umhos/cm
17-MAY-03	SATURDAY	COMP_PH	1100	pH	7.6	pH
17-MAY-03	SATURDAY	GRAB	1110	Specific Conductance	2500	umhos/cm
17-MAY-03	SATURDAY	GRAB	1110	pH	7.3	pH
24-MAY-03	SATURDAY	1_Hr_COMP	946	Specific Conductance	2400	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	946	pH	7.6	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1046	Specific Conductance	2300	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1046	pH	7.7	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1146	Specific Conductance	2300	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1146	pH	7.7	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1246	Specific Conductance	2300	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1246	pH	7.7	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1346	Specific Conductance	2700	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1346	pH	7.6	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1446	Specific Conductance	2300	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1446	pH	7.6	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1546	Specific Conductance	2200	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1546	pH	7.6	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1646	Specific Conductance	2100	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1646	pH	7.6	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1746	Specific Conductance	2100	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1746	pH	7.6	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1846	Specific Conductance	2100	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1846	pH	7.6	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1946	Specific Conductance	2200	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1946	pH	7.7	pH
24-MAY-03	SATURDAY	1_Hr_COMP	2046	Specific Conductance	2200	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2046	pH	7.6	pH

City of Mexicali
Site 13

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
24-MAY-03	SATURDAY	1_Hr_COMP	2146 Specific Conductance	2200 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2146 pH	7.7 pH
24-MAY-03	SATURDAY	1_Hr_COMP	2246 Specific Conductance	2200 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2246 pH	7.7 pH
24-MAY-03	SATURDAY	1_Hr_COMP	2346 Specific Conductance	2100 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2346 pH	7.7 pH
25-MAY-03	SUNDAY	1_Hr_COMP	46 Specific Conductance	2100 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	46 pH	7.8 pH
25-MAY-03	SUNDAY	1_Hr_COMP	146 Specific Conductance	2200 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	146 pH	7.8 pH
25-MAY-03	SUNDAY	1_Hr_COMP	246 Specific Conductance	2300 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	246 pH	7.8 pH
25-MAY-03	SUNDAY	1_Hr_COMP	346 Specific Conductance	2300 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	346 pH	7.8 pH
25-MAY-03	SUNDAY	1_Hr_COMP	446 Specific Conductance	2200 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	446 pH	7.8 pH
25-MAY-03	SUNDAY	1_Hr_COMP	546 Specific Conductance	2200 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	546 pH	7.8 pH
25-MAY-03	SUNDAY	1_Hr_COMP	646 Specific Conductance	2200 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	646 pH	7.8 pH
25-MAY-03	SUNDAY	1_Hr_COMP	746 Specific Conductance	2400 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	746 pH	7.8 pH
25-MAY-03	SUNDAY	1_Hr_COMP	846 Specific Conductance	2200 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	846 pH	7.7 pH
25-MAY-03	SUNDAY	COMP_CONDUCT	1035 Specific Conductance	2300 umhos/cm
25-MAY-03	SUNDAY	COMP_PH	1035 pH	7.8 pH
25-MAY-03	SUNDAY	GRAB	1040 Specific Conductance	2200 umhos/cm
25-MAY-03	SUNDAY	GRAB	1040 pH	7.6 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1015 Specific Conductance	2200 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1015 pH	7.3 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1115 Specific Conductance	2300 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1115 pH	7.6 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1215 Specific Conductance	2200 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1215 pH	7.8 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1315 Specific Conductance	2200 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1315 pH	7.7 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1415 Specific Conductance	2100 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1415 pH	7.7 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1515 Specific Conductance	2100 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1515 pH	7.6 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1615 Specific Conductance	2100 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1615 pH	7.6 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1715 Specific Conductance	2100 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1715 pH	7.6 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1815 Specific Conductance	2100 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1815 pH	7.6 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1915 Specific Conductance	2100 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1915 pH	7.6 pH
01-JUN-03	SUNDAY	1_Hr_COMP	2015 Specific Conductance	2100 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2015 pH	7.6 pH
01-JUN-03	SUNDAY	1_Hr_COMP	2115 Specific Conductance	2100 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2115 pH	7.6 pH
01-JUN-03	SUNDAY	1_Hr_COMP	2215 Specific Conductance	2100 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2215 pH	7.5 pH
01-JUN-03	SUNDAY	1_Hr_COMP	2315 Specific Conductance	2100 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2315 pH	7.6 pH
02-JUN-03	MONDAY	1_Hr_COMP	15 Specific Conductance	2100 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	15 pH	7.6 pH
02-JUN-03	MONDAY	1_Hr_COMP	115 Specific Conductance	2100 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	115 pH	7.6 pH
02-JUN-03	MONDAY	1_Hr_COMP	215 Specific Conductance	2100 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	215 pH	7.6 pH
02-JUN-03	MONDAY	1_Hr_COMP	315 Specific Conductance	2200 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	315 pH	7.6 pH
02-JUN-03	MONDAY	1_Hr_COMP	415 Specific Conductance	2100 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	415 pH	7.6 pH
02-JUN-03	MONDAY	1_Hr_COMP	515 Specific Conductance	2100 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	515 pH	7.6 pH
02-JUN-03	MONDAY	1_Hr_COMP	615 Specific Conductance	2100 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	615 pH	7.7 pH
02-JUN-03	MONDAY	1_Hr_COMP	715 Specific Conductance	2100 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	715 pH	7.7 pH
02-JUN-03	MONDAY	1_Hr_COMP	815 Specific Conductance	2200 umhos/cm

City of Mexicali
Site 13

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
02-JUN-03	MONDAY	1_Hr_COMP	815 pH	7.6 pH
02-JUN-03	MONDAY	1_Hr_COMP	915 Specific Conductance	2200 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	915 pH	7.5 pH
02-JUN-03	MONDAY	COMP_CONDUCT	1140 Specific Conductance	2100 umhos/cm
02-JUN-03	MONDAY	COMP_PH	1140 pH	7.6 pH
02-JUN-03	MONDAY	GRAB	1150 Specific Conductance	2200 umhos/cm
02-JUN-03	MONDAY	GRAB	1150 pH	7.2 pH
10-JUN-03	TUESDAY	COMP_CONDUCT	1135 Specific Conductance	2300 umhos/cm
10-JUN-03	TUESDAY	COMP_PH	1135 pH	7.7 pH
10-JUN-03	TUESDAY	GRAB	1140 Specific Conductance	2200 umhos/cm
10-JUN-03	TUESDAY	GRAB	1140 pH	7.3 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1120 Specific Conductance	2300 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1120 pH	5 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1220 Specific Conductance	2200 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1220 pH	5.1 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1320 Specific Conductance	2100 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1320 pH	5.2 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1420 Specific Conductance	2100 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1420 pH	5.2 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1520 Specific Conductance	2100 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1520 pH	5.3 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1620 Specific Conductance	2100 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1620 pH	5.3 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1720 Specific Conductance	2100 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1720 pH	5.5 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1820 Specific Conductance	2000 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1820 pH	5.5 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1920 Specific Conductance	2000 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1920 pH	5.5 pH
17-JUN-03	TUESDAY	1_Hr_COMP	2020 Specific Conductance	2100 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	2020 pH	5.6 pH
17-JUN-03	TUESDAY	1_Hr_COMP	2120 Specific Conductance	2100 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	2120 pH	5.6 pH
17-JUN-03	TUESDAY	1_Hr_COMP	2220 Specific Conductance	2200 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	2220 pH	5.6 pH
17-JUN-03	TUESDAY	1_Hr_COMP	2320 Specific Conductance	2100 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	2320 pH	5.7 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	20 Specific Conductance	2100 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	20 pH	5.7 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	120 Specific Conductance	2100 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	120 pH	5.9 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	220 Specific Conductance	2100 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	220 pH	5.7 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	320 Specific Conductance	2200 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	320 pH	5.7 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	420 Specific Conductance	2100 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	420 pH	5.7 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	520 Specific Conductance	2100 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	520 pH	5.7 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	620 Specific Conductance	2100 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	620 pH	5.9 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	720 Specific Conductance	2300 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	720 pH	5.7 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	820 Specific Conductance	2600 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	820 pH	5.6 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	920 Specific Conductance	2400 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	920 pH	5.6 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	1020 Specific Conductance	2300 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	1020 pH	5.5 pH
18-JUN-03	WEDNESDAY	COMP_CONDUCT	1110 Specific Conductance	2200 umhos/cm
18-JUN-03	WEDNESDAY	COMP_PH	1110 pH	5.2 pH
18-JUN-03	WEDNESDAY	GRAB	1115 Specific Conductance	2600 umhos/cm
18-JUN-03	WEDNESDAY	GRAB	1115 pH	5.4 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1030 Specific Conductance	2200 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1030 pH	7.6 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1130 Specific Conductance	2100 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1130 pH	7.8 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1230 Specific Conductance	2200 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1230 pH	7.9 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1330 Specific Conductance	2200 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1330 pH	7.9 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1430 Specific Conductance	2100 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1430 pH	7.8 pH

City of Mexicali
Site 13

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
25-JUN-03	WEDNESDAY	1_Hr_COMP	1530	Specific Conductance	2100	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1530	pH	7.8	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1630	Specific Conductance	2000	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1630	pH	7.8	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1730	Specific Conductance	2100	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1730	pH	7.8	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1830	Specific Conductance	2100	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1830	pH	7.9	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1930	Specific Conductance	2000	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1930	pH	7.9	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	2030	Specific Conductance	2000	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	2030	pH	7.9	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	2130	Specific Conductance	2100	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	2130	pH	7.9	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	2230	Specific Conductance	2100	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	2230	pH	7.9	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	2330	Specific Conductance	2100	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	2330	pH	7.9	pH
26-JUN-03	THURSDAY	1_Hr_COMP	30	Specific Conductance	2200	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	30	pH	7.9	pH
26-JUN-03	THURSDAY	1_Hr_COMP	130	Specific Conductance	2400	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	130	pH	7.9	pH
26-JUN-03	THURSDAY	1_Hr_COMP	230	Specific Conductance	2200	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	230	pH	7.9	pH
26-JUN-03	THURSDAY	1_Hr_COMP	330	Specific Conductance	2200	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	330	pH	7.9	pH
26-JUN-03	THURSDAY	1_Hr_COMP	430	Specific Conductance	2200	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	430	pH	8	pH
26-JUN-03	THURSDAY	1_Hr_COMP	530	Specific Conductance	2200	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	530	pH	8.8	pH
26-JUN-03	THURSDAY	1_Hr_COMP	630	Specific Conductance	2100	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	630	pH	8.5	pH
26-JUN-03	THURSDAY	1_Hr_COMP	730	Specific Conductance	2200	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	730	pH	8.3	pH
26-JUN-03	THURSDAY	1_Hr_COMP	830	Specific Conductance	2200	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	830	pH	7.9	pH
26-JUN-03	THURSDAY	1_Hr_COMP	930	Specific Conductance	2200	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	930	pH	7.8	pH
26-JUN-03	THURSDAY	COMP_CONDUCT	1110	Specific Conductance	2200	umhos/cm
26-JUN-03	THURSDAY	COMP_PH	1110	pH	7.7	pH
26-JUN-03	THURSDAY	GRAB	1120	Specific Conductance	2300	umhos/cm
26-JUN-03	THURSDAY	GRAB	1120	pH	7.4	pH
03-JUL-03	THURSDAY	1_Hr_COMP	955	Specific Conductance	2200	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	955	pH	7.5	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1055	Specific Conductance	3600	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1055	pH	7.8	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1155	Specific Conductance	2600	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1155	pH	7.8	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1255	Specific Conductance	2500	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1255	pH	7.8	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1355	Specific Conductance	2900	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1355	pH	7.8	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1455	Specific Conductance	2100	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1455	pH	7.8	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1555	Specific Conductance	2200	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1555	pH	7.8	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1655	Specific Conductance	2200	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1655	pH	7.9	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1755	Specific Conductance	3000	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1755	pH	7.9	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1855	Specific Conductance	7100	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1855	pH	7.9	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1955	Specific Conductance	7500	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1955	pH	8	pH
03-JUL-03	THURSDAY	1_Hr_COMP	2055	Specific Conductance	5000	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	2055	pH	7.9	pH
03-JUL-03	THURSDAY	1_Hr_COMP	2155	Specific Conductance	5000	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	2155	pH	7.9	pH
03-JUL-03	THURSDAY	1_Hr_COMP	2255	Specific Conductance	4500	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	2255	pH	7.8	pH
03-JUL-03	THURSDAY	1_Hr_COMP	2355	Specific Conductance	4400	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	2355	pH	7.8	pH
04-JUL-03	FRIDAY	1_Hr_COMP	55	Specific Conductance	4400	umhos/cm

City of Mexicali
Site 13

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
04-JUL-03	FRIDAY	1_Hr_COMP		55 pH	7.8	pH
04-JUL-03	FRIDAY	1_Hr_COMP		155 Specific Conductance	4400	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP		155 pH	7.9	pH
04-JUL-03	FRIDAY	1_Hr_COMP		255 Specific Conductance	4300	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP		255 pH	8.0	pH
04-JUL-03	FRIDAY	1_Hr_COMP		355 Specific Conductance	4500	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP		355 pH	7.8	pH
04-JUL-03	FRIDAY	1_Hr_COMP		455 Specific Conductance	4600	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP		455 pH	7.9	pH
04-JUL-03	FRIDAY	1_Hr_COMP		555 Specific Conductance	4500	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP		555 pH	7.9	pH
04-JUL-03	FRIDAY	1_Hr_COMP		655 Specific Conductance	4300	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP		655 pH	8.2	pH
04-JUL-03	FRIDAY	1_Hr_COMP		755 Specific Conductance	4100	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP		755 pH	7.9	pH
04-JUL-03	FRIDAY	1_Hr_COMP		855 Specific Conductance	2700	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP		855 pH	7.7	pH
04-JUL-03	FRIDAY	COMP_CONDUCT		1035 Specific Conductance	2600	umhos/cm
04-JUL-03	FRIDAY	COMP_PH		1035 pH	7.5	pH
04-JUL-03	FRIDAY	GRAB		1045 Specific Conductance	2200	umhos/cm
04-JUL-03	FRIDAY	GRAB		1045 pH	7.4	pH
11-JUL-03	FRIDAY	1_Hr_COMP		1017 Specific Conductance	2100	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP		1017 pH	8.4	pH
11-JUL-03	FRIDAY	1_Hr_COMP		1117 Specific Conductance	2800	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP		1117 pH	8.0	pH
11-JUL-03	FRIDAY	1_Hr_COMP		1217 Specific Conductance	2100	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP		1217 pH	9.2	pH
11-JUL-03	FRIDAY	1_Hr_COMP		1317 Specific Conductance	2100	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP		1317 pH	9.2	pH
11-JUL-03	FRIDAY	1_Hr_COMP		1417 Specific Conductance	2100	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP		1417 pH	9.2	pH
11-JUL-03	FRIDAY	1_Hr_COMP		1517 Specific Conductance	2100	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP		1517 pH	9.2	pH
11-JUL-03	FRIDAY	1_Hr_COMP		1617 Specific Conductance	2400	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP		1617 pH	9.2	pH
11-JUL-03	FRIDAY	1_Hr_COMP		1717 Specific Conductance	2000	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP		1717 pH	9.2	pH
11-JUL-03	FRIDAY	1_Hr_COMP		1817 Specific Conductance	2000	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP		1817 pH	9.3	pH
11-JUL-03	FRIDAY	1_Hr_COMP		1917 Specific Conductance	2000	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP		1917 pH	9.3	pH
11-JUL-03	FRIDAY	1_Hr_COMP		2017 Specific Conductance	2100	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP		2017 pH	9.3	pH
11-JUL-03	FRIDAY	1_Hr_COMP		2117 Specific Conductance	2000	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP		2117 pH	9.3	pH
11-JUL-03	FRIDAY	1_Hr_COMP		2217 Specific Conductance	2000	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP		2217 pH	9.3	pH
11-JUL-03	FRIDAY	1_Hr_COMP		2317 Specific Conductance	2100	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP		2317 pH	9.2	pH
12-JUL-03	SATURDAY	1_Hr_COMP		17 Specific Conductance	2000	umhos/cm
12-JUL-03	SATURDAY	1_Hr_COMP		17 pH	9.2	pH
12-JUL-03	SATURDAY	1_Hr_COMP		117 Specific Conductance	1900	umhos/cm
12-JUL-03	SATURDAY	1_Hr_COMP		117 pH	9.1	pH
12-JUL-03	SATURDAY	1_Hr_COMP		217 Specific Conductance	2000	umhos/cm
12-JUL-03	SATURDAY	1_Hr_COMP		217 pH	9.0	pH
12-JUL-03	SATURDAY	1_Hr_COMP		317 Specific Conductance	1900	umhos/cm
12-JUL-03	SATURDAY	1_Hr_COMP		317 pH	8.9	pH
12-JUL-03	SATURDAY	1_Hr_COMP		417 Specific Conductance	1900	umhos/cm
12-JUL-03	SATURDAY	1_Hr_COMP		417 pH	8.8	pH
12-JUL-03	SATURDAY	1_Hr_COMP		517 Specific Conductance	2000	umhos/cm
12-JUL-03	SATURDAY	1_Hr_COMP		517 pH	8.8	pH
12-JUL-03	SATURDAY	1_Hr_COMP		617 Specific Conductance	1900	umhos/cm
12-JUL-03	SATURDAY	1_Hr_COMP		617 pH	8.5	pH
12-JUL-03	SATURDAY	1_Hr_COMP		717 Specific Conductance	1900	umhos/cm
12-JUL-03	SATURDAY	1_Hr_COMP		717 pH	8.3	pH
12-JUL-03	SATURDAY	1_Hr_COMP		817 Specific Conductance	2000	umhos/cm
12-JUL-03	SATURDAY	1_Hr_COMP		817 pH	8.2	pH
12-JUL-03	SATURDAY	1_Hr_COMP		917 Specific Conductance	2100	umhos/cm
12-JUL-03	SATURDAY	1_Hr_COMP		917 pH	8	pH
12-JUL-03	SATURDAY	COMP_CONDUCT		1050 Specific Conductance	2100	umhos/cm
12-JUL-03	SATURDAY	COMP_PH		1050 pH	8.6	pH
12-JUL-03	SATURDAY	GRAB		1100 Specific Conductance	2000	umhos/cm
12-JUL-03	SATURDAY	GRAB		1100 pH	7.5	pH

City of Mexicali
Site 13

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
19-JUL-03	SATURDAY	1_Hr_COMP	925 Specific Conductance	2100 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	925 pH	7.6 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1025 Specific Conductance	1900 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1025 pH	7.7 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1125 Specific Conductance	2000 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1125 pH	7.6 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1225 Specific Conductance	2000 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1225 pH	7.6 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1325 Specific Conductance	2100 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1325 pH	7.6 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1425 Specific Conductance	2100 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1425 pH	7.6 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1525 Specific Conductance	2100 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1525 pH	7.6 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1625 Specific Conductance	2100 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1625 pH	7.6 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1725 Specific Conductance	2100 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1725 pH	7.6 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1825 Specific Conductance	2100 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1825 pH	7.6 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1925 Specific Conductance	2100 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1925 pH	7.6 pH
19-JUL-03	SATURDAY	1_Hr_COMP	2025 Specific Conductance	2100 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	2025 pH	7.6 pH
19-JUL-03	SATURDAY	1_Hr_COMP	2125 Specific Conductance	2200 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	2125 pH	7.1 pH
19-JUL-03	SATURDAY	1_Hr_COMP	2225 Specific Conductance	2200 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	2225 pH	7.1 pH
19-JUL-03	SATURDAY	1_Hr_COMP	2325 Specific Conductance	2200 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	2325 pH	7.1 pH
20-JUL-03	SUNDAY	1_Hr_COMP	25 Specific Conductance	2300 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	25 pH	7.6 pH
20-JUL-03	SUNDAY	1_Hr_COMP	125 Specific Conductance	2300 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	125 pH	7.6 pH
20-JUL-03	SUNDAY	1_Hr_COMP	225 Specific Conductance	2300 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	225 pH	7.6 pH
20-JUL-03	SUNDAY	1_Hr_COMP	325 Specific Conductance	2300 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	325 pH	7.6 pH
20-JUL-03	SUNDAY	1_Hr_COMP	425 Specific Conductance	2300 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	425 pH	7.6 pH
20-JUL-03	SUNDAY	1_Hr_COMP	525 Specific Conductance	2300 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	525 pH	7.6 pH
20-JUL-03	SUNDAY	1_Hr_COMP	625 Specific Conductance	2300 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	625 pH	7.6 pH
20-JUL-03	SUNDAY	1_Hr_COMP	725 Specific Conductance	2300 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	725 pH	7.5 pH
20-JUL-03	SUNDAY	1_Hr_COMP	825 Specific Conductance	2300 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	825 pH	2.8 pH
20-JUL-03	SUNDAY	COMP_CONDUCT	1000 Specific Conductance	2000 umhos/cm
20-JUL-03	SUNDAY	COMP_PH	1000 pH	7.7 pH
20-JUL-03	SUNDAY	GRAB	1010 Specific Conductance	2400 umhos/cm
20-JUL-03	SUNDAY	GRAB	1010 pH	7.4 pH

SITE 14

City of Mexicali
Site 14

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
30-APR-03	WEDNESDAY	1_Hr_COMP	1153 Specific Conductance	3800 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1153 pH	7.6 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1253 Specific Conductance	2800 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1253 pH	7.7 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1353 Specific Conductance	2200 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1353 pH	7.6 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1453 Specific Conductance	2400 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1453 pH	7.5 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1553 Specific Conductance	2400 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1553 pH	7.3 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1653 Specific Conductance	2200 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1653 pH	7.4 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1753 Specific Conductance	2200 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1753 pH	7.4 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1853 Specific Conductance	2100 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1853 pH	7.4 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	1953 Specific Conductance	2200 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	1953 pH	7.4 pH
30-APR-03	WEDNESDAY	1_Hr_COMP	2053 Specific Conductance	2200 umhos/cm
30-APR-03	WEDNESDAY	1_Hr_COMP	2053 pH	7.2 pH
01-MAY-03	THURSDAY	COMP_CONDUCT	1125 Specific Conductance	2400 umhos/cm
01-MAY-03	THURSDAY	COMP_PH	1125 pH	7.7 pH
01-MAY-03	THURSDAY	GRAB	1130 Specific Conductance	2400 umhos/cm
01-MAY-03	THURSDAY	GRAB	1130 pH	7.6 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1005 Specific Conductance	2200 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1005 pH	7.2 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1105 Specific Conductance	2400 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1105 pH	7.6 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1205 Specific Conductance	2300 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1205 pH	7.7 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1305 Specific Conductance	2200 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1305 pH	7.8 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1405 Specific Conductance	2300 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1405 pH	7.7 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1505 Specific Conductance	2100 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1505 pH	7.7 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1605 Specific Conductance	2100 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1605 pH	7.7 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1705 Specific Conductance	2300 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1705 pH	7.7 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1805 Specific Conductance	2300 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1805 pH	7.8 pH
08-MAY-03	THURSDAY	1_Hr_COMP	1905 Specific Conductance	2100 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	1905 pH	7.8 pH
08-MAY-03	THURSDAY	1_Hr_COMP	2005 Specific Conductance	2100 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	2005 pH	7.8 pH
08-MAY-03	THURSDAY	1_Hr_COMP	2105 Specific Conductance	2100 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	2105 pH	7.6 pH
08-MAY-03	THURSDAY	1_Hr_COMP	2205 Specific Conductance	2100 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	2205 pH	7.6 pH
08-MAY-03	THURSDAY	1_Hr_COMP	2305 Specific Conductance	2200 umhos/cm
08-MAY-03	THURSDAY	1_Hr_COMP	2305 pH	7.5 pH
09-MAY-03	FRIDAY	1_Hr_COMP	5 Specific Conductance	2200 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	5 pH	7.5 pH
09-MAY-03	FRIDAY	1_Hr_COMP	105 Specific Conductance	2100 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	105 pH	7.5 pH
09-MAY-03	FRIDAY	1_Hr_COMP	205 Specific Conductance	2100 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	205 pH	7.6 pH
09-MAY-03	FRIDAY	1_Hr_COMP	305 Specific Conductance	2200 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	305 pH	7.6 pH
09-MAY-03	FRIDAY	1_Hr_COMP	405 Specific Conductance	2300 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	405 pH	7.7 pH
09-MAY-03	FRIDAY	1_Hr_COMP	505 Specific Conductance	2300 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	505 pH	7.7 pH
09-MAY-03	FRIDAY	1_Hr_COMP	605 Specific Conductance	2300 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	605 pH	7.8 pH
09-MAY-03	FRIDAY	1_Hr_COMP	705 Specific Conductance	2200 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	705 pH	7.9 pH
09-MAY-03	FRIDAY	1_Hr_COMP	805 Specific Conductance	2200 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	805 pH	7.7 pH
09-MAY-03	FRIDAY	1_Hr_COMP	905 Specific Conductance	2100 umhos/cm
09-MAY-03	FRIDAY	1_Hr_COMP	905 pH	7.8 pH
09-MAY-03	FRIDAY	COMP_CONDUCT	1050 Specific Conductance	2300 umhos/cm

City of Mexicali
Site 14

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
09-MAY-03	FRIDAY	COMP_PH	1050	pH	7.3	pH
09-MAY-03	FRIDAY	GRAB	1100	Specific Conductance	2300	umhos/cm
09-MAY-03	FRIDAY	GRAB	1100	pH	7.4	pH
16-MAY-03	FRIDAY	1_Hr_COMP	955	Specific Conductance	2400	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	955	pH	7.1	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1055	Specific Conductance	2400	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1055	pH	7.1	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1155	Specific Conductance	2400	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1155	pH	7.2	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1255	Specific Conductance	2400	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1255	pH	7.2	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1355	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1355	pH	7.3	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1455	Specific Conductance	2400	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1455	pH	7.2	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1555	Specific Conductance	2400	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1555	pH	7.2	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1655	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1655	pH	7.2	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1755	Specific Conductance	2400	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1755	pH	7.3	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1855	Specific Conductance	2200	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1855	pH	7.5	pH
16-MAY-03	FRIDAY	1_Hr_COMP	1955	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	1955	pH	7.3	pH
16-MAY-03	FRIDAY	1_Hr_COMP	2055	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2055	pH	7.3	pH
16-MAY-03	FRIDAY	1_Hr_COMP	2155	Specific Conductance	2200	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2155	pH	7.3	pH
16-MAY-03	FRIDAY	1_Hr_COMP	2255	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2255	pH	7.4	pH
16-MAY-03	FRIDAY	1_Hr_COMP	2355	Specific Conductance	2300	umhos/cm
16-MAY-03	FRIDAY	1_Hr_COMP	2355	pH	7.4	pH
17-MAY-03	SATURDAY	1_Hr_COMP	55	Specific Conductance	2300	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	55	pH	7.4	pH
17-MAY-03	SATURDAY	1_Hr_COMP	155	Specific Conductance	2300	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	155	pH	7.4	pH
17-MAY-03	SATURDAY	1_Hr_COMP	255	Specific Conductance	2200	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	255	pH	7.5	pH
17-MAY-03	SATURDAY	1_Hr_COMP	355	Specific Conductance	2300	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	355	pH	7.6	pH
17-MAY-03	SATURDAY	1_Hr_COMP	455	Specific Conductance	2300	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	455	pH	7.6	pH
17-MAY-03	SATURDAY	1_Hr_COMP	555	Specific Conductance	2400	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	555	pH	7.7	pH
17-MAY-03	SATURDAY	1_Hr_COMP	655	Specific Conductance	2400	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	655	pH	7.7	pH
17-MAY-03	SATURDAY	1_Hr_COMP	755	Specific Conductance	2300	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	755	pH	7.7	pH
17-MAY-03	SATURDAY	1_Hr_COMP	855	Specific Conductance	2500	umhos/cm
17-MAY-03	SATURDAY	1_Hr_COMP	855	pH	7.6	pH
17-MAY-03	SATURDAY	COMP_CONDUCT	1030	Specific Conductance	2300	umhos/cm
17-MAY-03	SATURDAY	COMP_PH	1030	pH	7.1	pH
17-MAY-03	SATURDAY	GRAB	1035	Specific Conductance	2300	umhos/cm
17-MAY-03	SATURDAY	GRAB	1035	pH	7.2	pH
24-MAY-03	SATURDAY	1_Hr_COMP	925	Specific Conductance	2200	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	925	pH	7.4	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1125	Specific Conductance	2400	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1125	pH	7.7	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1225	Specific Conductance	2400	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1225	pH	7.4	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1325	Specific Conductance	2200	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1325	pH	7.7	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1525	Specific Conductance	2300	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1525	pH	7.6	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1625	Specific Conductance	2200	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1625	pH	7.6	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1825	Specific Conductance	2200	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1825	pH	7.3	pH
24-MAY-03	SATURDAY	1_Hr_COMP	1925	Specific Conductance	2200	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	1925	pH	7.3	pH
24-MAY-03	SATURDAY	1_Hr_COMP	2025	Specific Conductance	2300	umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2025	pH	7.5	pH

City of Mexicali
Site 14

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
24-MAY-03	SATURDAY	1_Hr_COMP	2125 Specific Conductance	2400 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2125 pH	7.4 pH
24-MAY-03	SATURDAY	1_Hr_COMP	2225 Specific Conductance	2200 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2225 pH	7.3 pH
24-MAY-03	SATURDAY	1_Hr_COMP	2325 Specific Conductance	2200 umhos/cm
24-MAY-03	SATURDAY	1_Hr_COMP	2325 pH	7.4 pH
25-MAY-03	SUNDAY	1_Hr_COMP	25 Specific Conductance	2400 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	25 pH	7.4 pH
25-MAY-03	SUNDAY	1_Hr_COMP	125 Specific Conductance	2200 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	125 pH	7.4 pH
25-MAY-03	SUNDAY	1_Hr_COMP	225 Specific Conductance	2200 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	225 pH	7.4 pH
25-MAY-03	SUNDAY	1_Hr_COMP	325 Specific Conductance	2200 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	325 pH	7.4 pH
25-MAY-03	SUNDAY	1_Hr_COMP	425 Specific Conductance	2200 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	425 pH	7.5 pH
25-MAY-03	SUNDAY	1_Hr_COMP	525 Specific Conductance	2200 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	525 pH	7.5 pH
25-MAY-03	SUNDAY	1_Hr_COMP	625 Specific Conductance	2200 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	625 pH	7.5 pH
25-MAY-03	SUNDAY	1_Hr_COMP	725 Specific Conductance	2200 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	725 pH	7.6 pH
25-MAY-03	SUNDAY	1_Hr_COMP	825 Specific Conductance	2200 umhos/cm
25-MAY-03	SUNDAY	1_Hr_COMP	825 pH	7.7 pH
25-MAY-03	SUNDAY	COMP_CONDUCT	1010 Specific Conductance	2200 umhos/cm
25-MAY-03	SUNDAY	COMP_PH	1010 pH	7.7 pH
25-MAY-03	SUNDAY	GRAB	1015 Specific Conductance	2200 umhos/cm
25-MAY-03	SUNDAY	GRAB	1015 pH	7.6 pH

SITE 15

City of Mexicali
Site 15

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
01-JUN-03	SUNDAY	1_Hr_COMP	845 Specific Conductance	3500 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	845 pH	7 pH
01-JUN-03	SUNDAY	1_Hr_COMP	945 Specific Conductance	2700 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	945 pH	7.2 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1045 Specific Conductance	2600 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1045 pH	7.3 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1145 Specific Conductance	2800 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1145 pH	7.3 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1245 Specific Conductance	2800 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1245 pH	7.3 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1345 Specific Conductance	2800 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1345 pH	7.3 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1445 Specific Conductance	2600 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1445 pH	7.3 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1545 Specific Conductance	2800 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1545 pH	7.2 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1645 Specific Conductance	3100 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1645 pH	7.1 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1745 Specific Conductance	3100 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1745 pH	7.1 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1845 Specific Conductance	2600 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1845 pH	7.1 pH
01-JUN-03	SUNDAY	1_Hr_COMP	1945 Specific Conductance	3400 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	1945 pH	7 pH
01-JUN-03	SUNDAY	1_Hr_COMP	2045 Specific Conductance	3100 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2045 pH	7.2 pH
01-JUN-03	SUNDAY	1_Hr_COMP	2145 Specific Conductance	3000 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2145 pH	7.2 pH
01-JUN-03	SUNDAY	1_Hr_COMP	2245 Specific Conductance	2800 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2245 pH	7.2 pH
01-JUN-03	SUNDAY	1_Hr_COMP	2345 Specific Conductance	2800 umhos/cm
01-JUN-03	SUNDAY	1_Hr_COMP	2345 pH	7.4 pH
02-JUN-03	MONDAY	1_Hr_COMP	45 Specific Conductance	3200 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	45 pH	7.3 pH
02-JUN-03	MONDAY	1_Hr_COMP	145 Specific Conductance	2300 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	145 pH	7.3 pH
02-JUN-03	MONDAY	1_Hr_COMP	245 Specific Conductance	2500 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	245 pH	7.4 pH
02-JUN-03	MONDAY	1_Hr_COMP	345 Specific Conductance	1900 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	345 pH	7.4 pH
02-JUN-03	MONDAY	1_Hr_COMP	445 Specific Conductance	2900 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	445 pH	7.9 pH
02-JUN-03	MONDAY	1_Hr_COMP	545 Specific Conductance	2900 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	545 pH	7.5 pH
02-JUN-03	MONDAY	1_Hr_COMP	645 Specific Conductance	3300 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	645 pH	7.5 pH
02-JUN-03	MONDAY	1_Hr_COMP	745 Specific Conductance	3100 umhos/cm
02-JUN-03	MONDAY	1_Hr_COMP	745 pH	7.4 pH
02-JUN-03	MONDAY	COMP_CONDUCT	925 Specific Conductance	2900 umhos/cm
02-JUN-03	MONDAY	COMP_PH	925 pH	7.1 pH
02-JUN-03	MONDAY	GRAB	930 Specific Conductance	3200 umhos/cm
02-JUN-03	MONDAY	GRAB	930 pH	7.3 pH
10-JUN-03	TUESDAY	COMP_CONDUCT	920 Specific Conductance	2400 umhos/cm
10-JUN-03	TUESDAY	COMP_PH	920 pH	6.75 pH
10-JUN-03	TUESDAY	GRAB	925 Specific Conductance	2700 umhos/cm
10-JUN-03	TUESDAY	GRAB	925 pH	7.4 pH

SITE 16

City of Mexicali
Site 16

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
17-JUN-03	TUESDAY	1_Hr_COMP	920	Specific Conductance	1900	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	920	pH	7.3	pH
17-JUN-03	TUESDAY	1_Hr_COMP	1020	Specific Conductance	1900	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1020	pH	7.3	pH
17-JUN-03	TUESDAY	1_Hr_COMP	1120	Specific Conductance	1900	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1120	pH	7.2	pH
17-JUN-03	TUESDAY	1_Hr_COMP	1220	Specific Conductance	1900	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1220	pH	7.1	pH
17-JUN-03	TUESDAY	1_Hr_COMP	1320	Specific Conductance	1900	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1320	pH	7.1	pH
17-JUN-03	TUESDAY	1_Hr_COMP	1420	Specific Conductance	1900	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1420	pH	7	pH
17-JUN-03	TUESDAY	1_Hr_COMP	1520	Specific Conductance	1900	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1520	pH	7.1	pH
17-JUN-03	TUESDAY	1_Hr_COMP	1620	Specific Conductance	1900	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1620	pH	7.1	pH
17-JUN-03	TUESDAY	1_Hr_COMP	1720	Specific Conductance	1900	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1720	pH	7.1	pH
17-JUN-03	TUESDAY	1_Hr_COMP	1820	Specific Conductance	1900	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1820	pH	7.2	pH
17-JUN-03	TUESDAY	1_Hr_COMP	1920	Specific Conductance	1900	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1920	pH	7.2	pH
17-JUN-03	TUESDAY	1_Hr_COMP	2020	Specific Conductance	1900	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	2020	pH	7.3	pH
17-JUN-03	TUESDAY	1_Hr_COMP	2120	Specific Conductance	1900	umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	2120	pH	7.2	pH
18-JUN-03	WEDNESDAY	COMP_CONDUCT	840	Specific Conductance	1900	umhos/cm
18-JUN-03	WEDNESDAY	COMP_PH	840	pH	7.3	pH
18-JUN-03	WEDNESDAY	GRAB	845	Specific Conductance	1700	umhos/cm
18-JUN-03	WEDNESDAY	GRAB	845	pH	7.4	pH

SITE 17

City of Mexicali
Site 17

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
17-JUN-03	TUESDAY	1_Hr_COMP	1030 Specific Conductance	2000 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1030 pH	7 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1230 Specific Conductance	2100 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1230 pH	7.1 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1330 Specific Conductance	2100 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1330 pH	7.1 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1430 Specific Conductance	2100 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1430 pH	7.1 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1530 Specific Conductance	2000 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1530 pH	7.1 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1630 Specific Conductance	2000 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1630 pH	7.1 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1730 Specific Conductance	2100 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1730 pH	7.1 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1830 Specific Conductance	2000 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1830 pH	7.3 pH
17-JUN-03	TUESDAY	1_Hr_COMP	1930 Specific Conductance	2000 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	1930 pH	7.4 pH
17-JUN-03	TUESDAY	1_Hr_COMP	2030 Specific Conductance	2100 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	2030 pH	7.5 pH
17-JUN-03	TUESDAY	1_Hr_COMP	2130 Specific Conductance	2000 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	2130 pH	7.4 pH
17-JUN-03	TUESDAY	1_Hr_COMP	2230 Specific Conductance	2000 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	2230 pH	7.4 pH
17-JUN-03	TUESDAY	1_Hr_COMP	2330 Specific Conductance	2000 umhos/cm
17-JUN-03	TUESDAY	1_Hr_COMP	2330 pH	7.4 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	30 Specific Conductance	2000 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	30 pH	7.4 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	130 Specific Conductance	2000 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	130 pH	7.4 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	230 Specific Conductance	2000 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	230 pH	7.4 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	330 Specific Conductance	2000 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	330 pH	7.5 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	430 Specific Conductance	1600 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	430 pH	7.5 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	530 Specific Conductance	1700 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	530 pH	7.5 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	630 Specific Conductance	1700 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	630 pH	7.1 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	730 Specific Conductance	1700 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	730 pH	6.7 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	830 Specific Conductance	1700 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	830 pH	7 pH
18-JUN-03	WEDNESDAY	1_Hr_COMP	930 Specific Conductance	2000 umhos/cm
18-JUN-03	WEDNESDAY	1_Hr_COMP	930 pH	7.4 pH
18-JUN-03	WEDNESDAY	COMP_CONDUCT	955 Specific Conductance	1900 umhos/cm
18-JUN-03	WEDNESDAY	COMP_PH	955 pH	7.3 pH
18-JUN-03	WEDNESDAY	GRAB	1000 Specific Conductance	2800 umhos/cm
18-JUN-03	WEDNESDAY	GRAB	1000 pH	7.4 pH

SITE 18

City of Mexicali
Site 18

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
25-JUN-03	WEDNESDAY	1_Hr_COMP	925 Specific Conductance	2300 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	925 pH	11.4 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1025 Specific Conductance	8450 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1025 pH	12.2 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1125 Specific Conductance	6500 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1125 pH	12.2 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1225 Specific Conductance	14800 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1225 pH	12.6 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1325 Specific Conductance	7500 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1325 pH	12.3 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1425 Specific Conductance	4500 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1425 pH	12.7 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1525 Specific Conductance	2600 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1525 pH	11.1 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1625 Specific Conductance	1600 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1625 pH	6.4 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1725 Specific Conductance	1600 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1725 pH	6.8 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1825 Specific Conductance	2100 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1825 pH	9.8 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1925 Specific Conductance	2900 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1925 pH	10.5 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	2025 Specific Conductance	2900 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	2025 pH	9.8 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	2125 Specific Conductance	2200 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	2125 pH	6.8 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	2225 Specific Conductance	3500 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	2225 pH	6.9 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	2325 Specific Conductance	3300 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	2325 pH	7.1 pH
26-JUN-03	THURSDAY	1_Hr_COMP	25 Specific Conductance	2000 umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	25 pH	4.9 pH
26-JUN-03	THURSDAY	1_Hr_COMP	125 Specific Conductance	2600 umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	125 pH	6.9 pH
26-JUN-03	THURSDAY	1_Hr_COMP	225 Specific Conductance	2500 umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	225 pH	7.3 pH
26-JUN-03	THURSDAY	1_Hr_COMP	325 Specific Conductance	2800 umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	325 pH	7.6 pH
26-JUN-03	THURSDAY	1_Hr_COMP	425 Specific Conductance	3200 umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	425 pH	7.5 pH
26-JUN-03	THURSDAY	1_Hr_COMP	525 Specific Conductance	4400 umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	525 pH	7.4 pH
26-JUN-03	THURSDAY	1_Hr_COMP	625 Specific Conductance	5500 umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	625 pH	7.3 pH
26-JUN-03	THURSDAY	1_Hr_COMP	725 Specific Conductance	4000 umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	725 pH	7.6 pH
26-JUN-03	THURSDAY	1_Hr_COMP	825 Specific Conductance	16000 umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP	825 pH	6.9 pH
26-JUN-03	THURSDAY	COMP_CONDUCT	932 Specific Conductance	3900 umhos/cm
26-JUN-03	THURSDAY	COMP_PH	932 pH	10.8 pH
26-JUN-03	THURSDAY	GRAB	940 Specific Conductance	1700 umhos/cm
26-JUN-03	THURSDAY	GRAB	940 pH	6.5 pH
03-JUL-03	THURSDAY	1_Hr_COMP	855 Specific Conductance	3300 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	855 pH	5 pH
03-JUL-03	THURSDAY	1_Hr_COMP	955 Specific Conductance	3400 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	955 pH	6.8 pH
03-JUL-03	THURSDAY	1_Hr_COMP	1055 Specific Conductance	6200 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1055 pH	6.1 pH
03-JUL-03	THURSDAY	1_Hr_COMP	1155 Specific Conductance	10300 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1155 pH	12.2 pH
03-JUL-03	THURSDAY	1_Hr_COMP	1255 Specific Conductance	3100 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1255 pH	4.8 pH
03-JUL-03	THURSDAY	1_Hr_COMP	1355 Specific Conductance	2700 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1355 pH	4.8 pH
03-JUL-03	THURSDAY	1_Hr_COMP	1455 Specific Conductance	4600 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1455 pH	6.7 pH
03-JUL-03	THURSDAY	1_Hr_COMP	1555 Specific Conductance	3400 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1555 pH	5.4 pH
03-JUL-03	THURSDAY	1_Hr_COMP	1655 Specific Conductance	1900 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1655 pH	8.1 pH
03-JUL-03	THURSDAY	1_Hr_COMP	1755 Specific Conductance	6500 umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1755 pH	12.1 pH
03-JUL-03	THURSDAY	1_Hr_COMP	1855 Specific Conductance	4700 umhos/cm

City of Mexicali
Site 18

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
03-JUL-03	THURSDAY	1_Hr_COMP	1855	pH	8	pH
03-JUL-03	THURSDAY	1_Hr_COMP	1955	Specific Conductance	4100	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	1955	pH	8.4	pH
03-JUL-03	THURSDAY	1_Hr_COMP	2055	Specific Conductance	2200	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	2055	pH	4.2	pH
03-JUL-03	THURSDAY	1_Hr_COMP	2155	Specific Conductance	2000	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	2155	pH	5.6	pH
03-JUL-03	THURSDAY	1_Hr_COMP	2255	Specific Conductance	3900	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	2255	pH	11.7	pH
03-JUL-03	THURSDAY	1_Hr_COMP	2355	Specific Conductance	2700	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	2355	pH	4.7	pH
04-JUL-03	FRIDAY	1_Hr_COMP	55	Specific Conductance	4000	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	55	pH	7	pH
04-JUL-03	FRIDAY	1_Hr_COMP	155	Specific Conductance	4400	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	155	pH	11.3	pH
04-JUL-03	FRIDAY	1_Hr_COMP	255	Specific Conductance	5000	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	255	pH	11.4	pH
04-JUL-03	FRIDAY	1_Hr_COMP	355	Specific Conductance	5100	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	355	pH	5.1	pH
04-JUL-03	FRIDAY	1_Hr_COMP	455	Specific Conductance	3900	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	455	pH	5.7	pH
04-JUL-03	FRIDAY	1_Hr_COMP	555	Specific Conductance	3600	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	555	pH	7.3	pH
04-JUL-03	FRIDAY	1_Hr_COMP	655	Specific Conductance	4600	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	655	pH	6.7	pH
04-JUL-03	FRIDAY	1_Hr_COMP	755	Specific Conductance	4100	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	755	pH	5.6	pH
04-JUL-03	FRIDAY	COMP_CONDUCT	950	Specific Conductance	3800	umhos/cm
04-JUL-03	FRIDAY	COMP_PH	950	pH	9.7	pH
04-JUL-03	FRIDAY	GRAB	955	Specific Conductance	5500	umhos/cm
04-JUL-03	FRIDAY	GRAB	955	pH	11.7	pH
11-JUL-03	FRIDAY	1_Hr_COMP	930	Specific Conductance	3000	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	930	pH	6.6	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1030	Specific Conductance	2500	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1030	pH	5	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1130	Specific Conductance	4000	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1130	pH	4.9	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1230	Specific Conductance	4500	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1230	pH	5	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1330	Specific Conductance	5000	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1330	pH	5.6	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1430	Specific Conductance	3700	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1430	pH	4.3	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1530	Specific Conductance	4400	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1530	pH	2.5	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1630	Specific Conductance	4700	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1630	pH	2.5	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1730	Specific Conductance	4700	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1730	pH	2.4	pH
12-JUL-03	SATURDAY	COMP_CONDUCT	935	Specific Conductance	4000	umhos/cm
12-JUL-03	SATURDAY	COMP_PH	935	pH	2.9	pH
12-JUL-03	SATURDAY	GRAB	940	Specific Conductance	2000	umhos/cm
12-JUL-03	SATURDAY	GRAB	940	pH	4.6	pH
19-JUL-03	SATURDAY	1_Hr_COMP	855	Specific Conductance	3400	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	855	pH	6.9	pH
19-JUL-03	SATURDAY	1_Hr_COMP	955	Specific Conductance	3400	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	955	pH	11.3	pH
19-JUL-03	SATURDAY	1_Hr_COMP	1055	Specific Conductance	2900	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1055	pH	5.9	pH
19-JUL-03	SATURDAY	1_Hr_COMP	1155	Specific Conductance	2500	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1155	pH	6.1	pH
19-JUL-03	SATURDAY	1_Hr_COMP	1255	Specific Conductance	4000	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1255	pH	11.1	pH
19-JUL-03	SATURDAY	1_Hr_COMP	1355	Specific Conductance	1500	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1355	pH	7	pH
19-JUL-03	SATURDAY	1_Hr_COMP	1455	Specific Conductance	1400	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1455	pH	6.4	pH
19-JUL-03	SATURDAY	1_Hr_COMP	1555	Specific Conductance	2500	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1555	pH	9.8	pH
19-JUL-03	SATURDAY	1_Hr_COMP	1655	Specific Conductance	2500	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1655	pH	5.6	pH
19-JUL-03	SATURDAY	1_Hr_COMP	2155	Specific Conductance	2000	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	2155	pH	7	pH

City of Mexicali
Site 18

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
20-JUL-03	SUNDAY	1_Hr_COMP	255 Specific Conductance	2000 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	255 pH	6.7 pH
20-JUL-03	SUNDAY	1_Hr_COMP	355 Specific Conductance	12100 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	355 pH	6.8 pH
20-JUL-03	SUNDAY	1_Hr_COMP	655 Specific Conductance	2200 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	655 pH	7 pH
20-JUL-03	SUNDAY	COMP_CONDUCT	900 Specific Conductance	3200 umhos/cm
20-JUL-03	SUNDAY	COMP_PH	900 pH	9.1 pH
20-JUL-03	SUNDAY	GRAB	910 Specific Conductance	2100 umhos/cm
20-JUL-03	SUNDAY	GRAB	910 pH	7.8 pH

SITE 19

City of Mexicali
Site 19

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
25-JUN-03	WEDNESDAY	1_Hr_COMP		940 Specific Conductance	4700	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP		940 pH	12.1	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP		1040 Specific Conductance	1800	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP		1040 pH	9.1	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP		1140 Specific Conductance	16800	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP		1140 pH	12.7	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP		1240 Specific Conductance	2500	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP		1240 pH	11.6	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP		1340 Specific Conductance	6200	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP		1340 pH	12.1	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP		1440 Specific Conductance	6800	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP		1440 pH	12.2	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP		1540 Specific Conductance	1800	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP		1540 pH	10.6	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP		1640 Specific Conductance	1600	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP		1640 pH	7.6	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP		1740 Specific Conductance	1700	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP		1740 pH	4.7	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP		1840 Specific Conductance	2200	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP		1840 pH	10.4	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP		2240 Specific Conductance	1600	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP		2240 pH	8.5	pH
25-JUN-03	WEDNESDAY	1_Hr_COMP		2340 Specific Conductance	1200	umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP		2340 pH	7.6	pH
26-JUN-03	THURSDAY	1_Hr_COMP		40 Specific Conductance	1400	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP		40 pH	6.7	pH
26-JUN-03	THURSDAY	1_Hr_COMP		140 Specific Conductance	1500	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP		140 pH	6.8	pH
26-JUN-03	THURSDAY	1_Hr_COMP		240 Specific Conductance	1600	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP		240 pH	6.7	pH
26-JUN-03	THURSDAY	1_Hr_COMP		340 Specific Conductance	1600	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP		340 pH	7.6	pH
26-JUN-03	THURSDAY	1_Hr_COMP		440 Specific Conductance	1700	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP		440 pH	10.3	pH
26-JUN-03	THURSDAY	1_Hr_COMP		540 Specific Conductance	1600	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP		540 pH	8.8	pH
26-JUN-03	THURSDAY	1_Hr_COMP		640 Specific Conductance	1800	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP		640 pH	8.3	pH
26-JUN-03	THURSDAY	1_Hr_COMP		740 Specific Conductance	6100	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP		740 pH	7.9	pH
26-JUN-03	THURSDAY	1_Hr_COMP		840 Specific Conductance	2600	umhos/cm
26-JUN-03	THURSDAY	1_Hr_COMP		840 pH	7.9	pH
26-JUN-03	THURSDAY	COMP_CONDUCT		958 Specific Conductance	2900	umhos/cm
26-JUN-03	THURSDAY	COMP_PH		958 pH	11.3	pH
26-JUN-03	THURSDAY	GRAB		1008 Specific Conductance	13300	umhos/cm
26-JUN-03	THURSDAY	GRAB		1008 pH	12.7	pH
03-JUL-03	THURSDAY	1_Hr_COMP		910 Specific Conductance	2000	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP		910 pH	5	pH
03-JUL-03	THURSDAY	1_Hr_COMP		1010 Specific Conductance	3000	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP		1010 pH	11.4	pH
03-JUL-03	THURSDAY	1_Hr_COMP		1110 Specific Conductance	6300	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP		1110 pH	11.1	pH
03-JUL-03	THURSDAY	1_Hr_COMP		1210 Specific Conductance	10100	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP		1210 pH	12.4	pH
03-JUL-03	THURSDAY	1_Hr_COMP		1310 Specific Conductance	2300	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP		1310 pH	8.1	pH
03-JUL-03	THURSDAY	1_Hr_COMP		1410 Specific Conductance	1800	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP		1410 pH	6.9	pH
03-JUL-03	THURSDAY	1_Hr_COMP		1510 Specific Conductance	1600	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP		1510 pH	7.7	pH
03-JUL-03	THURSDAY	1_Hr_COMP		1610 Specific Conductance	1700	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP		1610 pH	10	pH
03-JUL-03	THURSDAY	1_Hr_COMP		1710 Specific Conductance	8000	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP		1710 pH	12.3	pH
03-JUL-03	THURSDAY	1_Hr_COMP		1810 Specific Conductance	11300	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP		1810 pH	11.7	pH
03-JUL-03	THURSDAY	1_Hr_COMP		1910 Specific Conductance	3600	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP		1910 pH	11.9	pH
03-JUL-03	THURSDAY	1_Hr_COMP		2010 Specific Conductance	1500	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP		2010 pH	9.5	pH
03-JUL-03	THURSDAY	1_Hr_COMP		2110 Specific Conductance	1300	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP		2110 pH	6.4	pH
03-JUL-03	THURSDAY	1_Hr_COMP		2210 Specific Conductance	1500	umhos/cm

City of Mexicali
Site 19

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME	ANALYTE	VALUE	UNITS
03-JUL-03	THURSDAY	1_Hr_COMP	2210	pH	6.9	pH
03-JUL-03	THURSDAY	1_Hr_COMP	2310	Specific Conductance	9200	umhos/cm
03-JUL-03	THURSDAY	1_Hr_COMP	2310	pH	12.3	pH
04-JUL-03	FRIDAY	1_Hr_COMP	10	Specific Conductance	1600	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	10	pH	8.7	pH
04-JUL-03	FRIDAY	1_Hr_COMP	110	Specific Conductance	1500	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	110	pH	7.1	pH
04-JUL-03	FRIDAY	1_Hr_COMP	210	Specific Conductance	10300	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	210	pH	12.3	pH
04-JUL-03	FRIDAY	1_Hr_COMP	310	Specific Conductance	1700	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	310	pH	9.6	pH
04-JUL-03	FRIDAY	1_Hr_COMP	410	Specific Conductance	1500	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	410	pH	3.5	pH
04-JUL-03	FRIDAY	1_Hr_COMP	510	Specific Conductance	1400	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	510	pH	5	pH
04-JUL-03	FRIDAY	1_Hr_COMP	610	Specific Conductance	1400	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	610	pH	6.7	pH
04-JUL-03	FRIDAY	1_Hr_COMP	710	Specific Conductance	1400	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	710	pH	6.9	pH
04-JUL-03	FRIDAY	1_Hr_COMP	810	Specific Conductance	1600	umhos/cm
04-JUL-03	FRIDAY	1_Hr_COMP	810	pH	7	pH
04-JUL-03	FRIDAY	COMP_CONDUCT	1017	Specific Conductance	3000	umhos/cm
04-JUL-03	FRIDAY	COMP_PH	1017	pH	11.4	pH
04-JUL-03	FRIDAY	GRAB	1027	Specific Conductance	1500	umhos/cm
04-JUL-03	FRIDAY	GRAB	1027	pH	6.3	pH
11-JUL-03	FRIDAY	1_Hr_COMP	945	Specific Conductance	2300	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	945	pH	5.3	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1045	Specific Conductance	1900	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1045	pH	4.9	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1145	Specific Conductance	2200	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1145	pH	4.9	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1245	Specific Conductance	5200	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1245	pH	11.8	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1345	Specific Conductance	2700	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1345	pH	9	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1445	Specific Conductance	2700	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1445	pH	4.4	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1545	Specific Conductance	5000	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1545	pH	2.6	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1645	Specific Conductance	2800	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1645	pH	2.5	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1745	Specific Conductance	3200	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1745	pH	3	pH
11-JUL-03	FRIDAY	1_Hr_COMP	1845	Specific Conductance	3000	umhos/cm
11-JUL-03	FRIDAY	1_Hr_COMP	1845	pH	11	pH
12-JUL-03	SATURDAY	COMP_CONDUCT	955	Specific Conductance	3200	umhos/cm
12-JUL-03	SATURDAY	COMP_PH	955	pH	3.5	pH
12-JUL-03	SATURDAY	GRAB	1000	Specific Conductance	3500	umhos/cm
12-JUL-03	SATURDAY	GRAB	1000	pH	11.7	pH
19-JUL-03	SATURDAY	1_Hr_COMP	915	Specific Conductance	1400	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	915	pH	4.9	pH
19-JUL-03	SATURDAY	1_Hr_COMP	1015	Specific Conductance	2200	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1015	pH	10.2	pH
19-JUL-03	SATURDAY	1_Hr_COMP	1115	Specific Conductance	2100	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1115	pH	7.2	pH
19-JUL-03	SATURDAY	1_Hr_COMP	1215	Specific Conductance	1600	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1215	pH	4.7	pH
19-JUL-03	SATURDAY	1_Hr_COMP	1315	Specific Conductance	1600	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1315	pH	6	pH
19-JUL-03	SATURDAY	1_Hr_COMP	1415	Specific Conductance	2800	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1415	pH	10.8	pH
19-JUL-03	SATURDAY	1_Hr_COMP	1515	Specific Conductance	2000	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1515	pH	2.8	pH
19-JUL-03	SATURDAY	1_Hr_COMP	1615	Specific Conductance	2200	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1615	pH	2.8	pH
19-JUL-03	SATURDAY	1_Hr_COMP	1715	Specific Conductance	3900	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1715	pH	9.4	pH
19-JUL-03	SATURDAY	1_Hr_COMP	1815	Specific Conductance	3200	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1815	pH	7.2	pH
19-JUL-03	SATURDAY	1_Hr_COMP	1915	Specific Conductance	2100	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1915	pH	5.9	pH
19-JUL-03	SATURDAY	1_Hr_COMP	2015	Specific Conductance	2000	umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	2015	pH	4.3	pH

City of Mexicali
Site 19

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
19-JUL-03	SATURDAY	1_Hr_COMP	2115 Specific Conductance	1900 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	2115 pH	5.2 pH
19-JUL-03	SATURDAY	1_Hr_COMP	2215 Specific Conductance	1900 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	2215 pH	6.4 pH
19-JUL-03	SATURDAY	1_Hr_COMP	2315 Specific Conductance	13900 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	2315 pH	6.3 pH
20-JUL-03	SUNDAY	1_Hr_COMP	15 Specific Conductance	5600 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	15 pH	5.5 pH
20-JUL-03	SUNDAY	1_Hr_COMP	115 Specific Conductance	2100 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	115 pH	9.6 pH
20-JUL-03	SUNDAY	1_Hr_COMP	215 Specific Conductance	5300 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	215 pH	7.4 pH
20-JUL-03	SUNDAY	1_Hr_COMP	315 Specific Conductance	2000 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	315 pH	6.6 pH
20-JUL-03	SUNDAY	1_Hr_COMP	415 Specific Conductance	1800 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	415 pH	7.1 pH
20-JUL-03	SUNDAY	1_Hr_COMP	515 Specific Conductance	1800 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	515 pH	7.9 pH
20-JUL-03	SUNDAY	1_Hr_COMP	615 Specific Conductance	1800 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	615 pH	7.8 pH
20-JUL-03	SUNDAY	1_Hr_COMP	715 Specific Conductance	1800 umhos/cm
20-JUL-03	SUNDAY	1_Hr_COMP	715 pH	8 pH
20-JUL-03	SUNDAY	COMP_CONDUCT	925 Specific Conductance	3000 umhos/cm
20-JUL-03	SUNDAY	COMP_PH	925 pH	6.6 pH
20-JUL-03	SUNDAY	GRAB	935 Specific Conductance	1900 umhos/cm
20-JUL-03	SUNDAY	GRAB	935 pH	8.3 pH

SITE 20

City of Mexicali
Site 20

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
25-JUN-03	WEDNESDAY	1_Hr_COMP	1005 Specific Conductance	1200 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1005 pH	7.5 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1105 Specific Conductance	1300 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1105 pH	8.3 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1205 Specific Conductance	1200 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1205 pH	8.5 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1305 Specific Conductance	1100 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1305 pH	8.5 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1405 Specific Conductance	1100 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1405 pH	8.4 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1505 Specific Conductance	1100 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1505 pH	8.5 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1605 Specific Conductance	1100 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1605 pH	7.9 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1705 Specific Conductance	1100 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1705 pH	8.9 pH
25-JUN-03	WEDNESDAY	1_Hr_COMP	1805 Specific Conductance	2200 umhos/cm
25-JUN-03	WEDNESDAY	1_Hr_COMP	1805 pH	8.6 pH
26-JUN-03	THURSDAY	COMP_CONDUCT	1036 Specific Conductance	1300 umhos/cm
26-JUN-03	THURSDAY	COMP_PH	1036 pH	8.6 pH
26-JUN-03	THURSDAY	GRAB	1046 Specific Conductance	1000 umhos/cm
26-JUN-03	THURSDAY	GRAB	1046 pH	8.8 pH
04-JUL-03	FRIDAY	GRAB	1106 Specific Conductance	1500 umhos/cm
04-JUL-03	FRIDAY	GRAB	1106 pH	8.6 pH
12-JUL-03	SATURDAY	GRAB	1026 Specific Conductance	1700 umhos/cm
12-JUL-03	SATURDAY	GRAB	1026 pH	7.5 pH

SITE 21

City of Mexicali
Site 21

DATE	DAY OF WEEK	SAMPLE_TYPE	TIME ANALYTE	VALUE UNITS
19-JUL-03	SATURDAY	1_Hr_COMP	830 Specific Conductance	1700 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	830 pH	7.3 pH
19-JUL-03	SATURDAY	1_Hr_COMP	930 Specific Conductance	1800 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	930 pH	8 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1030 Specific Conductance	2000 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1030 pH	7.3 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1130 Specific Conductance	1800 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1130 pH	7.9 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1230 Specific Conductance	2200 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1230 pH	7.5 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1330 Specific Conductance	8600 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1330 pH	7.3 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1430 Specific Conductance	2500 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1430 pH	7.9 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1530 Specific Conductance	2000 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1530 pH	7.3 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1630 Specific Conductance	2000 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1630 pH	8.3 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1730 Specific Conductance	2000 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1730 pH	8.2 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1830 Specific Conductance	2600 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1830 pH	7.7 pH
19-JUL-03	SATURDAY	1_Hr_COMP	1930 Specific Conductance	1700 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	1930 pH	7.7 pH
19-JUL-03	SATURDAY	1_Hr_COMP	2030 Specific Conductance	1700 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	2030 pH	8.2 pH
19-JUL-03	SATURDAY	1_Hr_COMP	2130 Specific Conductance	1700 umhos/cm
19-JUL-03	SATURDAY	1_Hr_COMP	2130 pH	8.1 pH
20-JUL-03	SUNDAY	COMP_CONDUCT	1000 Specific Conductance	2600 umhos/cm
20-JUL-03	SUNDAY	COMP_PH	1000 pH	7.7 pH
20-JUL-03	SUNDAY	GRAB	1010 Specific Conductance	1450 umhos/cm
20-JUL-03	SUNDAY	GRAB	1010 pH	7.6 pH

LABORATORY TEST RESULTS

内

bat Docu

OBSERVATIONS

pH and Conductivity. The influents to the various pump stations and the main interceptors consistently showed normal pH and conductivity values. Upstream sites 900 and 1100 had some variability in conductivity with values as high as 6500 umho/cm. Sites 1200 and 1300 showed some pH variability with values ranging from 5.3 to 9.3. Extreme pH and conductivity values were detected at sites 1800 and 1900, with pH ranging from 2.5 up to 12.7 and conductivities up to 17,000 umho/cm. A pH of 2.5 denotes an extreme acidic condition and a pH of 12.7 an extreme basic or caustic condition. Conductivity is a measure of the dissolved solids present in a sample. A conductivity of 17,000 umho/cm is about six to nine times the average value commonly found in wastewaters.

Oil & Grease. This parameter was measured as “hexane extractable material” and it was observed at acceptable levels.

Total Petroleum Hydrocarbons. This parameter was measured as the silica gel treated portion of the hexane extractable material and it was detected consistently in the samples collected, at levels up to 37.4 mg/L.

Benzene and Ethylbenzene. These are components of gasoline and may be used separately as organic solvents. They were found at low levels at sites 100, 200, 300, 400, 700 and 1300.

Total Suspended Solids and Biochemical Oxygen Demand. These parameters determine the strength of a particular wastewater. Sites 800, 1100, 1500 and 2000 were found to have values significantly lower than a wastewater that is predominantly domestic.

Chemical Oxygen Demand. This parameter also reflects the strength of a wastewater and values commonly found are up to 1000 mg/L. Values ranging from 3000 to 14400 mg/L were detected at sites 1800 and 1900.

Methylene Blue Active Substances. This parameter measures the amount of common detergents in the wastewater. Sites 900, 1100, 1800, 1900, 2000 and 2001 were found to have values significantly lower than a wastewater that is predominantly domestic.

Ammonia-Nitrogen. The results at most sites are consistent with those commonly found in wastewaters of a predominantly domestic nature. Low values were observed at sites 800, 900, 1100 and 2000 and no ammonia-nitrogen was detected at sites 1800 and 1900.

Aluminum, Arsenic, Barium, Chromium, Copper, Lead, Manganese, Mercury, Selenium, Thallium and Zinc. These metals were detected in the collection system at concentrations commonly found in wastewaters.

Antimony. This compound is not commonly found in municipal wastewaters. At site 400 it was detected at 0.005 mg/L which is considered low, but at sites 1500 and 2000 it was

found at significantly higher levels (0.02 to 0.10 mg/L.) It is noteworthy to point out that it was detected at site 1500 in both of the samples collected and at site 2000 in the three samples collected.

Nickel. This metal was found throughout the collection system at typical low levels ranging from 0.01 to 0.2 mg/L, but at site 1400 it was found in all four samples collected at concentrations ranging from 0.04 to 1.6 mg/L.

Toluene. This compound was detected throughout the collection system at concentrations up to 340 ug/L at site 300. This compound is widely used as an organic solvent and as a degreaser.

Methylene Chloride and Tetrachloroethene. These compounds were detected throughout the collection system at levels up to 62 ug/L (site 300.) These compounds are widely used as degreasers in cleaning processes. Tetrachloroethene is commonly known as tetrachloroethylene.

Pesticides. Several pesticides were detected at low levels throughout the collection system. Lindane (up to 3.3 ug/L at site 100,) Chloryrifos (up to 5.4 ug/L at site 300,) Diazinon (up to 2.6 ug/L at site 200,) Parathion (0.55 ug/L at site 300) and Malathion (up to 1.1 ug/L at site 600.)

Bromodichloromethane, Chloroform and Dibromochloromethane. These compounds are known collectively as Trihalomethanes and are normal byproducts when chlorine is used in the disinfection process. These compounds were observed throughout the collection system at low values consistent with wastewaters of this type.

Phthalates. Several compounds of the phthalate family were detected throughout the collection system at levels commonly found in wastewaters (up to 200 ug/L) with the exception of a value of 4520 ug/L reported for the only sample collected at site 2100. These compounds are widely used as plasticizers.

Phenol and 4-chloro-3-methylphenol. Values ranging from "not detected" up to 120 ug/L were observed throughout the collection system. The presence of this type of compounds at these levels is common in wastewaters as they are widely used as disinfectants.

Dichlorobenzenes. These compounds are commonly found in domestic and industrial wastewaters at the concentrations detected in this study. They are a component of many disinfectants.

Trichlorofluoromethane. This compound was detected at a concentration of 44.7 ug/L at site 300. It belongs to the "freon" family and it is used as refrigerant.

ACTIONS (DGE and CESPM)

Based on the laboratory results from this study, DGE and CESPM have taken the following actions:

Continued the sampling program, including sites upstream from the ones where potential problems were detected in this study, to find the source of discharges exceeding the maximum concentrations allowed for the parameters listed in the Mexican regulations.

Continuous monitoring programs were established for the specific industries identified in this study as potentially being in noncompliance with discharge limits. The samples were analyzed by a laboratory certified by the Department of Ecology and by CESPM.

A sampling plan was developed for other sites of concern in Mexicali:

- Upstream from Pump Station 4
- El Vigia Industrial Park
- Mexicali II Industrial Park
- EX-XXI Industrial Park
- Accuride I and II industries
- Cesar Sanchez Quiñones industry
- Novamex industry

Some administrative actions have taken place to facilitate the enforcement of industrial wastewater discharge regulations:

CESPM's laboratory received certification from the Department of Ecology, enabling their laboratory analyses to have legal support for enforcement actions.

The Department of Ecology and CESPM signed an agreement enabling CESPM personnel to inspect industries, businesses and service establishments to verify their compliance with industrial wastewater discharge regulations.

CONCLUSIONS AND RECOMMENDATIONS

1. There is significant lack of control, with respect to pH and conductivity, at sites 1800 and 1900. These discharges may damage the pipes in the collection system and may cause operational problems at the treatment plant. Further monitoring and follow-up is required to identify and control these specific discharges.
2. Total Petroleum Hydrocarbons, Benzene and Ethylbenzene are indicators of the presence of gasoline. A program should be developed to monitor and control potential discharges from gas stations, auto repair and other facilities that might use gasoline as a cleaning solvent.
3. In general, there are no problems associated with the presence of metals in the collection system. Monitoring upstream from sites 1400, 1500 and 2000 is recommended to track potential discharges of antimony and nickel. The establishment of a monitoring program for metals is recommended, so that trends and potential problems can be detected for CESPM and DGE to initiate corrective actions and be proactive in enforcing compliance with the limits established by the Mexican official norm dealing with wastewater discharges into the sewer system (NOM-002-SEMARNAT-1996.)
4. The establishment of regulations for the wastewater discharge of organic compounds, such as toluene, methylene chloride and tetrachloroethene, and a strong monitoring program are recommended to control the presence of these compounds in the collection system. This control is also important to protect the quality of the sludge generated at the treatment plants.
5. Pesticides have a high potential to cause harmful toxicity effects, so it is important to continue monitoring their presence in the collection system. In particular, it is recommended to analyze the wastewater treatment plant effluents for these compounds, to obtain information regarding the effect of the treatment processes on their removal.
6. The samples collected and analyzed during the six-month duration of this project is a limited number considering the size of the collection system. The sampling of the wastewater treatment plants must be continued and expanded to include at least the parameters found in this study to be of concern, to obtain timely information that can help protect the integrity of the collection system, the efficient operation of the treatment plants, the quality of the effluents and the quality of the sludges. This project focused primarily on major pump stations and interceptors, but the very limited number of samples collected at upstream sites and closer to industrial discharges, identified areas of concern and indicated the need of extensive sampling at these sites and the need to expand the monitoring to other upstream sites and direct discharges.

7. CESPM's current available resources in the area of sampling and analyses of wastewater are not sufficient to carry out the above recommendations. Additional support is needed in the form of personnel, equipment and facilities.



